

Τετάρτη, 31 Αύγουστος 2022		Απολογισμός λειτουργίας ΗΣ Σερίφου																								
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,287	1,178	1,096	1,295	1,405	1,857	1,896	2,001	2,135	2,160	1,911	1,928	1,885	1,834	1,807	1,846	1,814	1,787	1,733	1,694	2,281	2,391	2,341	1,973	43,53
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MWM TBD603V12)	0,3																									Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G10 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη
2 ΦΟΡΗΤΑ Η/Ζ	1						1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	2	2	2	1	Διαθέσιμη

Παρασκευή, 2 Σεπτέμβριος 2022		Απολογισμός λειτουργίας ΗΣ Σερίφου																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,210	1,147	1,471	1,410	1,396	1,341	1,355	1,401	1,592	1,732	1,746	1,763	1,778	1,817	1,786	1,822	1,882	1,896	2,004	2,172	2,723	2,618	2,878	2,504	43,44	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MWM TBD603V12)	0,3																										Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	1																					1	1	1	1		Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G10 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη
2 ΦΟΡΗΤΑ Η/Ζ	1									1	1	1	1	1	1	1	1	1	1	1	1	2	2	2	1		Διαθέσιμη

Κυριακή, 4 Σεπτέμβριος 2022		Απολογισμός λειτουργίας ΗΣ Σερίφου																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,174	1,089	1,290	1,461	1,447	1,414	1,421	1,429	1,545	1,867	1,746	1,858	1,868	1,877	1,807	1,789	1,727	1,855	1,953	2,510	2,614	2,492	1,838	1,733	41,81	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MWM TBD603V12)	0,3																										Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G10 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη
2 ΦΟΡΗΤΑ Η/Ζ	1										1	1	1	1	1	1	1	1	1	1	2	2	2	1	1	Διαθέσιμη	

Τρίτη, 6 Σεπτέμβριος 2022		Απολογισμός λειτουργίας ΗΣ Σερίφου																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,299	1,195	1,096	1,069	1,054	1,035	1,121	1,117	1,234	1,358	1,402	1,447	1,418	1,376	1,397	1,357	1,293	1,365	1,481	1,621	1,827	1,676	1,532	1,238	32,01	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MWM TBD603V12)	0,3																										Διαθέσιμη
G3 (MITSUBISH S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (MITSUBISH S16R-PTA)	1																									Διαθέσιμη	
G5 (MITSUBISH S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G10 (MITSUBISH S16R-PTA)	1																									Διαθέσιμη	
2 ΦΟΡΗΤΑ Η/Ζ	1																				1	1	1			Διαθέσιμη	