

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 22 Απριλίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Τρίτη, 22 Απριλίου 2025	00:00	1,189		1	1			
	01:00	1,113		1	1			
	02:00	1,049		1	1			
	03:00	1,048		1	1			
	04:00	1,036		1	1			
	05:00	1,020		1	1			
	06:00	1,018		1	1			
	07:00	1,059		1	1			
	08:00	1,158		1	1			
	09:00	1,248		1	1			
	10:00	1,383		1	1			
	11:00	1,348		1	1			
	12:00	1,319		1		1		
	13:00	1,240		1		1		
	14:00	1,279		1		1		
	15:00	1,391		1		1		
	16:00	1,253		1		1		
	17:00	1,325		1		1		
	18:00	1,438		1		1		
	19:00	1,479		1		1		
	20:00	1,579		1		1		
	21:00	1,530		1		1		
	22:00	1,451		1		1		
	23:00	1,314		1		1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 23 Απριλίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Τετάρτη, 23 Απριλίου 2025	00:00	1,177		1		1		
	01:00	1,123		1		1		
	02:00	1,077		1		1		
	03:00	1,011		1		1		
	04:00	1,000		1		1		
	05:00	1,016		1		1		
	06:00	1,014		1		1		
	07:00	1,064		1		1		
	08:00	1,126		1		1		
	09:00	1,158		1		1		
	10:00	1,145		1		1		
	11:00	1,167		1		1		
	12:00	1,140		1		1		
	13:00	1,216		1		1		
	14:00	1,154		1		1		
	15:00	1,108		1		1		
	16:00	1,081		1		1		
	17:00	1,097		1		1		
	18:00	1,190		1		1		
	19:00	1,290		1		1		
	20:00	1,393		1		1		
	21:00	1,389		1		1		
	22:00	1,309		1		1		
	23:00	1,228		1		1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 24 Απριλίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Πέμπτη, 24 Απριλίου 2025	00:00	1,104		1		1		
	01:00	0,998		1		1		
	02:00	0,996				1		
	03:00	0,988				1		
	04:00	0,984				1		
	05:00	0,974				1		
	06:00	0,976				1		
	07:00	0,992				1		
	08:00	1,089		1		1		
	09:00	1,213		1		1		
	10:00	1,291		1		1		
	11:00	1,342		1		1		
	12:00	1,331		1		1		
	13:00	1,296		1		1		
	14:00	1,231		1		1		
	15:00	1,144		1		1		
	16:00	1,140		1		1		
	17:00	1,163		1		1		
	18:00	1,231		1		1		
	19:00	1,336		1		1		
	20:00	1,508		1		1		
	21:00	1,456		1		1		
	22:00	1,323		1		1		
	23:00	1,203		1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 25 Απριλίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Παρασκευή, 25 Απριλίου 2025	00:00	1,084		1		1		
	01:00	1,021				1		
	02:00	1,022				1		
	03:00	0,993				1		
	04:00	0,987				1		
	05:00	1,000				1		
	06:00	1,010				1		
	07:00	1,008				1		
	08:00	1,080		1		1		
	09:00	1,165		1		1		
	10:00	1,100		1		1		
	11:00	1,144		1		1		
	12:00	1,124		1		1		
	13:00	1,242		1		1		
	14:00	1,209		1		1		
	15:00	1,117		1		1		
	16:00	1,097		1		1		
	17:00	1,095		1		1		
	18:00	1,181		1		1		
	19:00	1,239		1		1		
	20:00	1,412		1		1		
	21:00	1,399		1		1		
	22:00	1,299		1		1		
	23:00	1,188		1		1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 26 Απριλίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Σάββατο, 26 Απριλίου 2025	00:00	1,079		1		1		
	01:00	1,040				1		
	02:00	0,953				1		
	03:00	0,949				1		
	04:00	0,948				1		
	05:00	0,934				1		
	06:00	0,953				1		
	07:00	1,004				1		
	08:00	1,096		1		1		
	09:00	1,162		1		1		
	10:00	1,183		1		1		
	11:00	1,116		1		1		
	12:00	1,107		1		1		
	13:00	1,147		1		1		
	14:00	1,073		1		1		
	15:00	1,139		1		1		
	16:00	1,099		1		1		
	17:00	1,093		1		1		
	18:00	1,155		1		1		
	19:00	1,250		1		1		
	20:00	1,413		1		1		
	21:00	1,391		1		1		
	22:00	1,308		1		1		
	23:00	1,190		1		1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 27 Απριλίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Κυριακή, 27 Απριλίου 2025	00:00	1,067		1		1		
	01:00	1,020		1		1		
	02:00	0,981				1		
	03:00	0,963				1		
	04:00	0,953				1		
	05:00	0,959				1		
	06:00	0,949				1		
	07:00	1,014				1		
	08:00	1,051				1		
	09:00	1,056		1		1		
	10:00	1,090		1		1		
	11:00	1,056		1		1		
	12:00	1,072		1		1		
	13:00	1,097		1		1		
	14:00	1,063		1		1		
	15:00	1,044		1		1		
	16:00	1,091		1		1		
	17:00	1,077		1		1		
	18:00	1,145		1		1		
	19:00	1,287		1		1		
	20:00	1,392		1		1		
	21:00	1,401		1		1		
	22:00	1,230		1		1		
	23:00	1,119		1		1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 28 Απριλίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
Δευτέρα, 28 Απριλίου 2025	00:00	1,064				1		
	01:00	1,015				1		
	02:00	0,976				1		
	03:00	1,002				1		
	04:00	1,042				1		
	05:00	0,985				1		
	06:00	0,985				1		
	07:00	1,047				1		
	08:00	1,161			1	1		
	09:00	1,170			1	1		
	10:00	1,157			1	1		
	11:00	1,123			1	1		
	12:00	1,077			1	1		
	13:00	1,130			1	1		
	14:00	1,143			1	1		
	15:00	1,098			1	1		
	16:00	1,137			1	1		
	17:00	1,128			1	1		
	18:00	1,181			1	1		
	19:00	1,354			1	1		
	20:00	1,498			1	1		
	21:00	1,504			1	1		
	22:00	1,377			1	1		
	23:00	1,207			1	1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης