

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 12 Μαρτίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Τετάρτη, 12 Μαρτίου 2025	00:00	0,939	1					
	01:00	0,886	1					
	02:00	0,857	1					
	03:00	0,846	1					
	04:00	0,849	1					
	05:00	0,866	1					
	06:00	0,901	1					
	07:00	0,924	1					
	08:00	0,910	1					
	09:00	0,898	1					
	10:00	0,877	1					
	11:00	0,933	1					
	12:00	0,916	1					
	13:00	0,910	1					
	14:00	0,927	1					
	15:00	0,979	1			1		
	16:00	1,038	1			1		
	17:00	1,109	1			1		
	18:00	1,236	1			1		
	19:00	1,328	1			1		
	20:00	1,317	1			1		
	21:00	1,284	1			1		
	22:00	1,200	1			1		
	23:00	1,062	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 13 Μαρτίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Πέμπτη, 13 Μαρτίου 2025	00:00	0,932	1					
	01:00	0,879	1					
	02:00	0,847	1					
	03:00	0,830	1					
	04:00	0,830	1					
	05:00	0,848	1					
	06:00	0,880	1					
	07:00	0,899	1					
	08:00	0,898	1					
	09:00	0,872	1					
	10:00	0,871	1					
	11:00	0,923	1					
	12:00	0,932	1					
	13:00	0,920	1					
	14:00	0,911	1					
	15:00	0,949	1			1		
	16:00	1,000	1			1		
	17:00	1,085	1			1		
	18:00	1,242	1			1		
	19:00	1,345	1			1		
	20:00	1,341	1			1		
	21:00	1,284	1			1		
	22:00	1,186	1			1		
	23:00	1,062	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 14 Μαρτίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Παρασκευή, 14 Μαρτίου 2025	00:00	0,938	1					
	01:00	0,884	1					
	02:00	0,851	1					
	03:00	0,836	1					
	04:00	0,835	1					
	05:00	0,852	1					
	06:00	0,882	1					
	07:00	0,924	1					
	08:00	0,915	1					
	09:00	0,903	1					
	10:00	0,909	1					
	11:00	0,937	1					
	12:00	0,956	1			1		
	13:00	0,974	1			1		
	14:00	0,978	1			1		
	15:00	0,994	1			1		
	16:00	1,024	1			1		
	17:00	1,075	1			1		
	18:00	1,212	1			1		
	19:00	1,307	1			1		
	20:00	1,324	1			1		
	21:00	1,286	1			1		
	22:00	1,200	1			1		
	23:00	1,050	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Σάββατο, 15 Μαρτίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ε Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Σάββατο, 15 Μαρτίου 2025	00:00	0,962	1			1		
	01:00	0,908	1					
	02:00	0,866	1					
	03:00	0,840	1					
	04:00	0,826	1					
	05:00	0,832	1					
	06:00	0,857	1					
	07:00	0,890	1					
	08:00	0,919	1					
	09:00	0,976	1			1		
	10:00	1,074	1			1		
	11:00	1,143	1			1		
	12:00	1,180	1			1		
	13:00	1,192	1			1		
	14:00	1,172	1			1		
	15:00	1,159	1			1		
	16:00	1,137	1			1		
	17:00	1,117	1			1		
	18:00	1,201	1			1		
	19:00	1,302	1			1		
	20:00	1,329	1			1		
	21:00	1,309	1			1		
	22:00	1,239	1			1		
	23:00	1,082	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 16 Μαρτίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Κυριακή, 16 Μαρτίου 2025	00:00	1,063	1			1		
	01:00	1,004	1			1		
	02:00	0,961	1			1		
	03:00	0,925	1					
	04:00	0,896	1					
	05:00	0,893	1					
	06:00	0,901	1					
	07:00	0,926	1					
	08:00	0,955	1			1		
	09:00	1,036	1			1		
	10:00	1,138	1			1		
	11:00	1,215	1			1		
	12:00	1,235	1			1		
	13:00	1,242	1			1		
	14:00	1,213	1			1		
	15:00	1,172	1			1		
	16:00	1,143	1			1		
	17:00	1,106	1			1		
	18:00	1,153	1			1		
	19:00	1,273	1			1		
	20:00	1,307	1			1		
	21:00	1,292	1			1		
	22:00	1,234	1			1		
	23:00	1,061	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 17 Μαρτίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Δευτέρα, 17 Μαρτίου 2025	00:00	1,004	1			1		
	01:00	0,940	1					
	02:00	0,895	1					
	03:00	0,874	1					
	04:00	0,869	1					
	05:00	0,877	1					
	06:00	0,902	1					
	07:00	0,936	1					
	08:00	0,959	1			1		
	09:00	1,014	1			1		
	10:00	1,116	1			1		
	11:00	1,209	1			1		
	12:00	1,244	1			1		
	13:00	1,250	1			1		
	14:00	1,237	1			1		
	15:00	1,196	1			1		
	16:00	1,090	1			1		
	17:00	1,106	1			1		
	18:00	1,138	1			1		
	19:00	1,250	1			1		
	20:00	1,299	1			1		
	21:00	1,304	1			1		
	22:00	1,239	1			1		
	23:00	1,071	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 18 Μαρτίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Τρίτη, 18 Μαρτίου 2025	00:00	0,988	1			1		
	01:00	0,930	1					
	02:00	0,895	1					
	03:00	0,883	1					
	04:00	0,883	1					
	05:00	0,898	1					
	06:00	0,928	1					
	07:00	0,972	1			1		
	08:00	1,003	1			1		
	09:00	0,998	1			1		
	10:00	1,100	1			1		
	11:00	1,093	1			1		
	12:00	1,160	1			1		
	13:00	1,064	1			1		
	14:00	1,063	1			1		
	15:00	1,082	1			1		
	16:00	1,099	1			1		
	17:00	1,074	1			1		
	18:00	1,154	1			1		
	19:00	1,290	1			1		
	20:00	1,345	1			1		
	21:00	1,338	1			1		
	22:00	1,253	1			1		
	23:00	1,084	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης