

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 19 Μαρτίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Τετάρτη, 19 Μαρτίου 2025	00:00	0,865	1					
	01:00	0,811	1					
	02:00	0,777	1					
	03:00	0,760	1					
	04:00	0,762	1					
	05:00	0,786	1					
	06:00	0,823	1					
	07:00	0,850	1					
	08:00	0,887	1					
	09:00	0,913	1					
	10:00	0,907	1					
	11:00	0,942	1			1		
	12:00	0,947	1			1		
	13:00	1,039	1			1		
	14:00	1,063	1			1		
	15:00	1,070	1			1		
	16:00	1,095	1			1		
	17:00	1,184	1			1		
	18:00	1,350	1			1		
	19:00	1,475	1			1		
	20:00	1,451	1			1		
	21:00	1,370	1			1		
	22:00	1,241	1			1		
	23:00	1,070	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 20 Μαρτίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Πέμπτη, 20 Μαρτίου 2025	00:00	0,950	1			1		
	01:00	0,921	1					
	02:00	0,883	1					
	03:00	0,858	1					
	04:00	0,853	1					
	05:00	0,873	1					
	06:00	0,908	1					
	07:00	0,934	1					
	08:00	0,950	1			1		
	09:00	0,954	1			1		
	10:00	0,958	1			1		
	11:00	0,988	1			1		
	12:00	0,962	1			1		
	13:00	0,954	1			1		
	14:00	0,960	1			1		
	15:00	1,015	1			1		
	16:00	1,094	1			1		
	17:00	1,228	1			1		
	18:00	1,442	1			1		
	19:00	1,572	1			1		
	20:00	1,548	1			1		
	21:00	1,456	1			1		
	22:00	1,313	1			1		
	23:00	1,129	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 21 Μαρτίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Παρασκευή, 21 Μαρτίου 2025	00:00	1,002	1			1		
	01:00	0,945	1			1		
	02:00	0,906	1					
	03:00	0,885	1					
	04:00	0,882	1					
	05:00	0,901	1					
	06:00	0,942	1			1		
	07:00	0,985	1			1		
	08:00	0,995	1			1		
	09:00	0,988	1			1		
	10:00	0,961	1			1		
	11:00	0,925	1					
	12:00	0,894	1					
	13:00	0,892	1					
	14:00	0,904	1					
	15:00	0,937	1					
	16:00	1,019	1			1		
	17:00	1,162	1			1		
	18:00	1,377	1			1		
	19:00	1,503	1			1		
	20:00	1,480	1			1		
	21:00	1,397	1			1		
	22:00	1,278	1			1		
	23:00	1,124	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 22 Μαρτίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Σάββατο, 22 Μαρτίου 2025	00:00	0,959	1			1		
	01:00	0,910	1					
	02:00	0,877	1					
	03:00	0,856	1					
	04:00	0,851	1					
	05:00	0,864	1					
	06:00	0,899	1					
	07:00	0,930	1					
	08:00	0,927	1					
	09:00	0,924	1					
	10:00	0,857	1					
	11:00	0,882	1					
	12:00	0,862	1					
	13:00	0,859	1					
	14:00	0,860	1					
	15:00	0,894	1					
	16:00	0,945	1			1		
	17:00	1,076	1			1		
	18:00	1,305	1			1		
	19:00	1,455	1			1		
	20:00	1,439	1			1		
	21:00	1,370	1			1		
	22:00	1,249	1			1		
	23:00	1,112	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ			Προτεινόμενος ΗΕΠ		Κυριακή, 23 Μαρτίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Κυριακή, 23 Μαρτίου 2025	00:00	0,921	1					
	01:00	0,867	1					
	02:00	0,834	1					
	03:00	0,818	1					
	04:00	0,818	1					
	05:00	0,834	1					
	06:00	0,867	1					
	07:00	0,909	1					
	08:00	0,896	1					
	09:00	0,886	1					
	10:00	0,879	1					
	11:00	0,883	1					
	12:00	0,875	1					
	13:00	0,867	1					
	14:00	0,874	1					
	15:00	0,883	1					
	16:00	0,897	1					
	17:00	0,945	1			1		
	18:00	1,187	1			1		
	19:00	1,311	1			1		
	20:00	1,292	1			1		
	21:00	1,223	1			1		
	22:00	1,119	1			1		
	23:00	1,003	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 24 Μαρτίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Δευτέρα, 24 Μαρτίου 2025	00:00	0,882	1					
	01:00	0,840	1					
	02:00	0,819	1					
	03:00	0,812	1					
	04:00	0,819	1					
	05:00	0,838	1					
	06:00	0,868	1					
	07:00	0,899	1					
	08:00	0,918	1					
	09:00	0,914	1					
	10:00	0,924	1					
	11:00	1,011	1			1		
	12:00	1,007	1			1		
	13:00	0,936	1					
	14:00	0,936	1					
	15:00	0,943	1			1		
	16:00	0,961	1			1		
	17:00	0,986	1			1		
	18:00	1,138	1			1		
	19:00	1,297	1			1		
	20:00	1,290	1			1		
	21:00	1,229	1			1		
	22:00	1,122	1			1		
	23:00	0,994	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 25 Μαρτίου 2025			
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
Τρίτη, 25 Μαρτίου 2025	00:00	0,890	1					
	01:00	0,847	1					
	02:00	0,815	1					
	03:00	0,798	1					
	04:00	0,792	1					
	05:00	0,802	1					
	06:00	0,824	1					
	07:00	0,849	1					
	08:00	0,873	1					
	09:00	0,915	1					
	10:00	0,995	1			1		
	11:00	1,049	1			1		
	12:00	1,101	1			1		
	13:00	1,130	1			1		
	14:00	1,146	1			1		
	15:00	1,145	1			1		
	16:00	1,130	1			1		
	17:00	1,114	1			1		
	18:00	1,180	1			1		
	19:00	1,328	1			1		
	20:00	1,340	1			1		
	21:00	1,306	1			1		
	22:00	1,207	1			1		
	23:00	1,062	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης