

[illegible]

[illegible]

[illegible]

Κυριακή, 31 Δεκέμβριος 2023		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,17	1,07	1,05	1,03	1,05	1,11	1,08	1,21	1,23	1,29	1,38	1,44	1,48	1,38	1,40	1,40	1,47	1,66	1,71	1,05	1,70	1,64	1,34	1,07	31,37
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																					1	1	1		Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	1,1			1	1	1	1	1	1	1												1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1								1	1	1	1	1	1	1	1	1	1	1					Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Παρατηρήσεις: Σημειώνεται ότι κατά το διάστημα 19:24-19:55 σημειώθηκε γενική διακοπή.

[illegible]

[illegible]

[illegible]

Τετάρτη, 10 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,94	0,82	0,82	0,79	0,77	0,79	0,86	1,09	1,43	1,52	1,42	1,25	1,22	1,19	1,25	1,30	1,33	1,45	1,62	1,64	1,60	1,52	1,36	1,17	29,14	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1	1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1													1	1												Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1	1			1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 9 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,89	0,81	0,78	0,75	0,75	0,77	0,82	0,96	1,33	1,40	1,41	1,55	1,67	1,53	1,44	1,10	1,19	1,37	1,50	1,47	1,44	1,39	1,26	1,08	28,66	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1													1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1								1	1																	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1										1	1	1														Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 8 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,85	0,77	0,76	0,73	0,73	0,76	0,84	0,98	1,34	1,37	1,38	1,41	1,41	1,40	1,41	1,35	1,37	1,52	1,63	1,60	1,44	1,28	1,18	1,02	28,54	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1								1	1																	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 7 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,87	0,80	0,75	0,73	0,73	0,73	0,77	0,84	1,20	1,24	1,26	1,39	1,40	1,44	1,35	1,10	1,11	1,26	1,30	1,29	1,29	1,20	1,10	0,96	26,13	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1									1	1	1					1	1	1								Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1				1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 6 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,89	0,79	0,75	0,75	0,75	0,76	0,83	0,89	0,89	0,83	0,80	0,87	0,89	1,01	0,87	0,91	1,02	1,16	1,26	1,27	1,20	1,15	1,09	0,98	22,63	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1														1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 5 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,86	0,80	0,77	0,75	0,74	0,76	0,85	1,00	1,25	1,00	0,96	0,96	0,94	0,92	0,92	0,96	1,01	1,19	1,32	1,31	1,35	1,26	1,14	0,99	24,04	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1										1	1	1	1	1	1	1	1	1	1							Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1								1	1											1	1	1	1	1		Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 4 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,87	0,80	0,78	0,76	0,73	0,76	0,79	0,93	1,13	1,22	1,23	1,31	1,38	1,51	1,48	1,51	1,51	1,60	1,61	1,40	1,35	1,26	1,12	0,97	28,00	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1								1	1																	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 17 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,96	0,84	0,83	0,80	0,80	0,85	0,94	1,06	1,26	1,27	1,18	1,12	1,17	1,20	1,12	1,15	1,22	1,36	1,52	1,55	1,58	1,53	1,30	1,07	27,68	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1									1	1																Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1				1	1						1	1	1	1									Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1											1	1	1					1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 16 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,04	0,93	0,91	0,85	0,85	0,87	0,97	1,14	1,35	1,60	1,61	1,66	1,69	1,66	1,63	1,65	1,72	1,83	1,92	1,87	1,86	1,77	1,38	1,15	33,90	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																		1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1											1	1	1					Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 15 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,06	0,92	0,90	0,87	0,86	0,91	1,00	1,17	1,56	1,62	1,54	1,57	1,61	1,76	1,73	1,49	1,48	1,62	1,80	1,75	1,80	1,69	1,54	1,29	33,54	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1									1	1					1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1												Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 14 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,11	0,98	0,92	0,89	0,88	0,91	0,97	1,05	1,35	1,42	1,47	1,44	1,50	1,58	1,58	1,73	1,89	2,02	2,09	2,07	2,08	1,99	1,53	1,28	34,72	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1										1	1	1	1	1				Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1											Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 13 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,09	0,97	0,94	0,91	0,89	0,91	0,97	1,14	1,45	1,46	1,45	1,39	1,39	1,45	1,47	1,59	1,69	1,86	1,94	1,99	1,95	1,74	1,53	1,32	33,49	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1												1	1					Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 12 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,03	0,92	0,87	0,84	0,85	0,87	1,00	1,11	1,39	1,57	1,63	1,67	1,57	1,47	1,51	1,52	1,49	1,59	1,62	1,64	1,80	1,68	1,49	1,26	32,41	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1	1											1	1	1								1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1							1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1					1	1	1	1	1	1					Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 11 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,00	0,89	0,86	0,82	0,80	0,82	0,93	1,15	1,37	1,38	1,37	1,42	1,55	1,62	1,54	1,62	1,69	1,82	1,84	1,85	1,77	1,73	1,49	1,19	32,51	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1						1	1																			Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1							1	1	1	1	1	1	1	1	1										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 24 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,97	0,88	0,85	0,84	0,82	0,87	0,98	1,06	1,22	1,21	1,15	1,15	1,13	1,03	1,04	1,15	1,24	1,40	1,64	1,68	1,64	1,53	1,41	1,18	28,09	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																		1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1							1	1									1									Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 23 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,92	0,83	0,82	0,80	0,77	0,80	0,89	1,04	1,14	1,24	1,23	1,26	1,27	1,26	1,25	1,31	1,42	1,55	1,70	1,62	1,56	1,47	1,32	1,14	28,61	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1							1	1					1	1												Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1				1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 22 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,84	0,76	0,73	0,76	0,73	0,76	0,83	0,97	1,16	1,21	1,14	1,16	1,18	1,20	1,22	1,29	1,35	1,44	1,57	1,63	1,59	1,51	1,24	1,05	27,31	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1																										Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 21 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		0,85	0,77	0,75	0,74	0,74	0,75	0,79	0,84	1,08	1,11	1,10	1,19	1,22	1,23	1,09	1,13	1,23	1,39	1,46	1,50	1,44	1,30	1,08	0,94	25,71
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1																			1	1					Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	1,1									1	1	1					1	1							1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1			1				1	1		Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Σάββατο, 20 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,86	0,78	0,76	0,75	0,75	0,76	0,80	0,89	1,16	1,21	1,22	1,25	1,29	1,33	1,24	1,23	1,26	1,37	1,49	1,47	1,40	1,34	1,11	0,97	26,71	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1								1	1	1	1	1	1											1		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1														1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 19 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,91	0,81	0,79	0,75	0,76	0,81	0,90	0,92	1,13	1,22	1,17	1,14	1,12	1,10	1,07	1,08	1,14	1,34	1,43	1,40	1,47	1,38	1,20	1,00	26,05	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1									1	1	1	1	1	1	1	1	1								1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1																		1	1	1	1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 18 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,93	0,82	0,81	0,77	0,77	0,81	0,88	1,02	1,18	1,28	1,29	1,28	1,24	1,29	1,42	1,41	1,44	1,55	1,62	1,64	1,64	1,54	1,26	1,06	28,94	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1									1																Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1				1	1	1	1	1	1	1																Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1																										Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 31 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,24	1,14	1,12	1,08	1,08	1,12	1,21	1,42	1,51	1,44	1,36	1,33	1,31	1,32	1,36	1,44	1,55	1,71	1,92	1,99	2,02	1,93	1,77	1,54	34,90	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																			1	1	1	1	1	1		Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1			1	1	1	1	1																			Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1	1	1				Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 30 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,15	1,01	0,99	0,94	0,94	0,99	1,08	1,29	1,52	1,49	1,39	1,41	1,48	1,57	1,63	1,75	1,80	1,95	2,06	2,06	2,01	1,96	1,80	1,51	35,78	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1	1							1	1									1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1		1	1	1		1	1																			Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 29 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,05	0,94	0,92	0,88	0,86	0,91	1,00	1,17	1,36	1,44	1,38	1,35	1,39	1,40	1,41	1,47	1,59	1,78	2,01	2,05	2,03	1,91	1,61	1,37	33,28	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																				1	1	1	1	1		Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1						1	1											1	1	1	1				Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1							Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 28 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,06	0,95	0,91	0,87	0,87	0,87	0,91	1,03	1,24	1,26	1,24	1,27	1,28	1,28	1,26	1,42	1,50	1,64	1,78	1,82	1,80	1,75	1,46	1,23	30,71	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1							1	1	1									1	1	1	1				Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 27 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,07	0,95	0,95	0,90	0,88	0,91	0,99	1,16	1,38	1,32	1,30	1,29	1,29	1,30	1,32	1,42	1,61	1,75	1,88	1,87	1,83	1,71	1,46	1,23	31,77	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1						1	1											1	1	1					Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 26 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,03	0,92	0,89	0,85	0,84	0,90	1,01	1,12	1,32	1,28	1,23	1,22	1,27	1,24	1,27	1,40	1,48	1,63	1,74	1,75	1,79	1,73	1,43	1,22	30,56	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1									1																	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1							1												1	1	1				Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 25 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,03	0,90	0,89	0,86	0,84	0,87	0,94	1,11	1,34	1,37	1,32	1,30	1,32	1,31	1,30	1,44	1,59	1,70	1,87	1,83	1,81	1,75	1,42	1,20	31,31	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1								1											1	1	1	1		1		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 7 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,09	1,01	1,00	0,94	0,95	0,98	1,10	1,18	1,21	1,19	1,16	1,16	1,13	1,17	1,21	1,28	1,31	1,49	1,66	1,65	1,62	1,57	1,42	1,19	29,68	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1																										Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 6 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανόμης		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,14	1,02	1,01	0,99	0,99	1,02	1,10	1,25	1,25	1,21	1,15	1,13	1,17	1,12	1,15	1,16	1,24	1,40	1,61	1,68	1,62	1,57	1,44	1,22	29,65	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1				1	1	1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 5 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,19	1,09	1,09	1,04	1,04	1,06	1,16	1,32	1,36	1,28	1,22	1,16	1,15	1,15	1,18	1,23	1,27	1,40	1,67	1,74	1,72	1,67	1,51	1,32	31,03	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1															Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1																										Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 4 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,23	1,14	1,09	1,07	1,09	1,12	1,16	1,26	1,37	1,36	1,31	1,28	1,26	1,24	1,29	1,35	1,55	1,63	1,81	1,86	1,86	1,77	1,55	1,35	33,00
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1			1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1																							Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	1,1																			1	1	1	1			Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Σάββατο, 3 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,22	1,12	1,12	1,06	1,08	1,10	1,17	1,23	1,32	1,42	1,39	1,35	1,34	1,35	1,44	1,35	1,52	1,70	1,86	1,90	1,92	1,86	1,67	1,41	33,88	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1																			1	1	1	1				Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 2 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,24	1,13	1,09	1,07	1,08	1,14	1,28	1,34	1,37	1,30	1,22	1,24	1,23	1,27	1,26	1,35	1,44	1,60	1,82	1,86	1,96	1,89	1,67	1,40	33,23	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1			1	1	1	1													1	1	1	1				Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1					1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 1 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,26	1,16	1,15	1,10	1,08	1,12	1,22	1,40	1,44	1,41	1,31	1,28	1,27	1,28	1,29	1,41	1,51	1,71	1,90	1,93	1,92	1,88	1,66	1,43	34,11	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1			1	1	1	1	1												1	1	1	1	1			Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 14 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,09	1,00	1,00	0,95	0,95	0,98	1,09	1,23	1,26	1,22	1,19	1,12	1,16	1,16	1,15	1,15	1,26	1,39	1,61	1,69	1,69	1,65	1,41	1,27	29,67	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																				1	1	1	1	1		Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1							Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 13 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,15	1,05	0,99	0,94	0,94	0,98	1,09	1,24	1,34	1,33	1,20	1,19	1,17	1,18	1,15	1,14	1,19	1,33	1,57	1,60	1,59	1,55	1,45	1,26	29,60	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1	1	1							1	1																Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1				1	1	1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 12 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,06	0,97	0,97	0,95	0,93	0,98	1,05	1,15	1,20	1,31	1,36	1,37	1,40	1,34	1,29	1,35	1,37	1,46	1,63	1,66	1,65	1,57	1,40	1,25	30,66	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																				1	1	1	1	1		Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1	1																	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1						Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 11 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,03	0,98	0,94	0,93	0,93	0,95	1,00	1,02	1,15	1,19	1,25	1,32	1,35	1,28	1,26	1,21	1,28	1,47	1,58	1,65	1,57	1,47	1,33	1,16	29,32	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1	1	1																Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 10 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,06	0,98	0,99	0,94	0,94	0,96	1,06	1,12	1,17	1,12	1,12	1,12	1,22	1,26	1,27	1,23	1,25	1,37	1,53	1,59	1,57	1,50	1,31	1,12	28,78	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1										Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1																		1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 9 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,05	0,97	0,99	0,96	0,95	1,00	1,12	1,22	1,25	1,21	1,21	1,20	1,13	1,10	1,10	1,17	1,24	1,30	1,44	1,53	1,56	1,54	1,42	1,23	28,89	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1			1	1	1	1	1	1							1	1	1									Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1							1	1	1	1	1	1				1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 8 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,06	0,98	0,98	0,94	0,94	0,96	1,06	1,20	1,26	1,26	1,20	1,29	1,24	1,21	1,26	1,28	1,35	1,41	1,64	1,61	1,65	1,57	1,43	1,22	29,98	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1			1	1	1	1	1	1	1																	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 21 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,13	1,02	1,01	0,99	0,96	1,02	1,09	1,20	1,26	1,22	1,18	1,13	1,16	1,12	1,10	1,20	1,30	1,42	1,69	1,73	1,72	1,70	1,50	1,27	30,12	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																			1	1	1	1	1	1		Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1		1	1	1	1	1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1								1	1	1	1	1	1	1	1	1	1								Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 20 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,08	1,01	1,01	0,98	0,95	1,00	1,07	1,19	1,21	1,18	1,18	1,28	1,33	1,29	1,26	1,31	1,34	1,42	1,66	1,67	1,72	1,66	1,51	1,31	30,60	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1	1																	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 19 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,94	0,85	0,84	0,81	0,79	0,85	0,90	1,03	1,12	1,19	1,13	1,14	1,13	1,14	1,11	1,19	1,24	1,34	1,54	1,66	1,67	1,60	1,42	1,24	27,85	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1								1	1	1						1	1									Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1			1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 18 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,98	0,90	0,86	0,81	0,81	0,84	0,87	0,93	1,10	1,11	1,11	1,16	1,16	1,11	1,06	1,13	1,20	1,35	1,59	1,67	1,61	1,50	1,24	1,07	27,17	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1															Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1																										Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 17 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,08	1,02	1,02	0,99	1,00	1,03	1,06	1,12	1,14	1,15	1,18	1,21	1,26	1,27	1,30	1,26	1,27	1,39	1,59	1,68	1,64	1,44	1,25	1,13	29,49	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																				1	1	1			Διαθέσιμη	
G5 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1		1	1	1	1	1	1	1	1	1	1														Διαθέσιμη	
G8 (MITSUBISHI S16R-PTA)	1,1	1											1	1	1	1	1	1	1	1				1	1	Διαθέσιμη	
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	

Παρασκευή, 16 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,09	0,99	1,01	0,95	0,95	0,99	1,12	1,16	1,21	1,14	1,08	1,09	1,09	1,07	1,12	1,16	1,24	1,29	1,52	1,24	1,55	1,48	1,36	1,21	28,11
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1																					1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1					Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1																	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Πέμπτη, 15 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,10	1,03	1,04	0,98	0,97	1,02	1,11	1,24	1,25	1,20	1,15	1,14	1,13	1,11	1,13	1,19	1,13	1,33	1,63	1,66	1,67	1,57	1,43	1,23	29,43	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1																			Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 22 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,11	1,02	1,02	0,97	0,97	1,01	1,07	1,21	1,30	1,26	1,12	1,13	1,15	1,12	1,06	1,12	1,17	1,32	1,55	1,63	1,58	1,56	1,44	1,24	29,12	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1															Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1									1	1																Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 23 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,09	0,99	1,00	0,95	0,98	1,03	1,15	1,13	1,10	1,09	1,10	1,12	1,02	1,02	1,01	1,03	1,07	1,16	1,43	1,50	1,56	1,48	1,37	1,20	27,57	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1		1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1								Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1																		1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 24 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,04	1,00	0,99	0,95	0,93	0,96	1,04	1,06	1,11	1,10	1,10	1,07	1,09	1,11	1,08	1,05	1,13	1,22	1,41	1,45	1,46	1,41	1,17	1,01	26,95
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	1,1		1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1						1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1																		1	1	1	1	1		Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Κυριακή, 25 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,89	0,81	0,79	0,77	0,77	0,79	0,82	0,84	0,87	0,92	1,03	1,17	1,18	1,14	1,03	1,02	1,06	1,22	1,42	1,48	1,49	1,34	1,11	1,00	24,97	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1						1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1														1	1	1	1	1								Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 26 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,86	0,78	0,77	0,77	0,75	0,78	0,82	0,96	1,20	1,21	1,14	1,29	1,34	1,34	1,27	1,23	1,29	1,45	1,67	1,71	1,72	1,58	1,39	1,20	28,53	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1								1	1	1										1	1	1	1	1		Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1																										Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1	1	1	1	1							Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 27 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,07	0,98	1,00	0,96	0,96	0,97	1,03	1,16	1,26	1,23	1,18	1,16	1,18	1,17	1,12	1,08	1,14	1,21	1,42	1,46	1,48	1,43	1,30	1,16	28,10	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 28 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,02	0,95	0,95	0,92	0,89	0,95	1,02	1,08	1,14	1,12	1,11	1,09	1,10	1,07	1,02	1,01	1,07	1,18	1,41	1,46	1,50	1,42	1,24	1,12	26,84	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1								Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1																			1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 29 Φεβρουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,01	0,95	0,92	0,88	0,87	0,91	0,96	1,10	1,17	1,18	1,13	1,16	1,15	1,13	1,04	1,05	1,10	1,20	1,41	1,46	1,49	1,42	1,26	1,08	27,04	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1						1	1	1	1	1	1	1	1	1	1									Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1																			1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 1 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,97	0,92	0,90	0,87	0,88	0,95	1,02	1,12	1,19	1,17	1,17	1,21	1,31	1,28	1,20	1,24	1,27	1,33	1,46	1,54	1,49	1,41	1,24	1,11	28,25	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1					1	1	1	1	1	1															Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1													1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 2 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,97	0,93	0,93	0,89	0,91	0,93	0,96	1,02	1,11	1,22	1,28	1,40	1,30	1,35	1,31	1,33	1,29	1,39	1,62	1,69	1,62	1,53	1,42	1,29	29,67	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																			1	1	1	1				Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1				1	1	1	1	1	1																	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1									1	1	1	1	1	1	1	1	1					1	1		Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 3 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,18	1,11	1,07	1,05	1,04	1,08	1,03	1,06	1,19	1,26	1,32	1,25	1,22	1,22	1,18	1,14	1,17	1,27	1,47	1,54	1,57	1,51	1,41	1,25	29,60	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1			1	1	1	1	1	1	1																	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 4 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,14	1,08	1,08	1,02	1,02	1,06	1,06	1,25	1,25	1,28	1,32	1,25	1,21	1,11	0,97	0,99	1,03	1,16	1,29	1,43	1,52	1,47	1,19	1,02	28,19	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1			1	1	1	1	1	1									1	1								Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1							1	1	1	1	1	1	1	1			1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 5 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,87	0,80	0,80	0,75	0,75	0,78	0,83	0,97	1,09	1,27	1,37	1,34	1,33	1,26	1,15	1,18	1,21	1,32	1,48	1,59	1,62	1,49	1,20	1,02	27,48	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1									1																1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 6 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,90	0,79	0,78	0,76	0,75	0,80	0,87	0,95	0,99	1,09	1,10	1,05	1,06	1,11	1,12	1,19	1,24	1,30	1,61	1,69	1,74	1,62	1,51	1,36	27,38	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1								1	1	1	1	1	1	1												Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1															1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 7 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,20	1,12	1,14	1,11	1,11	1,12	1,11	1,24	1,29	1,31	1,21	1,12	1,11	0,92	0,76	0,77	0,81	0,91	1,13	1,31	1,26	1,19	1,09	1,16	26,49	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1			1	1	1	1													1	1			1	1		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1					1	1	1	1	1	1	1								1	1				Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 8 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,15	1,09	1,08	1,03	1,04	1,08	1,16	1,26	1,31	1,31	1,43	1,37	1,32	1,19	1,04	1,06	1,07	1,08	1,26	1,37	1,47	1,36	1,25	1,07	28,85	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1								1	1	1	1								Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1	1	1	1					1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

[illegible]

Κυριακή, 10 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,93	0,83	0,80	0,79	0,77	0,80	0,83	0,90	1,15	1,32	1,38	1,37	1,37	1,29	1,07	0,89	0,91	1,01	1,26	1,32	1,31	1,28	1,16	1,04	25,76	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	-																									Βλάβη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1																	1	1						1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1					1	1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 11 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		0,89	0,81	0,78	0,76	0,76	0,79	0,84	0,91	1,11	1,27	1,28	1,27	1,35	1,28	1,19	1,23	1,23	1,30	1,54	1,66	1,69	1,61	1,52	1,31	28,36
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	-												1	1	1											Βλάβη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1						1	1	1	1																Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1					1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1											1	1	1											Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1				1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Τρίτη, 12 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,16	1,10	1,08	1,08	1,09	1,10	1,08	1,23	1,28	1,31	0,98	1,00	1,00	0,98	0,96	1,03	1,05	1,13	1,30	1,35	1,36	1,28	1,16	1,04	27,14
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1											Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	1,1		1	1	1	1	1	1								1	1	1	1						1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1							1	1	1									1	1	1	1	1		Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Τετάρτη, 13 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,89	0,79	0,76	0,74	0,75	0,80	0,85	0,89	1,01	1,24	1,26	1,25	1,22	1,21	1,16	1,16	1,19	1,29	1,49	1,60	1,48	1,27	1,16	1,04	26,53	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1	1	1								Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1							1	1	1																Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1																			1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 14 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,90	0,79	0,75	0,74	0,74	0,78	0,85	0,96	1,10	1,14	1,04	1,25	1,32	1,30	1,25	1,27	1,29	1,39	1,53	1,64	1,62	1,29	1,15	1,00	27,07	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1							Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1						1	1	1																1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1																				1	1	1	1	1		Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

[illegible]

Σάββατο, 16 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		0,93	0,84	0,80	0,79	0,79	0,81	0,85	1,15	1,29	1,29	1,26	1,26	1,31	1,34	1,28	1,21	1,21	1,34	1,50	1,41	1,40	1,29	1,18	1,04	27,54
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1	1							1	1	1	1	1	1	1	1	1	1								Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	1,1																									Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1																			1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Κυριακή, 17 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,90	0,82	0,79	0,78	0,77	0,79	1,03	1,20	1,25	1,29	1,29	1,35	1,34	1,09	0,86	0,81	0,83	0,91	1,09	1,23	1,32	1,29	1,18	1,00	25,22	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																						1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1																	1	1	1						Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1							1	1	1	1	1	1	1													Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 18 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,89	0,82	0,78	0,76	0,78	0,78	0,84	0,91	0,96	1,00	1,01	0,95	0,93	0,81	0,68	0,70	0,77	0,89	1,13	1,28	1,26	1,21	1,09	0,95	22,18	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1																			1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη	
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη	
G4 (MITSUBISHI S16R-PTA)	1,1	1																								Διαθέσιμη	
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (MTU 12V 4000G60)	-																									Συντήρηση	
G7 (MTU 12V 4000G60)	1,1								1	1	1	1	1	1					1							Διαθέσιμη	
G8 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	

Τρίτη, 19 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,85	0,77	0,74	0,74	0,73	0,89	1,12	1,25	1,27	1,30	1,28	1,29	1,24	1,24	1,20	1,26	1,24	1,32	1,52	1,62	1,58	1,26	1,14	0,99	27,83	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1			1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη	
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη	
G4 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (MTU 12V 4000G60)	-																									Συντήρηση	
G7 (MTU 12V 4000G60)	1,1							1	1																	Διαθέσιμη	
G8 (MITSUBISHI S16R-PTA)	1,1																				1	1				Διαθέσιμη	
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	

[illegible]

Πέμπτη, 21 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,24	1,15	1,13	1,12	1,12	1,16	1,15	1,31	1,31	1,24	1,17	1,19	1,35	1,34	1,20	1,14	1,19	1,30	1,53	1,63	1,59	1,46	1,30	1,09	30,41	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1																										Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 22 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		0,94	0,85	0,81	0,79	0,79	1,05	1,14	1,29	1,30	1,30	1,26	1,28	1,30	1,29	1,23	1,27	1,30	1,40	1,59	1,72	1,61	1,42	1,30	1,13	29,35
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	1,1						1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Σάββατο, 23 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		0,96	0,88	0,85	0,84	0,83	1,06	1,10	1,26	1,31	1,31	1,26	1,32	1,32	1,37	1,32	1,34	1,34	1,38	1,59	1,72	1,46	1,36	1,23	1,08	29,46
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1								1	1					1	1	1									Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1				1	1	1	1					Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1																					1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Κυριακή, 24 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,97	0,88	0,85	0,82	0,82	1,11	1,11	1,24	1,25	1,21	1,20	1,18	0,96	0,97	0,93	0,91	0,97	1,10	1,26	1,33	1,31	1,26	1,19	1,10	25,93	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1													1	1	1											Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1							1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1									1	1	1								Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1															Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 25 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,94	0,86	0,84	0,81	0,80	0,85	0,86	0,97	1,05	1,10	1,07	1,03	0,99	1,01	0,96	1,01	1,07	1,35	1,59	1,65	1,63	1,55	1,42	1,26	26,67	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1	1											1	1	1				Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1																		1	1	1	1	1	1	1		Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 26 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,13	1,08	1,07	1,07	1,05	1,08	1,06	1,25	1,27	1,29	1,25	1,27	1,30	1,29	1,23	1,25	1,27	1,35	1,51	1,60	1,56	1,23	1,10	0,94	29,53	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1																		1	1	1	1	1	1	1		Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1																								1		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1																	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

[illegible]

Πέμπτη, 28 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,81	0,73	0,73	0,72	0,71	0,74	0,80	1,14	0,97	1,01	1,01	1,16	1,26	1,32	1,34	1,32	1,34	1,40	1,55	1,62	1,30	1,19	1,04	0,92	26,13	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1							1																		1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 29 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,81	0,75	0,71	0,71	0,71	0,87	1,04	1,17	1,08	1,05	1,08	1,10	1,15	1,18	1,09	1,06	1,06	1,12	1,27	1,34	1,39	1,35	1,25	1,18	25,52	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1						1																				Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 30 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,05	0,99	1,00	0,93	0,87	0,88	0,89	0,96	1,00	1,01	1,05	1,05	1,11	1,13	1,03	0,98	0,98	1,02	1,16	1,28	1,12	1,01	0,93	0,84	24,28	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1			1	1	1	1						1	1	1	1	1	1	1				1	1	1		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1					1	1	1	1	1								1	1	1					Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 31 Μάρτιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,74	0,70	0,70	0,69	0,68	0,68	0,70	0,89	0,93	0,99	1,07	1,13	1,10	1,05	0,99	0,91	0,93	0,95	1,02	1,12	1,20	1,01	0,96	0,85	22,00	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1								1								1	1	1	1				1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1					1	1					Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 1 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,74	0,68	0,68	0,68	0,66	0,69	0,88	0,93	0,99	1,06	1,07	1,05	1,05	1,05	1,02	0,95	0,95	1,01	1,08	1,17	1,24	1,19	1,08	0,96	22,85	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1							1	1						1	1	1	1	1	1	1						Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1								1	1	1	1		Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 2 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,87	0,82	0,82	0,81	0,81	0,84	0,90	0,94	1,01	1,04	0,92	0,90	1,03	1,06	0,87	0,93	0,80	0,81	0,89	0,98	1,05	1,02	0,94	0,83	21,89	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1		1				1	1	1							1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1								1	1	1	1	1	1												Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 3 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,74	0,69	0,68	0,67	0,66	0,70	0,75	0,79	0,89	0,92	0,93	0,91	0,89	0,97	1,05	0,97	0,93	0,97	1,06	1,14	1,26	1,20	1,11	0,99	21,88	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1														1	1	1	1	1	1							Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1							1	1	1	1	1		Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 4 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,90	0,83	0,83	0,82	0,81	0,84	0,91	0,97	1,13	1,16	1,21	1,06	1,10	1,12	1,19	1,08	1,07	1,10	1,22	1,32	1,44	1,36	1,28	1,17	25,94	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1													1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1														Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1							1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 5 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,07	1,02	1,02	1,01	1,00	1,04	1,02	1,13	1,17	1,20	1,22	1,23	1,23	1,18	1,16	1,09	1,08	1,13	1,19	1,25	1,40	1,33	1,25	1,13	27,55
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																									Συντήρηση
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	1,1																									Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Σάββατο, 6 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,06	1,01	0,99	0,98	0,94	0,86	0,89	0,92	1,02	1,21	1,07	1,03	1,13	1,13	1,03	0,95	0,95	0,99	1,09	1,21	1,41	1,34	1,27	1,15	25,63	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 7 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,07	1,03	1,02	1,00	0,98	1,02	0,96	1,06	1,15	1,19	1,23	1,30	1,37	1,33	1,27	1,16	1,15	1,16	1,23	1,32	1,45	1,38	1,28	1,18	28,29	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 8 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,07	1,01	0,98	0,98	0,99	1,00	1,00	1,17	1,24	1,26	1,28	1,29	1,32	1,29	1,22	1,15	1,11	1,15	1,26	1,34	1,42	1,33	1,26	1,17	28,28	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 9 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,08	1,01	1,02	1,01	1,01	1,03	1,00	1,18	1,21	1,27	1,26	1,23	1,20	1,08	0,87	0,84	0,94	1,01	1,08	1,15	1,14	1,07	0,98	0,85	25,50	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1									1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1												Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 10 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,77	0,71	0,70	0,69	0,79	1,04	1,04	1,16	1,23	1,26	1,27	1,30	1,32	1,27	1,19	1,15	1,15	1,17	1,26	1,34	1,43	1,32	1,00	0,86	26,42	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1												Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1					1	1	1								1	1	1	1					1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1										1	1									1	1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 11 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,77	0,72	0,70	0,70	0,78	1,00	0,97	1,13	1,28	1,30	1,26	1,23	1,24	1,28	1,23	1,17	1,13	1,19	1,28	1,37	1,45	1,39	1,28	1,15	27,00	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1									1	1	1															Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1					1	1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 12 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,05	1,01	0,99	1,01	0,97	0,89	0,96	1,03	1,11	1,14	1,14	1,29	1,31	1,30	1,28	1,21	1,15	1,20	1,27	1,36	1,50	1,39	1,29	1,14	27,99	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1	1	1	1																Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 13 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,05	1,03	1,02	1,03	1,02	1,04	1,02	1,13	1,25	1,37	1,37	1,34	1,39	1,38	1,29	1,12	1,20	1,23	1,31	1,37	1,49	1,42	1,30	1,21	29,38	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1		1	1	1	1	1	1	1	1																	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 14 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,11	1,06	1,04	1,02	1,00	1,01	0,97	1,15	1,22	1,28	1,32	1,30	1,35	1,30	1,24	1,19	1,11	1,16	1,24	1,35	1,48	1,40	1,27	1,17	28,72	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1		1	1	1	1	1	1	1	1																	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 15 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,06	1,00	1,00	1,00	1,02	1,04	1,00	1,18	1,23	1,30	1,27	1,31	1,33	1,30	1,24	1,21	1,13	1,19	1,28	1,39	1,49	1,39	1,29	1,19	28,84
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																									Συντήρηση
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1	1	1	1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Τρίτη, 16 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,08	1,01	0,97	0,99	1,00	1,03	1,01	1,14	1,23	1,30	1,29	1,30	1,36	1,30	1,00	0,91	0,88	0,92	0,99	1,14	1,16	1,09	0,99	0,88	25,95	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1		1	1	1	1	1	1	1							1	1				1	1	1	1	1		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1								1	1	1	1	1	1												Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 17 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,79	0,73	0,71	0,71	0,98	1,06	1,06	1,19	1,20	1,28	1,31	1,39	1,38	1,36	1,24	1,19	1,16	1,19	1,33	1,41	1,52	1,42	1,28	1,16	28,05	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1					1	1	1																			Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 18 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,05	1,01	1,00	0,99	1,00	1,05	1,04	1,23	1,29	1,33	1,31	1,35	1,44	1,43	1,28	1,22	1,20	1,22	1,29	1,39	1,51	1,39	1,00	0,91	28,91	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																								1		Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1		1	1	1	1	1	1	1																1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1				Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 19 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,80	0,73	0,71	0,70	0,69	0,97	1,02	1,17	1,30	1,21	1,25	1,23	1,20	1,21	1,14	1,06	1,03	1,05	1,12	1,21	1,47	1,32	1,02	0,88	25,50	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1																	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1						1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 20 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,77	0,74	0,74	0,73	0,94	1,02	1,00	1,13	1,15	1,13	1,31	1,34	1,35	1,27	1,24	1,09	1,07	1,11	1,19	1,29	1,40	1,32	1,20	1,10	26,63	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1					1	1	1																			Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1															Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 21 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		0,97	0,89	0,87	0,86	0,86	0,88	0,85	1,02	1,09	1,12	1,19	1,15	1,17	1,15	1,10	1,02	1,04	1,07	1,15	1,25	1,33	1,26	1,16	1,05	25,50
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1								1	1																Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																									Συντήρηση
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1	1				1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Δευτέρα, 22 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		0,95	0,88	0,85	0,87	0,86	0,88	0,86	1,09	1,15	1,20	1,24	1,41	1,43	1,37	1,31	1,21	1,19	1,24	1,31	1,44	1,58	1,47	1,34	1,19	28,32	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1	1																									Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 23 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,09	1,02	1,03	1,05	1,04	1,07	1,03	1,22	1,28	1,42	1,40	1,34	1,38	1,39	1,36	1,29	1,25	1,29	1,39	1,46	1,59	1,48	1,33	1,20	30,39
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																									Συντήρηση
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	1,1			1	1	1	1	1																		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Τετάρτη, 24 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,09	1,04	1,03	1,03	1,03	1,07	1,05	1,24	1,34	1,43	1,46	1,45	1,45	1,43	1,35	1,28	1,23	1,27	1,35	1,40	1,55	1,38	1,29	1,25	30,49	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1			1	1	1	1	1																			Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 25 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,15	1,09	1,07	1,07	1,06	1,08	1,05	1,23	1,33	1,39	1,38	1,43	1,40	1,49	1,42	1,34	1,27	1,30	1,42	1,47	1,58	1,52	1,36	1,28	31,18	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1			1	1	1	1																				Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1					1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 26 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,13	1,03	1,01	1,02	1,03	1,09	1,05	1,24	1,28	1,34	1,37	1,40	1,42	1,40	1,32	1,27	1,22	1,25	1,31	1,39	1,55	1,52	1,36	1,28	30,27	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1												1	1													Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	1,1																										Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 27 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,13	1,06	1,03	1,03	1,02	1,06	1,05	1,20	1,25	1,18	1,29	1,42	1,47	1,46	1,42	1,33	1,27	1,31	1,39	1,49	1,58	1,53	1,37	1,26	30,61	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1							Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1												1	1	1	1	1		Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 28 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,13	1,07	1,09	1,07	1,07	1,10	1,06	1,22	1,21	1,27	1,32	1,34	1,51	1,51	1,41	1,28	1,27	1,31	1,42	1,44	1,51	1,46	1,42	1,27	30,75	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1	1	1	1	1					1		Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1											1	1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 29 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανόμης		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,16	1,10	1,07	1,11	1,11	1,15	1,09	1,23	1,33	1,44	1,46	1,49	1,53	1,52	1,46	1,40	1,30	1,39	1,46	1,49	1,55	1,52	1,42	1,30	32,09	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1				1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1							1	1	1																	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1					1	Διαθέσιμη	
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1													1	1	1					1	1	1	1		Διαθέσιμη	
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 30 Απρίλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,18	1,10	1,09	1,11	1,11	1,15	1,13	1,27	1,42	1,45	1,49	1,54	1,55	1,53	1,46	1,39	1,32	1,36	1,47	1,50	1,61	1,55	1,36	1,30	32,43	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1															Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 1 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,19	1,11	1,10	1,11	1,10	1,16	1,13	1,29	1,40	1,49	1,52	1,50	1,54	1,57	1,54	1,42	1,35	1,38	1,51	1,58	1,74	1,67	1,52	1,36	33,26	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1							1	1	1												1	1				Διαθέσιμη
G6 (MTU 12V 4000G60)	1,1																										Διαθέσιμη
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1				1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 2 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,21	1,14	1,12	1,13	1,13	1,18	1,17	1,36	1,49	1,57	1,57	1,61	1,60	1,60	1,55	1,46	1,42	1,51	1,61	1,65	1,65	1,54	1,43	1,38	34,09	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1			1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1											1	1														Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1																Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 3 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,28	1,20	1,18	1,18	1,16	1,20	1,14	1,32	1,40	1,45	1,47	1,47	1,46	1,54	1,48	1,40	1,39	1,45	1,53	1,60	1,60	1,49	1,47	1,42	33,29
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	-																									Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Σάββατο, 4 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,30	1,23	1,23	1,19	1,18	1,23	1,17	1,39	1,41	1,52	1,58	1,57	1,65	1,67	1,63	1,58	1,57	1,67	1,73	1,78	1,93	1,65	1,43	1,26	35,55	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1													1	1					1	1						Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1																					1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 5 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,11	1,07	1,24	1,20	1,16	1,18	1,13	1,29	1,43	1,60	1,67	1,46	1,19	1,09	0,97	0,92	0,96	1,14	1,32	1,40	1,44	1,36	1,34	1,25	29,92	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 6 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,13	1,04	1,02	1,02	1,02	1,04	1,08	1,16	1,27	1,36	1,43	1,52	1,60	1,58	1,52	1,42	1,35	1,41	1,56	1,59	1,73	1,54	1,38	1,25	32,01	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 7 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,13	1,03	0,99	0,99	0,98	1,01	0,94	1,12	1,26	1,38	1,47	1,59	1,69	1,70	1,59	1,44	1,38	1,44	1,55	1,64	1,68	1,64	1,50	1,34	32,46
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	-																									Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Τετάρτη, 8 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,24	1,16	1,13	1,11	1,11	1,17	1,14	1,30	1,48	1,46	1,55	1,58	1,61	1,62	1,57	1,45	1,39	1,45	1,54	1,59	1,68	1,65	1,51	1,36	33,86	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1				1	1	1	1	1	1																	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 9 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,25	1,16	1,16	1,18	1,17	1,20	1,17	1,36	1,51	1,62	1,59	1,69	1,76	1,75	1,60	1,52	1,40	1,46	1,54	1,60	1,71	1,68	1,50	1,37	34,95	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1																1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 10 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,25	1,15	1,13	1,15	1,16	1,18	1,18	1,36	1,48	1,58	1,57	1,63	1,61	1,58	1,55	1,47	1,38	1,45	1,51	1,59	1,71	1,66	1,48	1,36	34,17	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 11 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,24	1,19	1,18	1,17	1,18	1,20	1,15	1,34	1,39	1,52	1,57	1,62	1,62	1,72	1,63	1,49	1,43	1,47	1,52	1,59	1,72	1,67	1,55	1,41	34,57	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 12 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,31	1,23	1,16	1,14	1,14	1,17	1,15	1,25	1,40	1,52	1,57	1,58	1,62	1,60	1,51	1,35	1,33	1,37	1,49	1,55	1,65	1,65	1,52	1,37	33,63
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1								1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1								Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1				1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	-																									Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Δευτέρα, 13 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,27	1,20	1,15	1,17	1,17	1,18	1,15	1,36	1,40	1,52	1,55	1,55	1,59	1,59	1,51	1,39	1,33	1,38	1,52	1,59	1,70	1,66	1,48	1,32	33,73
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1			1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1							1	1	1	1															Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1					1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	-																									Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1									1	1															Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Τρίτη, 14 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,22	1,15	1,12	1,12	1,12	1,17	1,12	1,23	1,29	1,36	1,40	1,52	1,57	1,57	1,48	1,39	1,32	1,38	1,47	1,62	1,74	1,68	1,48	1,33	32,82	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 15 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,22	1,14	1,13	1,13	1,12	1,16	1,18	1,41	1,53	1,55	1,59	1,57	1,62	1,58	1,52	1,41	1,39	1,43	1,53	1,59	1,71	1,67	1,48	1,34	34,01	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 16 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,21	1,15	1,14	1,15	1,16	1,18	1,15	1,36	1,50	1,59	1,56	1,63	1,61	1,62	1,61	1,48	1,37	1,51	1,57	1,62	1,69	1,65	1,52	1,38	34,40	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1						1	1	1	1	1	1	1														Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1									1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 17 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,29	1,20	1,17	1,17	1,17	1,05	1,18	1,36	1,49	1,63	1,67	1,74	1,85	1,93	1,75	1,50	1,49	1,50	1,68	1,68	1,74	1,72	1,71	1,58	36,23	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1			1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1														1	1											Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1											Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 18 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,47	1,37	1,20	1,20	1,18	1,21	1,19	1,39	1,49	1,62	1,69	1,77	1,91	1,94	1,76	1,61	1,54	1,58	1,69	1,84	1,98	1,80	1,62	1,45	37,48	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1														Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1													1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1	1			1	1	1	1				Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 19 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,32	1,24	1,20	1,21	1,21	1,23	1,16	1,36	1,45	1,59	1,62	1,72	1,71	1,74	1,70	1,63	1,53	1,69	1,76	1,76	1,76	1,76	1,75	1,48	36,58	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1				1	1	1	1	1	1																1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1			1	1	1	1	1	1	1	1	1															Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 20 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,32	1,25	1,22	1,22	1,20	1,25	1,21	1,45	1,53	1,73	1,72	1,74	1,84	1,87	1,84	1,74	1,66	1,84	1,97	2,05	2,04	1,98	1,92	1,77	39,36	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1												Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1						1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 21 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,61	1,49	1,34	1,32	1,29	1,30	1,27	1,43	1,60	1,70	1,76	1,84	1,90	1,91	1,88	1,76	1,75	1,81	1,87	1,93	1,97	1,93	1,81	1,67	40,13	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 22 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,47	1,39	1,34	1,34	1,31	1,35	1,32	1,41	1,63	1,77	1,80	1,84	1,81	1,91	1,99	1,96	1,87	1,90	2,02	2,08	2,09	2,09	1,97	1,71	41,37	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 23 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,49	1,41	1,35	1,33	1,31	1,33	1,27	1,50	1,63	1,70	1,83	1,86	1,98	2,00	1,91	1,80	1,72	1,77	1,84	1,94	2,02	1,98	1,70	1,69	40,35	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 24 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,57	1,49	1,45	1,46	1,32	1,32	1,26	1,51	1,77	1,76	1,78	1,92	1,97	1,98	1,84	1,73	1,70	1,77	1,82	1,80	2,02	1,97	1,84	1,68	40,71	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 25 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,57	1,51	1,47	1,45	1,45	1,47	1,40	1,63	1,76	1,87	1,89	1,90	1,97	1,97	1,92	1,82	1,75	1,78	1,88	1,95	2,02	2,04	1,87	1,72	42,03	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 26 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,61	1,54	1,50	1,50	1,49	1,48	1,43	1,59	1,68	1,83	1,93	2,04	2,11	2,12	1,97	1,76	1,73	1,81	1,83	1,76	1,70	1,64	1,48	1,35	40,86
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1	1	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1			1	1	1	1	1	1	1																Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	-																									Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη

Δευτέρα, 27 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,23	1,16	1,12	1,12	1,11	1,10	1,06	1,27	1,39	1,45	1,51	1,57	1,71	1,75	1,66	1,59	1,56	1,60	1,67	1,75	1,81	1,81	1,70	1,52	35,22	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1													1	1	1	1	1			1	1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 28 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,37	1,30	1,25	1,24	1,24	1,25	1,23	1,42	1,51	1,62	1,69	1,74	1,79	1,81	1,79	1,63	1,52	1,55	1,66	1,70	1,78	1,81	1,63	1,49	37,01	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1	1					1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 29 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,35	1,14	1,12	1,11	1,07	1,10	1,19	1,49	1,72	1,69	1,72	1,73	1,78	1,78	1,67	1,45	1,38	1,42	1,55	1,61	1,68	1,63	1,48	1,32	35,17	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Πέμπτη, 30 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,21	1,14	1,11	1,09	1,07	1,07	1,04	1,27	1,51	1,66	1,69	1,71	1,77	1,95	1,84	1,59	1,50	1,49	1,68	1,76	1,82	1,82	1,66	1,49	35,92	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1													1	1	1						1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Παρασκευή, 31 Μάιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,36	1,18	1,13	1,11	1,10	1,11	1,26	1,46	1,62	1,78	1,85	1,86	1,90	1,97	1,77	1,64	1,54	1,60	1,65	1,69	1,70	1,86	1,71	1,56	37,41	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1											1	1	1	1	1	1							1	1		Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Σάββατο, 1 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,43	1,34	1,32	1,30	1,27	1,29	1,25	1,47	1,57	1,69	1,72	1,79	1,84	1,87	1,84	1,71	1,72	1,74	1,83	1,87	1,90	1,88	1,76	1,62	39,01	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Κυριακή, 2 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,47	1,35	1,34	1,35	1,33	1,33	1,25	1,49	1,64	1,65	1,64	1,78	1,95	2,13	2,03	1,96	1,80	1,83	1,92	1,98	2,00	2,03	1,91	1,67	40,81	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1								1	1																	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 3 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,41	1,32	1,33	1,27	1,34	1,27	1,24	1,47	1,74	2,01	2,07	2,08	2,25	2,34	2,34	2,26	2,17	2,21	2,32	2,32	2,37	2,32	2,22	2,09	45,78	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1									1	1				1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1				1	1	1	1	1	1	1	1	1	1													Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τρίτη, 4 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,94	1,82	1,75	1,70	1,67	1,68	1,62	1,82	1,96	2,13	2,05	2,12	2,24	2,47	2,43	2,37	2,31	2,19	2,23	2,31	2,36	2,23	2,38	2,23	49,99	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1	1	1	1											1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1	1	1													Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Τετάρτη, 5 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,04	1,89	1,84	1,81	1,78	1,77	1,70	1,92	2,12	2,10	2,21	2,41	2,56	2,66	2,71	2,61	2,53	2,61	2,64	2,66	2,69	2,71	2,71	2,58	55,26	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1				1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1							1	1	1													Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1													1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη

Πέμπτη, 6 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,41	2,28	2,22	2,11	2,04	2,04	1,90	2,10	2,23	2,30	2,41	2,50	2,56	2,75	2,78	2,69	2,57	2,55	2,54	2,62	2,71	2,58	2,45	2,23	57,56	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1													1	1	1	1	1	1	1	1	1	1				Διαθέσιμη

Παρασκευή, 7 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		2,09	1,97	1,85	1,77	1,80	2,11	2,07	2,23	2,46	2,60	2,67	2,72	2,71	2,73	2,62	2,51	2,63	2,79	2,84	2,77	2,80	2,72	2,49	58,67	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	-																									Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη

Σάββατο, 8 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,33	2,17	2,07	2,01	1,95	1,90	1,84	1,98	2,05	2,17	2,26	2,36	2,41	2,60	2,78	2,65	2,66	2,69	2,74	2,66	2,65	2,64	2,59	2,55	56,71	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1														1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη

Κυριακή, 9 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,42	2,26	2,15	2,09	2,03	1,96	1,92	2,01	2,15	2,27	2,29	2,41	2,48	2,56	2,63	2,42	2,50	2,52	2,58	2,57	2,56	2,63	2,60	2,46	56,45	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1			1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1	1	1																								Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη

Δευτέρα, 10 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		2,26	2,13	2,03	1,95	1,90	1,87	1,85	2,01	2,19	2,31	2,35	2,40	2,54	2,71	2,69	2,60	2,53	2,55	2,59	2,59	2,56	2,60	2,58	2,42	56,21
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	-																									Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1														1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1																		1	1	1	1	1			Διαθέσιμη

Τρίτη, 11 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,21	2,06	1,96	1,88	1,86	1,82	1,79	1,95	2,07	2,24	2,32	2,37	2,52	2,69	2,75	2,64	2,56	2,56	2,59	2,56	2,56	2,61	2,58	2,49	55,64	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1		1	1	1	1	1	1	1	1																	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1													1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη

Τετάρτη, 12 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,26	2,12	2,01	1,93	1,88	1,85	1,84	2,04	2,19	2,31	2,41	2,49	2,61	2,77	2,78	2,69	2,67	2,70	2,83	2,73	2,66	2,77	2,77	2,66	57,99	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1,1												1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη

Τετάρτη, 19 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,48	2,34	2,22	2,10	2,03	1,99	1,94	2,10	2,33	2,46	2,53	2,67	2,82	2,92	2,97	2,94	2,66	2,75	2,80	2,74	2,88	3,01	3,06	3,06	61,80	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,85															1	1	1					1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1	1	1								1	1	1	1	1				1	1	1						Διαθέσιμη

Πέμπτη, 20 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,89	2,61	2,36	2,23	2,16	2,13	1,94	2,15	2,48	2,61	2,57	2,60	2,88	3,02	3,08	2,88	2,80	2,75	2,94	2,85	2,79	2,92	2,92	2,75	63,31	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,85	1	1	1											1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1									1	1	1	1	1													Διαθέσιμη

Παρασκευή, 21 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,54	2,38	2,30	2,20	2,11	2,07	1,96	2,15	2,24	2,36	2,42	2,51	2,50	2,58	2,73	2,65	2,57	2,59	2,61	2,50	2,45	2,49	2,46	2,29	57,64	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,85																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1	1	1									1	1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη

Σάββατο, 22 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,13	2,00	1,90	1,89	1,87	1,82	1,76	1,95	2,06	2,19	2,26	2,41	2,51	2,52	2,53	2,45	2,39	2,45	2,54	2,55	2,56	2,56	2,49	2,42	54,20	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,85																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1												1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη

Κυριακή, 23 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		2,22	2,03	1,96	1,91	1,86	1,79	1,71	1,98	2,20	2,33	2,38	2,49	2,58	2,63	2,65	2,56	2,56	2,54	2,58	2,62	2,61	2,68	2,56	2,42	55,86
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,85									1	1															Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	-																									Συντήρηση
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1											1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη

Δευτέρα, 24 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,25	2,08	1,98	1,92	1,86	1,82	1,71	1,97	2,17	2,33	2,41	2,51	2,64	2,71	2,74	2,63	2,66	2,66	2,63	2,69	2,61	2,72	2,66	2,51	56,86	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,85																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,85	1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Συντήρηση
G7 (MTU 12V 4000G60)	-																										Συντήρηση
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη

Τρίτη, 25 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		2,31	2,14	2,04	1,99	1,94	1,90	1,80	2,04	2,28	2,46	2,52	2,66	2,83	2,86	2,90	2,80	2,91	2,93	3,09	3,15	3,11	3,14	3,08	0,00	58,88
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,85																			1	1	1	1	1		Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Συντήρηση
G7 (MTU 12V 4000G60)	-																									Συντήρηση
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1	1									1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
Παρατηρήσεις: Στις 23:03 πραγματοποιήθηκε γενική διακοπή ηλεκτροδότησης λόγω σφάλματος στον ΤΣΠ. Η αποκατάσταση ολοκληρώθηκε στις 00:31.																										

Πέμπτη, 20 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,65	2,20	1,95	0,54	0,67	1,90	1,75	1,85	2,04	2,19	2,24	2,31	2,59	3,08	3,17	3,13	3,07	3,07	3,06	3,12	3,05	3,18	3,13	2,95	57,88
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,85													1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	-																									Βλάβη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-												1	1	1	1	1	1	1	1	1	1	1	1	1	Συντήρηση
G7 (MTU 12V 4000G60)	-																									Συντήρηση
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1	1	1	1			1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1				Διαθέσιμη
Παρατηρήσεις: Σε συνέχεια της διακοπής στις 19/06/2024 πραγματοποιήθηκε νέα διακοπή μεταξύ 03:15 και 04:30 για εργασίες επισκευής στον ΤΣΠ. Η μονάδα G6 εντάχθηκε σε δοκιμαστική λειτουργία.																										

Παρασκευή, 21 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,95	1,84	1,59	1,52	1,50	1,48	1,43	1,55	1,68	1,91	2,21	2,97	3,08	3,16	3,30	3,05	2,96	2,95	2,97	3,04	2,94	2,96	2,87	2,76	57,67	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85											1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	-																										Βλάβη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1						1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (MTU 12V 4000G60)	-												1	1	1	1	1			1	1	1	1	1	1	1	Συντήρηση
G8 (MITSUBISHI S16R-PTA)	0,75	1	1								1	1	1	1	1	1	1	1	1								Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1												1	1	1	1	1	1	1								Διαθέσιμη
Παρατηρήσεις: Η μονάδα G7 εντάχθηκε σε δοκιμαστική λειτουργία.																											

Σάββατο, 22 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,55	2,38	2,25	2,17	2,13	2,06	1,99	2,23	2,37	2,61	2,71	2,77	2,85	2,98	3,12	3,06	3,18	3,23	3,32	3,29	3,27	3,16	3,12	3,03	65,82	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85	1	1											1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	-																										Βλάβη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1							Διαθέσιμη
G7 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,75																			1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																				1	1	1				Διαθέσιμη

Κυριακή, 23 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,88	2,69	2,59	2,50	2,41	2,31	2,23	2,40	2,53	2,68	2,66	2,85	2,89	2,96	3,00	2,97	2,85	2,89	2,99	2,93	2,83	2,85	2,82	2,72	65,43	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1								1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	-																										Βλάβη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	1																										Διαθέσιμη
G7 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1					Διαθέσιμη

Δευτέρα, 24 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,58	2,45	2,34	2,24	2,18	2,12	2,02	2,25	2,47	2,61	2,66	2,78	2,88	2,99	3,04	2,96	2,87	2,89	2,92	2,94	2,88	2,83	2,77	2,50	63,19	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85	1	1								1	1	1	1												Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	-																										Βλάβη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	1														1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη

Τρίτη, 25 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,33	2,18	2,06	1,98	1,91	1,88	1,78	2,06	2,13	1,92	1,57	2,20	2,39	2,51	2,54	2,46	2,35	2,37	2,39	2,35	2,30	2,45	2,35	2,19	52,65	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	-																										Βλάβη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	1												1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1	1	1																	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη

Τετάρτη, 26 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,03	1,89	2,11	2,19	2,14	2,10	2,03	2,23	2,44	2,61	2,23	2,79	2,94	3,03	3,19	3,10	3,02	3,04	3,12	3,09	3,07	3,14	3,10	2,96	63,59	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85															1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	-												1	1	1												Βλάβη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1												Διαθέσιμη
G7 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,75												1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1															1	1	1	1	1	1	1	1	1			Διαθέσιμη

Πέμπτη, 27 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		2,73	2,56	2,40	2,28	2,20	2,15	2,07	2,25	2,55	2,67	2,76	2,80	2,92	3,06	3,12	3,01	2,73	2,64	2,69	2,70	2,61	2,59	2,60	2,48	62,56
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,85	1	1	1															1	1						Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	-											1	1	1												Βλάβη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	1																									Διαθέσιμη
G7 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1				1	1	1	1				1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
Παρατηρήσεις: Η μονάδα G4 εντάχθηκε σε δοκιμαστική λειτουργία.																										

Παρασκευή, 28 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,43	2,26	2,14	2,02	1,83	1,82	1,78	1,94	2,16	2,43	2,47	2,49	2,58	2,72	2,73	2,67	2,55	2,62	2,73	2,75	2,68	2,69	2,60	2,49	57,55	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,85																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Βλάβη
G7 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1											1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη

Σάββατο, 29 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,32	2,20	2,15	2,09	2,04	1,97	1,85	2,01	2,14	2,25	2,36	2,46	2,73	2,86	2,89	2,89	2,86	2,92	2,97	2,88	2,85	2,85	2,84	2,71	60,11	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,85																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Βλάβη
G7 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1	1	1	1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη

Κυριακή, 30 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		2,56	2,42	2,32	2,25	2,18	2,11	2,03	2,22	2,28	2,36	2,42	2,57	2,64	2,77	2,96	2,91	2,87	2,87	2,95	2,89	2,89	2,95	2,96	2,86	62,24
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,85								1	1	1	1	1				1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,85																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,75	1	1	1	1	1	1	1					1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1	1	1	1										1	1	1										Διαθέσιμη

Δευτέρα, 1 Ιούλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		2,56	2,38	2,28	2,19	2,12	2,06	1,97	2,19	2,39	2,48	2,53	2,53	2,84	3,05	2,96	3,06	2,94	2,88	2,98	1,43	2,70	3,05	3,02	2,92	61,50
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1					Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,85																					1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	1												1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1					Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,75	1	1																							Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																						1	1	1	Διαθέσιμη
Παρατηρήσεις: Κατά το διάστημα 19:20 έως 20:20 σημειώθηκε γενική διακοπή ηλεκτροδότησης.																										

Τρίτη, 2 Ιούλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,79	2,61	2,46	2,36	2,26	2,20	2,10	2,30	2,15	2,22	2,68	2,70	2,90	3,04	3,08	2,97	2,95	2,93	2,99	3,02	2,97	2,94	2,92	2,81	64,33	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,85	1	1																								Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (MTU 12V 4000G60)	1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	-																										Βλάβη
G9 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη

Τετάρτη, 3 Ιούλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,65	2,47	2,32	2,23	2,17	2,11	2,03	2,24	2,46	2,43	2,60	2,75	2,82	2,86	3,02	2,78	2,70	2,66	2,77	2,76	2,70	2,69	2,60	2,45	61,28	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,85																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,85				1	1	1	1	1	1																	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,85	1	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (MTU 12V 4000G60)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	-																										Βλάβη
G9 (MITSUBISHI S16R-PTA)	1	1	1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Σάββατο, 27 Ιούλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																										
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)		
Ζήτηση (MWh)		2,79	2,67	2,61	2,51	2,43	2,39	2,28	2,41	2,59	2,73	2,76	2,89	2,98	3,11	3,21	3,14	3,09	3,28	3,39	3,43	3,42	3,41	3,36	3,22	70,09		
Μονάδα	Αποδιδόμενη Ισχύς (MW)																											
G1 (MITSUBISHI S16R-PTA)	0,9	1	1											1	1	1	1									1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																											Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																											Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9																											Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9			1	1	1					1	1	1						1	1	1	1	1	1	1			Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																											Διαθέσιμη
Μισθωμένη Ισχύς	1																	1	1	1	1	1	1	1	1	1		Διαθέσιμη

[illegible]

Δευτέρα, 29 Ιούλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		2,87	2,67	2,62	2,54	2,45	2,38	2,29	2,46	2,90	3,10	3,15	3,26	3,25	3,44	3,61	3,53	3,41	3,29	3,41	3,43	3,58	3,51	3,50	3,43	74,08
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9	1																					1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9		1	1	1									1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη
Μισθωμένη Ισχύς	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη

Τρίτη, 30 Ιούλιος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		3,23	3,06	2,91	2,80	2,69	2,63	2,48	2,66	2,90	3,07	3,15	3,25	3,31	3,54	3,60	3,47	3,42	3,52	3,61	3,57	3,57	3,57	2,64	3,43	76,09	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1								1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9																								1	Διαθέσιμη	
G5 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G8 (MITSUBISHI S16R-PTA)	0,9	1													1											Διαθέσιμη	
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη	
Μισθωμένη Ισχύς	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη	
Παρατηρήσεις: Κατά το διάστημα 22:35 έως 23:00 σημειώθηκε γενική διακοπή ηλεκτροδότησης.																											

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Τρίτη, 6 Αύγουστος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,59	2,43	2,25	2,16	2,09	2,02	1,86	2,43	2,94	3,08	3,11	3,20	3,34	3,49	3,55	3,48	3,43	3,45	3,50	3,63	3,65	3,53	3,45	2,97	71,63	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9	1	1												1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη
Μισθωμένα Ισχύς	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
Παρατηρήσεις: Κατά το διάστημα 22:35 έως 23:00 σημειώθηκε γενική διακοπή ηλεκτροδότησης.																											

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Πέμπτη, 29 Αύγουστος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,80	2,61	2,48	2,36	2,31	2,29	2,17	2,33	2,54	2,59	2,67	2,88	2,97	3,08	3,15	3,03	2,84	2,82	2,32	2,74	3,09	2,99	2,91	2,76	64,72	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1										1	1	1	1	1		Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9	1	1	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G6 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη
Μισθωμένη Ισχύς	1									1	1	1	1	1	1	1	1	1	1	1							Διαθέσιμη
Παρατηρήσεις: Κατά το διάστημα 18:41-18:52 σημειώθηκε γενική διακοπή ηλεκτροδότησης. Κατά το διάστημα 19:33-20:07 σημειώθηκε μερική διακοπή ηλεκτροδότησης λόγω εργασιών.																											

[illegible]

Σάββατο, 31 Αύγουστος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,67	2,51	2,38	2,31	2,26	2,19	2,12	2,30	2,50	2,66	2,75	2,88	2,97	3,03	3,04	2,94	2,82	2,88	2,94	2,91	3,02	2,89	2,74	2,63	64,35	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1							1	1											1	1	1	1		Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G6 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη
Μισθωμένη Ισχύς	1											1	1	1	1	1	1	1	1	1	1						Διαθέσιμη

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Τρίτη, 10 Σεπτέμβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		2,39	2,29	2,22	2,13	2,07	2,05	1,99	2,19	2,33	2,55	2,60	2,63	2,72	2,76	2,70	2,55	2,47	2,55	2,68	2,81	2,91	2,74	2,51	2,33	59,17
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9	1											1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G6 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

[illegible]

[illegible]

Παρασκευή, 13 Σεπτέμβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,28	2,14	2,05	1,97	1,93	1,93	1,87	2,03	2,01	2,23	2,26	2,40	2,76	2,75	2,76	2,60	2,48	2,55	2,68	2,83	2,82	2,72	2,56	2,41	57,04	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,9												1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																										Διαθέσιμη
G6 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη
Παρατηρήσεις: Κατά το διάστημα 08:02-11:48 σημειώθηκε μερική διακοπή ηλεκτροδότησης λόγω εργασιών.																											

[illegible]

[illegible]

Δευτέρα, 16 Σεπτέμβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		2,00	1,91	1,87	1,83	1,80	1,82	1,79	2,00	2,22	2,26	2,17	2,36	2,42	2,47	2,45	2,33	2,19	2,26	2,44	2,55	2,52	2,40	2,34	2,10	52,48
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9																				1	1	1		1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G6 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

Τρίτη, 17 Σεπτέμβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,95	1,82	1,77	1,72	1,70	1,72	1,74	1,94	2,10	2,20	2,23	2,27	2,34	2,42	2,37	2,22	2,16	2,24	2,37	2,58	2,57	2,41	2,27	2,11	51,22
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9							1	1	1	1	1									1	1	1			Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

Τετάρτη, 18 Σεπτέμβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,92	1,82	1,75	1,72	1,70	1,70	1,71	1,95	2,14	2,31	2,35	2,43	2,42	2,47	2,41	2,25	2,12	2,09	2,19	2,38	2,44	2,31	2,17	1,99	50,75
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA) G2 (CEGIELSKI 6AL20/24) G3 (CEGIELSKI 6AL20/24)	0,9 - -	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη Βλάβη Βλάβη
G4 (MITSUBISHI S16R-PTA) G5 (MITSUBISHI S16R-PTA) G6 (MTU 12V 4000G60)	0,9 0,9 -	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη Διαθέσιμη Βλάβη
G7 (MTU 12V 4000G60) G8 (MITSUBISHI S16R-PTA) G9 (MITSUBISHI S16R-PTA)	0,7 0,9 1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη Διαθέσιμη Διαθέσιμη

[illegible]

Παρασκευή, 20 Σεπτέμβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,92	1,80	1,73	1,70	1,67	1,70	1,70	1,95	2,15	2,23	2,20	2,27	2,33	2,31	2,30	2,19	2,10	2,16	2,31	2,40	2,36	2,26	2,14	1,99	49,87
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

Σάββατο, 21 Σεπτέμβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,86	1,75	1,69	1,67	1,63	1,65	1,65	1,83	1,97	2,12	2,15	2,25	2,37	2,39	2,27	2,19	2,06	2,11	2,24	2,43	2,40	2,24	2,10	1,95	48,99
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

Κυριακή, 22 Σεπτέμβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,81	1,70	1,65	1,63	1,59	1,65	1,67	1,81	1,90	2,03	2,11	2,20	2,27	2,27	2,18	2,15	2,06	2,11	2,19	2,33	2,37	2,23	2,07	1,95	47,93
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1			1	1																Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

[illegible]

[illegible]

[illegible]

Πέμπτη, 26 Σεπτέμβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,74	1,64	1,60	1,64	1,62	1,63	1,66	1,88	2,02	2,17	2,15	2,06	2,16	2,36	2,36	2,16	2,06	2,14	2,28	2,48	2,42	2,28	2,12	1,93	48,56
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9	1	1	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9								1	1																Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

Παρασκευή, 27 Σεπτέμβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,81	1,70	1,64	1,61	1,60	1,62	1,62	1,85	2,04	2,19	2,20	2,24	2,32	2,34	2,37	2,22	2,10	2,16	2,32	2,46	2,40	2,29	2,17	2,00	49,25
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

Σάββατο, 28 Σεπτέμβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,83	1,72	1,67	1,64	1,60	1,61	1,59	1,80	1,95	2,13	1,98	2,07	2,24	2,38	2,36	2,24	2,12	2,22	2,34	2,51	2,42	2,28	2,12	1,90	48,75
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

Κυριακή, 29 Σεπτέμβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,79	1,71	1,67	1,65	1,61	1,60	1,62	1,77	1,92	2,01	2,01	2,09	2,27	2,30	2,22	2,14	2,03	2,10	2,23	2,38	2,35	2,28	2,10	1,96	47,81
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

Δευτέρα, 30 Σεπτέμβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,83	1,72	1,67	1,65	1,64	1,65	1,67	1,85	2,04	2,16	2,02	1,99	2,04	2,09	1,99	1,82	1,73	1,75	1,95	2,15	2,07	1,94	1,77	1,58	44,78
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

[illegible]

[illegible]

[illegible]

Παρασκευή, 4 Οκτώβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,55	1,43	1,44	1,49	1,63	1,81	1,91	1,83	1,75	1,71	1,78	2,06	1,89	1,74	1,83	2,03	2,14	2,15	2,01	1,87	1,72	1,60	1,51	1,49	42,36
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9					1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1				Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

[illegible]

[illegible]

[illegible]

Τρίτη, 8 Οκτώβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,53	1,43	1,41	1,38	1,36	1,38	1,36	1,46	1,66	1,96	1,99	2,08	2,15	2,17	2,08	1,98	1,87	1,96	2,09	2,22	2,14	2,05	1,91	1,75	43,37	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	0,9										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																										Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9				1	1	1	1	1	1																	Διαθέσιμη
G6 (MTU 12V 4000G60)	-																										Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																										Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη

Τετάρτη, 9 Οκτώβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,60	1,58	1,55	1,53	1,51	1,55	1,58	1,73	1,88	2,02	1,97	2,06	2,09	2,07	2,00	1,90	1,69	1,75	2,00	2,19	2,13	2,01	1,83	1,69	43,92
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

Πέμπτη, 10 Οκτώβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,62	1,54	1,53	1,46	1,45	1,47	1,49	1,67	1,86	1,99	1,96	2,06	2,10	2,11	2,07	1,92	1,86	1,93	2,07	2,19	2,14	2,05	1,87	1,73	44,14
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9				1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9									1	1															Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

[illegible]

Σάββατο, 12 Οκτώβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,66	1,57	1,59	1,57	1,56	1,56	1,57	1,61	1,73	1,86	1,92	2,11	2,26	2,29	2,22	2,08	2,00	2,00	2,14	2,23	2,20	2,06	1,94	1,81	45,54
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9	1	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

[illegible]

Δευτέρα, 14 Οκτώβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,59	1,56	1,53	1,53	1,52	1,55	1,56	1,55	1,72	1,86	1,89	1,84	1,86	2,00	1,99	1,84	1,80	1,85	2,07	2,14	2,06	1,94	1,81	1,67	42,75
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

Τρίτη, 15 Οκτώβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,55	1,53	1,52	1,50	1,49	1,52	1,55	1,71	1,86	1,93	1,88	1,98	2,06	1,94	1,83	1,71	1,68	1,76	1,88	2,01	1,90	1,79	1,65	1,57	41,83
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9	1										1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9									1	1															Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

Τετάρτη, 16 Οκτώβριος 2024		Απολογισμός λειτουργίας ΗΣ Σύμης																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,42	1,35	1,31	1,31	1,31	1,33	1,46	1,57	1,73	1,90	1,90	1,89	1,94	1,94	1,87	1,77	1,70	1,73	1,85	1,99	1,93	1,82	1,66	1,60	40,26
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	0,9											1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G2 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G3 (CEGIELSKI 6AL20/24)	-																									Βλάβη
G4 (MITSUBISHI S16R-PTA)	0,9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G6 (MTU 12V 4000G60)	-																									Βλάβη
G7 (MTU 12V 4000G60)	0,7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,9																									Διαθέσιμη
G9 (MITSUBISHI S16R-PTA)	1																									Διαθέσιμη

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 17 Οκτωβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 17 Οκτωβρίου 2024	00:00	1,466				1			1		
	01:00	1,366				1			1		
	02:00	1,354				1			1		
	03:00	1,330				1			1		
	04:00	1,310				1			1		
	05:00	1,340				1			1		
	06:00	1,407				1			1		
	07:00	1,539				1			1		
	08:00	1,713				1			1		
	09:00	1,883				1			1		
	10:00	1,831				1			1		
	11:00	1,870				1			1		
	12:00	1,880				1			1		
	13:00	1,898				1			1		
	14:00	1,813				1			1		
	15:00	1,691				1			1		
	16:00	1,587				1			1		
	17:00	1,628				1			1		
	18:00	1,780				1			1		
	19:00	1,922				1			1		
	20:00	1,850				1			1		
	21:00	1,766				1			1		
	22:00	1,595				1			1		
	23:00	1,449				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 18 Οκτωβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 18 Οκτωβρίου 2024	00:00	1,326				1			1		
	01:00	1,281				1			1		
	02:00	1,283				1			1		
	03:00	1,265				1			1		
	04:00	1,255				1			1		
	05:00	1,301				1			1		
	06:00	1,404				1			1		
	07:00	1,505				1			1		
	08:00	1,641				1			1		
	09:00	1,545				1			1		
	10:00	1,515				1			1		
	11:00	1,607				1			1		
	12:00	1,739				1			1		
	13:00	1,793				1			1		
	14:00	1,705				1			1		
	15:00	1,574				1			1		
	16:00	1,541				1			1		
	17:00	1,582				1			1		
	18:00	1,739				1			1		
	19:00	1,820				1			1		
	20:00	1,801				1			1		
	21:00	1,468				1			1		
	22:00	1,337				1			1		
	23:00	1,208				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 19 Οκτωβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 19 Οκτωβρίου 2024	00:00	1,097				1			1		
	01:00	1,037				1			1		
	02:00	1,025				1			1		
	03:00	1,017				1			1		
	04:00	1,032				1			1		
	05:00	1,042				1			1		
	06:00	1,077				1			1		
	07:00	1,227				1			1		
	08:00	1,351				1			1		
	09:00	1,637				1			1		
	10:00	1,566				1			1		
	11:00	1,589				1			1		
	12:00	1,777				1			1		
	13:00	1,759				1			1		
	14:00	1,639				1			1		
	15:00	1,526				1			1		
	16:00	1,484				1			1		
	17:00	1,534				1			1		
	18:00	1,713				1			1		
	19:00	1,856				1			1		
	20:00	1,807				1			1		
	21:00	1,678				1			1		
	22:00	1,511				1			1		
	23:00	1,369				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 20 Οκτωβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 20 Οκτωβρίου 2024	00:00	1,278				1			1		
	01:00	1,230				1			1		
	02:00	1,212				1			1		
	03:00	1,110				1			1		
	04:00	1,037				1			1		
	05:00	1,080				1			1		
	06:00	1,156				1			1		
	07:00	1,226				1			1		
	08:00	1,351				1			1		
	09:00	1,613				1			1		
	10:00	1,654				1			1		
	11:00	1,736				1			1		
	12:00	1,771				1			1		
	13:00	1,830				1			1		
	14:00	1,687				1			1		
	15:00	1,618				1			1		
	16:00	1,536				1			1		
	17:00	1,513				1			1		
	18:00	1,671				1			1		
	19:00	1,786				1			1		
	20:00	1,711				1			1		
	21:00	1,616				1			1		
	22:00	1,477				1			1		
	23:00	1,373				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 21 Οκτωβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 21 Οκτωβρίου 2024	00:00	1,266				1			1		
	01:00	1,214				1			1		
	02:00	1,194				1			1		
	03:00	1,188				1			1		
	04:00	1,180				1			1		
	05:00	1,238				1			1		
	06:00	1,248				1			1		
	07:00	1,298				1			1		
	08:00	1,580				1			1		
	09:00	1,677				1			1		
	10:00	1,689				1			1		
	11:00	1,751				1			1		
	12:00	1,716				1			1		
	13:00	1,733				1			1		
	14:00	1,635				1			1		
	15:00	1,545				1			1		
	16:00	1,487				1			1		
	17:00	1,540				1			1		
	18:00	1,719				1			1		
	19:00	1,831				1			1		
	20:00	1,805				1			1		
	21:00	1,642				1			1		
	22:00	1,493				1			1		
	23:00	1,327				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 22 Οκτωβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 22 Οκτωβρίου 2024	00:00	1,248				1			1		
	01:00	1,169				1			1		
	02:00	1,171				1			1		
	03:00	1,149				1			1		
	04:00	1,174				1			1		
	05:00	1,230				1			1		
	06:00	1,205				1			1		
	07:00	1,272				1			1		
	08:00	1,504				1			1		
	09:00	1,653				1			1		
	10:00	1,643				1			1		
	11:00	1,679				1			1		
	12:00	1,702				1			1		
	13:00	1,740				1			1		
	14:00	1,665				1			1		
	15:00	1,512				1			1		
	16:00	1,653				1			1		
	17:00	1,711				1			1		
	18:00	1,822				1			1		
	19:00	1,934				1			1		
	20:00	1,880				1			1		
	21:00	1,781				1			1		
	22:00	1,631				1			1		
	23:00	1,506				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 23 Οκτωβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 23 Οκτωβρίου 2024	00:00	1,416				1			1		
	01:00	1,357				1			1		
	02:00	1,346				1			1		
	03:00	1,329					1		1		
	04:00	1,324					1		1		
	05:00	1,366					1		1		
	06:00	1,365					1		1		
	07:00	1,362					1		1		
	08:00	1,534					1		1		
	09:00	1,779				1			1		
	10:00	1,796				1			1		
	11:00	1,686				1			1		
	12:00	1,829				1			1		
	13:00	1,865				1			1		
	14:00	1,788				1			1		
	15:00	1,651				1			1		
	16:00	1,654				1			1		
	17:00	1,676				1			1		
	18:00	1,801				1			1		
	19:00	1,874				1			1		
	20:00	1,873				1			1		
	21:00	1,777				1			1		
	22:00	1,610				1			1		
	23:00	1,473				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 24 Οκτωβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 24 Οκτωβρίου 2024	00:00	1,378				1			1		
	01:00	1,335				1			1		
	02:00	1,340				1			1		
	03:00	1,332				1			1		
	04:00	1,324				1			1		
	05:00	1,345				1			1		
	06:00	1,357				1			1		
	07:00	1,538				1			1		
	08:00	1,637				1			1		
	09:00	1,719				1			1		
	10:00	1,775				1			1		
	11:00	1,748				1			1		
	12:00	1,855				1			1		
	13:00	1,880				1			1		
	14:00	1,767				1			1		
	15:00	1,656				1			1		
	16:00	1,606				1			1		
	17:00	1,661				1			1		
	18:00	1,841				1			1		
	19:00	1,936				1			1		
	20:00	1,814				1			1		
	21:00	1,755				1			1		
	22:00	1,583				1			1		
	23:00	1,470				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 25 Οκτωβρίου 2024							
Αποδιδόμενη Ισχύς (MW)			1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	
Α	Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 25 Οκτωβρίου 2024		00:00	1,383				1			1		
		01:00	1,333				1			1		
		02:00	1,214				1			1		
		03:00	1,192				1			1		
		04:00	1,284				1			1		
		05:00	1,348				1			1		
		06:00	1,350				1			1		
		07:00	1,497				1			1		
		08:00	1,686				1			1		
		09:00	1,792				1			1		
		10:00	1,611				1			1		
		11:00	1,633				1			1		
		12:00	1,699				1			1		
		13:00	1,705				1			1		
		14:00	1,604				1			1		
		15:00	1,502				1			1		
		16:00	1,437				1			1		
		17:00	1,507				1			1		
		18:00	1,640				1			1		
		19:00	1,753				1			1		
		20:00	1,663				1			1		
		21:00	1,532				1			1		
		22:00	1,384				1			1		
		23:00	1,266				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 26 Οκτωβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 26 Οκτωβρίου 2024	00:00	1,194				1			1		
	01:00	1,140				1			1		
	02:00	1,123				1			1		
	03:00	1,157				1			1		
	04:00	1,165				1			1		
	05:00	1,170				1			1		
	06:00	1,155				1			1		
	07:00	1,321				1			1		
	08:00	1,392				1			1		
	09:00	1,429				1			1		
	10:00	1,427				1			1		
	11:00	1,515				1			1		
	12:00	1,621				1			1		
	13:00	1,622				1			1		
	14:00	1,565				1			1		
	15:00	1,469				1			1		
	16:00	1,485				1			1		
	17:00	1,503				1			1		
	18:00	1,617				1			1		
	19:00	1,724				1			1		
	20:00	1,718				1			1		
	21:00	1,553				1			1		
	22:00	1,463				1			1		
	23:00	1,332				1			1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 27 Οκτωβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 27 Οκτωβρίου 2024	00:00	1,216				1			1		
	01:00	1,157				1			1		
	02:00	1,169				1			1		
	03:00	1,159				1			1		
	04:00	1,163				1			1		
	05:00	1,014				1			1		
	06:00	1,056				1			1		
	07:00	1,182				1			1		
	08:00	1,255				1			1		
	09:00	1,313				1			1		
	10:00	1,440				1			1		
	11:00	1,525				1			1		
	12:00	1,522				1			1		
	13:00	1,503				1			1		
	14:00	1,440				1			1		
	15:00	1,371				1			1		
	16:00	1,349				1			1		
	17:00	1,470				1			1		
	18:00	1,626				1			1		
	19:00	1,749				1			1		
	20:00	1,650				1			1		
	21:00	1,524				1			1		
	22:00	1,357				1			1		
	23:00	1,217				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 28 Οκτωβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 28 Οκτωβρίου 2024	00:00	1,180				1			1		
	01:00	1,144				1			1		
	02:00	1,132				1			1		
	03:00	1,119				1			1		
	04:00	1,136				1			1		
	05:00	1,173				1			1		
	06:00	1,205				1			1		
	07:00	1,234				1			1		
	08:00	1,463				1			1		
	09:00	1,611				1			1		
	10:00	1,620				1			1		
	11:00	1,556				1			1		
	12:00	1,632				1			1		
	13:00	1,622				1			1		
	14:00	1,540				1			1		
	15:00	1,487				1			1		
	16:00	1,436				1			1		
	17:00	1,551				1			1		
	18:00	1,694				1			1		
	19:00	1,696				1			1		
	20:00	1,611				1			1		
	21:00	1,486				1			1		
	22:00	1,329				1			1		
	23:00	1,219				1			1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 29 Οκτωβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 29 Οκτωβρίου 2024	00:00	1,144				1			1		
	01:00	1,134				1			1		
	02:00	1,137				1			1		
	03:00	1,125				1			1		
	04:00	1,139				1			1		
	05:00	1,153				1			1		
	06:00	1,144				1			1		
	07:00	1,157				1			1		
	08:00	1,348				1			1		
	09:00	1,527				1			1		
	10:00	1,525				1			1		
	11:00	1,534				1			1		
	12:00	1,531				1			1		
	13:00	1,583				1			1		
	14:00	1,510				1			1		
	15:00	1,457				1			1		
	16:00	1,444				1			1		
	17:00	1,564				1			1		
	18:00	1,622				1			1		
	19:00	1,622				1			1		
	20:00	1,585				1			1		
	21:00	1,500				1			1		
	22:00	1,334				1			1		
	23:00	1,249				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 30 Οκτωβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 30 Οκτωβρίου 2024	00:00	1,175				1			1		
	01:00	1,132				1			1		
	02:00	1,110				1			1		
	03:00	1,118				1			1		
	04:00	1,119				1			1		
	05:00	1,145				1			1		
	06:00	1,121				1			1		
	07:00	1,136				1			1		
	08:00	1,325				1			1		
	09:00	1,472				1			1		
	10:00	1,539				1			1		
	11:00	1,551				1			1		
	12:00	1,571				1			1		
	13:00	1,528				1			1		
	14:00	1,488				1			1		
	15:00	1,449				1			1		
	16:00	1,412				1			1		
	17:00	1,543				1			1		
	18:00	1,629				1			1		
	19:00	1,618				1			1		
	20:00	1,567				1			1		
	21:00	1,484				1			1		
	22:00	1,357				1			1		
	23:00	1,269				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 31 Οκτωβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 31 Οκτωβρίου 2024	00:00	1,193				1					
	01:00	1,139				1					
	02:00	1,124				1					
	03:00	1,106				1					
	04:00	1,108				1					
	05:00	1,106				1					
	06:00	1,071				1					
	07:00	1,126				1					
	08:00	1,391				1	1				
	09:00	1,538				1	1				
	10:00	1,564				1	1				
	11:00	1,752				1	1				
	12:00	1,790				1	1				
	13:00	1,808				1			1		
	14:00	1,753				1			1		
	15:00	1,659				1			1		
	16:00	1,559				1			1		
	17:00	1,711				1			1		
	18:00	1,797	1			1			1		
	19:00	1,768	1			1			1		
	20:00	1,709				1			1		
	21:00	1,582				1			1		
	22:00	1,477				1			1		
	23:00	1,401				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 1 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 1 Νοεμβρίου 2024	00:00	1,329				1			1		
	01:00	1,277				1			1		
	02:00	1,274				1			1		
	03:00	1,260				1			1		
	04:00	1,270				1			1		
	05:00	1,312				1			1		
	06:00	1,318				1			1		
	07:00	1,446				1			1		
	08:00	1,491				1			1		
	09:00	1,562	1			1					
	10:00	1,572	1			1					
	11:00	1,612	1			1					
	12:00	1,625	1			1					
	13:00	1,667	1			1					
	14:00	1,552	1			1					
	15:00	1,531	1			1					
	16:00	1,548	1			1					
	17:00	1,711	1			1					
	18:00	1,806	1			1					
	19:00	1,723	1			1					
	20:00	1,729	1			1					
	21:00	1,670	1			1					
	22:00	1,526	1			1					
	23:00	1,433	1			1					



Μη διαθεσιμότητα μονάδας λόγω σι

Μη διαθεσιμότητα μονάδας λόγω βλ

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 2 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 2 Νοεμβρίου 2024	00:00	1,344	1			1					
	01:00	1,299	1			1					
	02:00	1,294	1			1					
	03:00	1,294	1			1					
	04:00	1,298	1			1					
	05:00	1,310	1			1					
	06:00	1,306	1			1					
	07:00	1,464	1			1					
	08:00	1,546	1			1					
	09:00	1,608	1			1					
	10:00	1,674	1			1			1		
	11:00	1,722	1			1			1		
	12:00	1,739	1			1			1		
	13:00	1,723	1			1			1		
	14:00	1,648	1			1			1		
	15:00	1,596	1			1			1		
	16:00	1,584	1			1			1		
	17:00	1,734	1			1					
	18:00	1,831	1			1					
	19:00	1,764	1			1					
	20:00	1,721	1			1					
	21:00	1,494	1			1					
	22:00	1,376	1			1					
	23:00	1,349	1			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 3 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 3 Νοεμβρίου 2024	00:00	1,331	1			1					
	01:00	1,308	1			1					
	02:00	1,294	1			1					
	03:00	1,279	1			1					
	04:00	1,304	1			1					
	05:00	1,328	1			1					
	06:00	1,288	1			1					
	07:00	1,418	1			1					
	08:00	1,453	1			1					
	09:00	1,539	1			1					
	10:00	1,585				1			1		
	11:00	1,666					1		1		
	12:00	1,729					1		1		
	13:00	1,717				1			1		
	14:00	1,595				1			1		
	15:00	1,535				1			1		
	16:00	1,503				1			1		
	17:00	1,636				1			1		
	18:00	1,718				1			1		
	19:00	1,706				1			1		
	20:00	1,705				1			1		
	21:00	1,603				1			1		
	22:00	1,490				1			1		
	23:00	1,401				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 4 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 4 Νοεμβρίου 2024	00:00	1,325				1			1		
	01:00	1,265				1			1		
	02:00	1,261				1			1		
	03:00	1,250				1			1		
	04:00	1,260				1			1		
	05:00	1,279				1			1		
	06:00	1,293				1			1		
	07:00	1,455				1			1		
	08:00	1,578				1			1		
	09:00	1,652				1			1		
	10:00	1,678				1			1		
	11:00	1,685				1			1		
	12:00	1,646				1			1		
	13:00	1,602				1			1		
	14:00	1,578				1			1		
	15:00	1,509				1			1		
	16:00	1,511				1			1		
	17:00	1,652				1			1		
	18:00	1,721				1			1		
	19:00	1,731				1			1		
	20:00	1,731				1			1		
	21:00	1,646				1			1		
	22:00	1,502				1			1		
	23:00	1,369				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 5 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Α Ρ Χ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 5 Νοεμβρίου 2024	00:00	1,286				1			1		
	01:00	1,261				1			1		
	02:00	1,260				1			1		
	03:00	1,237				1			1		
	04:00	1,250				1			1		
	05:00	1,270				1			1		
	06:00	1,265				1			1		
	07:00	1,291				1			1		
	08:00	1,351				1			1		
	09:00	1,337				1			1		
	10:00	1,380				1			1		
	11:00	1,411				1			1		
	12:00	1,375				1			1		
	13:00	1,378				1			1		
	14:00	1,382				1			1		
	15:00	1,338				1			1		
	16:00	1,353				1			1		
	17:00	1,485				1			1		
	18:00	1,598				1			1		
	19:00	1,552				1			1		
	20:00	1,501				1			1		
	21:00	1,423				1			1		
	22:00	1,346				1			1		
	23:00	1,195				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 6 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 6 Νοεμβρίου 2024	00:00	1,109				1			1		
	01:00	1,077				1			1		
	02:00	1,098				1			1		
	03:00	1,086				1			1		
	04:00	1,094				1			1		
	05:00	1,102				1			1		
	06:00	1,137				1			1		
	07:00	1,277				1			1		
	08:00	1,368				1			1		
	09:00	1,415				1			1		
	10:00	1,454				1			1		
	11:00	1,413				1			1		
	12:00	1,404				1			1		
	13:00	1,413				1			1		
	14:00	1,385				1			1		
	15:00	1,364				1			1		
	16:00	1,415				1			1		
	17:00	1,600				1			1		
	18:00	1,650				1			1		
	19:00	1,591				1			1		
	20:00	1,575				1			1		
	21:00	1,494				1			1		
	22:00	1,391				1			1		
	23:00	1,286				1			1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 7 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 7 Νοεμβρίου 2024	00:00	1,156				1			1		
	01:00	1,126				1			1		
	02:00	1,120				1			1		
	03:00	1,099				1			1		
	04:00	1,116				1			1		
	05:00	1,131				1			1		
	06:00	1,134				1			1		
	07:00	1,282				1			1		
	08:00	1,428				1			1		
	09:00	1,475				1			1		
	10:00	1,575				1			1		
	11:00	1,729				1			1		
	12:00	1,697				1			1		
	13:00	1,704				1			1		
	14:00	1,643				1			1		
	15:00	1,653				1			1		
	16:00	1,669				1			1		
	17:00	1,798	1			1			1		
	18:00	1,841	1			1			1		
	19:00	1,756	1			1			1		
	20:00	1,626				1			1		
	21:00	1,612				1			1		
	22:00	1,558				1			1		
	23:00	1,545				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 8 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 8 Νοεμβρίου 2024	00:00	1,485				1			1		
	01:00	1,395				1			1		
	02:00	1,366				1			1		
	03:00	1,362				1			1		
	04:00	1,359				1			1		
	05:00	1,356				1			1		
	06:00	1,355				1			1		
	07:00	1,319				1			1		
	08:00	1,442				1			1		
	09:00	1,482				1			1		
	10:00	1,438				1			1		
	11:00	1,413				1			1		
	12:00	1,444				1			1		
	13:00	1,431				1			1		
	14:00	1,346				1			1		
	15:00	1,414				1			1		
	16:00	1,402				1			1		
	17:00	1,580				1			1		
	18:00	1,679				1			1		
	19:00	1,633				1			1		
	20:00	1,585				1			1		
	21:00	1,510				1			1		
	22:00	1,436				1			1		
	23:00	1,330				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 9 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Α Ξ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 9 Νοεμβρίου 2024	00:00	1,258				1			1		
	01:00	1,178				1			1		
	02:00	1,179				1			1		
	03:00	1,199				1			1		
	04:00	1,198				1			1		
	05:00	1,195				1			1		
	06:00	1,252				1			1		
	07:00	1,337				1			1		
	08:00	1,395				1			1		
	09:00	1,311				1			1		
	10:00	1,240				1			1		
	11:00	1,388				1			1		
	12:00	1,478				1			1		
	13:00	1,472				1			1		
	14:00	1,446				1			1		
	15:00	1,375				1			1		
	16:00	1,354				1			1		
	17:00	1,408				1			1		
	18:00	1,331				1			1		
	19:00	1,322				1			1		
	20:00	1,324				1			1		
	21:00	1,199				1			1		
	22:00	1,108				1			1		
	23:00	0,991				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 10 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 10 Νοεμβρίου 2024	00:00	0,895				1			1		
	01:00	0,838				1					
	02:00	0,829				1					
	03:00	0,835				1					
	04:00	0,814				1					
	05:00	0,821				1					
	06:00	0,883				1					
	07:00	0,945				1			1		
	08:00	1,004				1			1		
	09:00	1,113				1			1		
	10:00	1,174				1			1		
	11:00	1,211				1			1		
	12:00	1,380				1			1		
	13:00	1,370				1			1		
	14:00	1,237				1			1		
	15:00	1,222				1			1		
	16:00	1,245				1			1		
	17:00	1,369				1			1		
	18:00	1,430				1			1		
	19:00	1,484				1			1		
	20:00	1,537				1			1		
	21:00	1,410				1			1		
	22:00	1,174				1			1		
	23:00	1,044				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 11 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 11 Νοεμβρίου 2024	00:00	0,949				1			1		
	01:00	0,905				1			1		
	02:00	0,902				1			1		
	03:00	0,896				1					
	04:00	0,892				1					
	05:00	0,905				1					
	06:00	0,907				1					
	07:00	1,094				1			1		
	08:00	1,175				1			1		
	09:00	1,223				1			1		
	10:00	1,254				1			1		
	11:00	1,282				1			1		
	12:00	1,244				1			1		
	13:00	1,247				1			1		
	14:00	1,331				1			1		
	15:00	1,254				1			1		
	16:00	1,246				1			1		
	17:00	1,412				1			1		
	18:00	1,485				1			1		
	19:00	1,484				1			1		
	20:00	1,458				1			1		
	21:00	1,366				1			1		
	22:00	1,276				1			1		
	23:00	1,176				1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 12 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 12 Νοεμβρίου 2024	00:00	1,099				1			1		
	01:00	0,993				1			1		
	02:00	1,028				1			1		
	03:00	1,022				1			1		
	04:00	1,016				1			1		
	05:00	1,026				1			1		
	06:00	1,003				1			1		
	07:00	1,167				1			1		
	08:00	1,243				1			1		
	09:00	1,306				1			1		
	10:00	1,307				1			1		
	11:00	1,211				1			1		
	12:00	1,372				1			1		
	13:00	1,363					1		1		
	14:00	1,285					1		1		
	15:00	1,279					1		1		
	16:00	1,187					1		1		
	17:00	1,337					1		1		
	18:00	1,333					1		1		
	19:00	1,468					1		1		
	20:00	1,539					1		1		
	21:00	1,473					1		1		
	22:00	1,344					1		1		
	23:00	1,224					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 13 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 13 Νοεμβρίου 2024	00:00	1,133					1		1		
	01:00	1,055					1		1		
	02:00	1,043					1		1		
	03:00	1,051					1		1		
	04:00	1,055					1		1		
	05:00	1,072					1		1		
	06:00	1,069					1		1		
	07:00	1,148					1		1		
	08:00	1,251	1				1				
	09:00	1,329	1				1				
	10:00	1,268	1				1				
	11:00	1,274	1				1				
	12:00	1,321	1				1				
	13:00	1,273					1		1		
	14:00	1,227					1		1		
	15:00	1,228					1		1		
	16:00	1,237					1		1		
	17:00	1,396					1		1		
	18:00	1,494					1		1		
	19:00	1,509					1		1		
	20:00	1,431					1		1		
	21:00	1,360					1		1		
	22:00	1,306					1		1		
	23:00	1,187					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 14 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 14 Νοεμβρίου 2024	00:00	1,096					1		1		
	01:00	1,049					1		1		
	02:00	1,046					1		1		
	03:00	1,022					1		1		
	04:00	1,011					1		1		
	05:00	1,030					1		1		
	06:00	1,000					1		1		
	07:00	1,038					1		1		
	08:00	1,272	1				1				
	09:00	1,295	1				1				
	10:00	1,300	1				1				
	11:00	1,164	1				1				
	12:00	1,326	1				1				
	13:00	1,333	1				1				
	14:00	1,251					1		1		
	15:00	1,236					1		1		
	16:00	1,220					1		1		
	17:00	1,392					1		1		
	18:00	1,490					1		1		
	19:00	1,465					1		1		
	20:00	1,431					1		1		
	21:00	1,376					1		1		
	22:00	1,292					1		1		
	23:00	1,139					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 15 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 15 Νοεμβρίου 2024	00:00	1,081					1		1		
	01:00	1,048					1		1		
	02:00	1,040					1		1		
	03:00	1,029					1		1		
	04:00	1,005					1		1		
	05:00	1,047					1		1		
	06:00	1,011					1		1		
	07:00	0,962					1		1		
	08:00	1,074					1		1		
	09:00	1,137					1		1		
	10:00	1,123					1		1		
	11:00	1,121					1		1		
	12:00	1,232					1		1		
	13:00	1,312					1		1		
	14:00	1,100					1		1		
	15:00	1,144					1		1		
	16:00	1,199					1		1		
	17:00	1,354					1		1		
	18:00	1,346					1		1		
	19:00	1,325					1		1		
	20:00	1,286					1		1		
	21:00	1,192					1		1		
	22:00	1,086					1		1		
	23:00	0,991					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 16 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 16 Νοεμβρίου 2024	00:00	0,904					1		1		
	01:00	0,861					1		1		
	02:00	0,852					1		1		
	03:00	0,838					1		1		
	04:00	0,831					1		1		
	05:00	0,845					1		1		
	06:00	0,824					1		1		
	07:00	0,946					1		1		
	08:00	1,062					1		1		
	09:00	1,161					1		1		
	10:00	1,261					1		1		
	11:00	1,218					1		1		
	12:00	1,250					1		1		
	13:00	1,267					1		1		
	14:00	1,262					1		1		
	15:00	1,292					1		1		
	16:00	1,307					1		1		
	17:00	1,449					1		1		
	18:00	1,477					1		1		
	19:00	1,443					1		1		
	20:00	1,452					1		1		
	21:00	1,357					1		1		
	22:00	1,189					1		1		
	23:00	1,138					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 17 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 17 Νοεμβρίου 2024	00:00	1,049					1		1		
	01:00	1,001					1		1		
	02:00	0,990					1		1		
	03:00	0,978					1		1		
	04:00	0,960					1		1		
	05:00	0,998					1		1		
	06:00	0,816					1		1		
	07:00	0,931					1		1		
	08:00	1,029	1				1				
	09:00	1,199	1				1				
	10:00	1,320	1				1				
	11:00	1,416	1				1				
	12:00	1,306	1				1				
	13:00	1,144	1				1				
	14:00	1,126					1		1		
	15:00	1,015					1		1		
	16:00	1,166					1		1		
	17:00	1,287					1		1		
	18:00	1,367					1		1		
	19:00	1,375					1		1		
	20:00	1,351					1		1		
	21:00	1,243					1		1		
	22:00	1,145					1		1		
	23:00	1,009					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 18 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 18 Νοεμβρίου 2024	00:00	0,926					1		1		
	01:00	0,880					1		1		
	02:00	0,858					1		1		
	03:00	0,848					1		1		
	04:00	0,861					1		1		
	05:00	0,922					1		1		
	06:00	0,962					1		1		
	07:00	1,069					1		1		
	08:00	1,247	1				1				
	09:00	1,309	1				1				
	10:00	1,288	1				1				
	11:00	1,406	1				1				
	12:00	1,435	1				1				
	13:00	1,432					1		1		
	14:00	1,376					1		1		
	15:00	1,343					1		1		
	16:00	1,349					1		1		
	17:00	1,477					1		1		
	18:00	1,534					1		1		
	19:00	1,576					1		1		
	20:00	1,541					1		1		
	21:00	1,516					1		1		
	22:00	1,352					1		1		
	23:00	1,195					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 19 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 19 Νοεμβρίου 2024	00:00	1,089					1		1		
	01:00	1,044					1		1		
	02:00	1,056					1		1		
	03:00	1,044					1		1		
	04:00	1,032					1		1		
	05:00	1,037					1		1		
	06:00	1,024					1		1		
	07:00	1,189					1		1		
	08:00	1,329	1				1				
	09:00	1,286	1				1				
	10:00	1,288	1				1				
	11:00	1,273	1				1				
	12:00	1,307	1				1				
	13:00	1,322	1				1				
	14:00	1,286	1				1				
	15:00	1,278					1		1		
	16:00	1,315					1		1		
	17:00	1,475					1		1		
	18:00	1,465					1		1		
	19:00	1,426					1		1		
	20:00	1,434					1		1		
	21:00	1,454					1		1		
	22:00	1,370					1		1		
	23:00	1,229					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 20 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 20 Νοεμβρίου 2024	00:00	1,111					1		1		
	01:00	1,049					1		1		
	02:00	1,043					1		1		
	03:00	1,068					1		1		
	04:00	1,061					1		1		
	05:00	1,050					1		1		
	06:00	1,032					1		1		
	07:00	1,190					1		1		
	08:00	1,299	1				1				
	09:00	1,337	1				1				
	10:00	1,349	1				1				
	11:00	1,323	1				1				
	12:00	1,319	1				1				
	13:00	1,302	1				1				
	14:00	1,297					1		1		
	15:00	1,320					1		1		
	16:00	1,341					1		1		
	17:00	1,501					1		1		
	18:00	1,591					1		1		
	19:00	1,647					1		1		
	20:00	1,597					1		1		
	21:00	1,482					1		1		
	22:00	1,365					1		1		
	23:00	1,189					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 21 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 21 Νοεμβρίου 2024	00:00	1,094					1		1		
	01:00	1,059					1		1		
	02:00	1,063					1		1		
	03:00	1,050					1		1		
	04:00	1,045					1		1		
	05:00	1,070					1		1		
	06:00	1,032					1		1		
	07:00	1,193					1		1		
	08:00	1,292	1								1
	09:00	1,333	1								1
	10:00	1,342	1								1
	11:00	1,367					1				1
	12:00	1,383					1				1
	13:00	1,412					1				1
	14:00	1,306					1				1
	15:00	1,279					1		1		
	16:00	1,309					1		1		
	17:00	1,473					1		1		
	18:00	1,566					1		1		
	19:00	1,544					1		1		
	20:00	1,537					1		1		
	21:00	1,431					1		1		
	22:00	1,321					1		1		
	23:00	1,191					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 22 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 22 Νοεμβρίου 2024	00:00	1,105					1		1		
	01:00	1,044					1		1		
	02:00	1,007					1		1		
	03:00	1,037					1		1		
	04:00	1,058					1		1		
	05:00	1,063					1		1		
	06:00	1,061					1		1		
	07:00	1,110					1		1		
	08:00	1,232					1		1		
	09:00	1,272					1		1		
	10:00	1,232					1		1		
	11:00	1,245					1		1		
	12:00	1,238					1		1		
	13:00	1,193					1				1
	14:00	1,160					1				1
	15:00	1,161					1				1
	16:00	1,179					1				1
	17:00	1,311					1				1
	18:00	1,384					1				1
	19:00	1,410					1		1		
	20:00	1,485					1		1		
	21:00	1,422					1		1		
	22:00	1,284					1		1		
	23:00	1,165					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 23 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Α Ρ Χ Η	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 23 Νοεμβρίου 2024	00:00	1,067					1		1		
	01:00	1,026					1		1		
	02:00	1,007					1		1		
	03:00	1,035					1		1		
	04:00	1,049					1		1		
	05:00	1,049					1		1		
	06:00	1,030					1		1		
	07:00	1,122					1		1		
	08:00	1,218					1		1		
	09:00	1,261					1		1		
	10:00	1,340					1		1		
	11:00	1,412	1						1		
	12:00	1,410	1						1		
	13:00	1,397	1						1		
	14:00	1,316	1						1		
	15:00	1,339	1						1		
	16:00	1,375	1						1		
	17:00	1,537	1						1		
	18:00	1,546	1						1		
	19:00	1,569	1						1		
	20:00	1,525	1						1		
	21:00	1,448	1						1		
	22:00	1,393	1						1		
	23:00	1,310	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 24 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 24 Νοεμβρίου 2024	00:00	1,192	1						1		
	01:00	1,134	1						1		
	02:00	1,093	1						1		
	03:00	1,106	1						1		
	04:00	1,089	1						1		
	05:00	1,080	1						1		
	06:00	1,003	1						1		
	07:00	1,167	1						1		
	08:00	1,275	1								1
	09:00	1,312	1								1
	10:00	1,433	1				1				1
	11:00	1,453	1				1				
	12:00	1,467	1				1				
	13:00	1,422					1		1		
	14:00	1,453					1		1		
	15:00	1,513					1		1		
	16:00	1,560					1		1		
	17:00	1,772	1				1		1		
	18:00	1,871	1				1		1		
	19:00	1,880	1				1		1		
	20:00	1,822	1				1		1		
	21:00	1,718	1				1		1		
	22:00	1,227							1		
	23:00	1,243	1						1		

Γενική διακοπή στις 22:40 λόγω βλάβης της G5.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 25 Νοεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 25 Νοεμβρίου 2024	00:00	1,178	1						1		
	01:00	1,150	1						1		
	02:00	1,116	1						1		
	03:00	1,116	1						1		
	04:00	1,145	1						1		
	05:00	1,173	1						1		
	06:00	1,187	1						1		
	07:00	1,245	1								1
	08:00	1,463	1								1
	09:00	1,478	1				1				
	10:00	1,291	1				1				
	11:00	1,361	1				1				
	12:00	1,527	1				1				
	13:00	1,479					1		1		
	14:00	1,471					1		1		
	15:00	1,563					1		1		
	16:00	1,680					1		1		
	17:00	1,901	1				1		1		
	18:00	1,981	1				1		1		
	19:00	1,952	1				1		1		
	20:00	1,914	1				1		1		
	21:00	1,810	1				1		1		
	22:00	1,655	1				1		1		
	23:00	1,526	1				1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 3 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 3 Δεκεμβρίου 2024	00:00	1,102	1				1				
	01:00	1,021	1				1				
	02:00	0,979	1				1				
	03:00	0,980	1				1				
	04:00	0,996	1				1				
	05:00	0,978	1				1				
	06:00	1,044	1				1				
	07:00	1,159	1				1				
	08:00	1,260	1				1				
	09:00	1,377	1				1				
	10:00	1,457	1				1				
	11:00	1,545	1				1				
	12:00	1,528	1				1				
	13:00	1,403					1		1		
	14:00	1,357					1		1		
	15:00	1,361					1		1		
	16:00	1,448					1		1		
	17:00	1,586					1		1		
	18:00	1,651					1		1		
	19:00	1,634					1		1		
	20:00	1,647					1		1		
	21:00	1,610					1		1		
	22:00	1,464					1		1		
	23:00	1,236					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 4 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 4 Δεκεμβρίου 2024	00:00	1,069					1		1		
	01:00	0,982					1		1		
	02:00	0,952					1		1		
	03:00	0,951					1		1		
	04:00	0,965					1		1		
	05:00	0,983					1		1		
	06:00	1,086					1		1		
	07:00	1,192					1		1		
	08:00	1,275	1				1				
	09:00	1,232	1				1				
	10:00	1,222	1				1				
	11:00	1,197	1				1				
	12:00	1,165	1				1				
	13:00	1,181	1				1				
	14:00	1,203					1		1		
	15:00	1,301					1		1		
	16:00	1,364					1		1		
	17:00	1,524					1		1		
	18:00	1,602					1		1		
	19:00	1,655					1		1		
	20:00	1,686					1		1		
	21:00	1,651					1		1		
	22:00	1,528					1		1		
	23:00	1,273					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 5 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 5 Δεκεμβρίου 2024	00:00	1,084					1		1		
	01:00	1,006					1		1		
	02:00	0,970					1		1		
	03:00	0,974					1		1		
	04:00	0,994					1		1		
	05:00	1,024					1		1		
	06:00	1,136					1		1		
	07:00	1,240					1		1		
	08:00	1,376	1				1				
	09:00	1,347	1				1				
	10:00	1,292	1				1				
	11:00	1,239	1				1				
	12:00	1,244	1				1				
	13:00	1,294					1		1		
	14:00	1,271					1		1		
	15:00	1,388					1		1		
	16:00	1,462					1		1		
	17:00	1,661					1		1		
	18:00	1,718					1		1		
	19:00	1,698					1		1		
	20:00	1,651					1		1		
	21:00	1,607					1		1		
	22:00	1,453					1		1		
	23:00	1,291					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 6 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Α Σ Τ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 6 Δεκεμβρίου 2024	00:00	1,114					1		1		
	01:00	1,015					1		1		
	02:00	0,985					1		1		
	03:00	0,984					1		1		
	04:00	0,982					1		1		
	05:00	0,995					1		1		
	06:00	1,151					1		1		
	07:00	1,178					1		1		
	08:00	1,270	1				1				
	09:00	1,293	1				1				
	10:00	1,377	1				1				
	11:00	1,453	1				1				
	12:00	1,534	1				1				
	13:00	1,493	1				1				
	14:00	1,453					1		1		
	15:00	1,488					1		1		
	16:00	1,503					1		1		
	17:00	1,583					1		1		
	18:00	1,626					1		1		
	19:00	1,632					1		1		
	20:00	1,655					1		1		
	21:00	1,583					1		1		
	22:00	1,448					1		1		
	23:00	1,255					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 7 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 7 Δεκεμβρίου 2024	00:00	1,124					1		1		
	01:00	1,020					1		1		
	02:00	0,972					1		1		
	03:00	0,965					1		1		
	04:00	0,958					1		1		
	05:00	0,965					1		1		
	06:00	1,031					1		1		
	07:00	1,143					1		1		
	08:00	1,238	1				1				
	09:00	1,291	1				1				
	10:00	1,360	1				1				
	11:00	1,425	1				1				
	12:00	1,492	1				1				
	13:00	1,497	1				1		1		
	14:00	1,434					1		1		
	15:00	1,401					1		1		
	16:00	1,498					1		1		
	17:00	1,699					1		1		
	18:00	1,751					1		1		
	19:00	1,714					1		1		
	20:00	1,721					1		1		
	21:00	1,579					1		1		
	22:00	1,422					1		1		
	23:00	1,221					1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 8 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 8 Δεκεμβρίου 2024	00:00	1,088					1		1		
	01:00	0,982					1		1		
	02:00	0,966					1		1		
	03:00	0,988					1		1		
	04:00	0,981					1		1		
	05:00	0,955					1		1		
	06:00	1,003					1		1		
	07:00	1,116	1				1		1		
	08:00	1,235	1				1				
	09:00	1,322	1				1				
	10:00	1,350	1				1				
	11:00	1,432	1				1				
	12:00	1,520	1				1				
	13:00	1,528	1				1				
	14:00	1,368	1				1	1			
	15:00	1,382					1	1			
	16:00	1,389					1	1			
	17:00	1,480					1	1			
	18:00	1,606					1	1			
	19:00	1,581					1	1			
	20:00	1,564					1	1			
	21:00	1,499					1	1			
	22:00	1,366					1	1			
	23:00	1,217					1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 9 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Α Π Ε Ρ Ε Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 9 Δεκεμβρίου 2024	00:00	1,052					1	1			
	01:00	0,962					1	1			
	02:00	0,929					1	1			
	03:00	0,941					1	1			
	04:00	0,941					1	1			
	05:00	0,935					1	1			
	06:00	1,021					1	1			
	07:00	1,135					1	1			
	08:00	1,248	1				1				
	09:00	1,286	1				1				
	10:00	1,270	1				1				
	11:00	1,243	1				1				
	12:00	1,233	1				1				
	13:00	1,244	1				1				
	14:00	1,250	1				1				
	15:00	1,323					1	1			
	16:00	1,282					1	1			
	17:00	1,417					1	1			
	18:00	1,508					1	1			
	19:00	1,471					1	1			
	20:00	1,500					1	1			
	21:00	1,438					1	1			
	22:00	1,355					1	1			
	23:00	1,176					1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 10 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 10 Δεκεμβρίου 2024	00:00	1,023					1	1			
	01:00	0,942					1	1			
	02:00	0,913					1	1			
	03:00	0,912					1	1			
	04:00	0,952					1	1			
	05:00	0,979					1	1			
	06:00	1,044					1	1			
	07:00	1,126					1	1			
	08:00	1,228	1				1				
	09:00	1,204	1				1				
	10:00	1,249	1				1				
	11:00	1,257	1				1				
	12:00	1,315	1				1				
	13:00	1,257	1				1				
	14:00	1,242	1				1				
	15:00	1,281	1				1				
	16:00	1,334					1	1			
	17:00	1,467					1	1			
	18:00	1,542					1	1			
	19:00	1,549					1	1			
	20:00	1,520					1	1			
	21:00	1,460					1	1			
	22:00	1,314					1	1			
	23:00	1,150					1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 11 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 11 Δεκεμβρίου 2024	00:00	1,015					1	1			
	01:00	0,939					1	1			
	02:00	0,911	1					1			
	03:00	0,952	1					1			
	04:00	0,998	1					1			
	05:00	0,958	1					1			
	06:00	1,016	1					1			
	07:00	1,118	1					1			
	08:00	1,189	1					1			
	09:00	1,244	1			1					
	10:00	1,230	1			1					
	11:00	1,229	1			1					
	12:00	1,240	1			1					
	13:00	1,179	1			1					
	14:00	1,124					1	1			
	15:00	1,123					1	1			
	16:00	1,167					1	1			
	17:00	1,348					1	1			
	18:00	1,450					1	1			
	19:00	1,523					1	1			
	20:00	1,470					1	1			
	21:00	1,434					1	1			
	22:00	1,326					1	1			
	23:00	1,147					1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 12 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 12 Δεκεμβρίου 2024	00:00	1,021					1	1			
	01:00	0,951					1	1			
	02:00	0,930					1	1			
	03:00	0,949					1	1			
	04:00	0,969					1	1			
	05:00	0,974					1	1			
	06:00	1,029					1	1			
	07:00	1,111					1	1			
	08:00	1,224					1	1			
	09:00	1,220				1	1				
	10:00	1,203				1	1				
	11:00	1,180				1	1				
	12:00	1,169				1	1				
	13:00	1,184					1	1			
	14:00	1,196					1	1			
	15:00	1,248					1	1			
	16:00	1,309					1	1			
	17:00	1,493					1	1			
	18:00	1,603					1	1			
	19:00	1,612					1	1			
	20:00	1,594					1	1			
	21:00	1,504					1	1			
	22:00	1,372					1	1			
	23:00	1,211					1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 13 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 13 Δεκεμβρίου 2024	00:00	1,089					1	1			
	01:00	1,014					1	1			
	02:00	0,951					1	1			
	03:00	0,981					1	1			
	04:00	1,012					1	1			
	05:00	1,009					1	1			
	06:00	1,112				1	1				
	07:00	1,167				1	1				
	08:00	1,262				1	1				
	09:00	1,265				1	1				
	10:00	1,242				1	1				
	11:00	1,227				1	1				
	12:00	1,234				1	1				
	13:00	1,211				1	1				
	14:00	1,230					1	1			
	15:00	1,360					1	1			
	16:00	1,358					1	1			
	17:00	1,487					1	1			
	18:00	1,566					1	1			
	19:00	1,599					1	1			
	20:00	1,707					1	1			
	21:00	1,640					1	1			
	22:00	1,471					1	1			
	23:00	1,304					1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 14 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 14 Δεκεμβρίου 2024	00:00	1,140					1	1			
	01:00	1,044					1	1			
	02:00	0,999					1	1			
	03:00	0,984					1	1			
	04:00	0,989					1	1			
	05:00	1,055					1	1			
	06:00	1,126				1	1				
	07:00	1,182				1	1				
	08:00	1,277				1	1				
	09:00	1,288				1	1				
	10:00	1,271				1	1				
	11:00	1,276				1	1				
	12:00	1,268				1	1				
	13:00	1,282				1	1				
	14:00	1,242					1	1			
	15:00	1,330					1	1			
	16:00	1,373					1	1			
	17:00	1,581					1	1			
	18:00	1,676					1	1			
	19:00	1,639					1	1			
	20:00	1,611					1	1			
	21:00	1,618					1	1			
	22:00	1,514					1	1			
	23:00	1,339					1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 15 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 15 Δεκεμβρίου 2024	00:00	1,174					1	1			
	01:00	1,074					1	1			
	02:00	1,022					1	1			
	03:00	1,004					1	1			
	04:00	1,012					1	1			
	05:00	1,042					1	1			
	06:00	1,094				1	1				
	07:00	1,166				1	1				
	08:00	1,257				1	1				
	09:00	1,320				1	1				
	10:00	1,376				1	1				
	11:00	1,406				1	1				
	12:00	1,437				1	1				
	13:00	1,468				1	1				
	14:00	1,447				1	1				
	15:00	1,419				1	1				
	16:00	1,497				1	1				
	17:00	1,646				1	1				1
	18:00	1,674				1	1				1
	19:00	1,619				1	1				1
	20:00	1,622				1	1				1
	21:00	1,515				1	1				1
	22:00	1,417				1	1				
	23:00	1,235				1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 16 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 16 Δεκεμβρίου 2024	00:00	1,094				1	1				
	01:00	0,999				1	1				
	02:00	0,967				1	1				
	03:00	0,951				1	1				
	04:00	0,989				1	1				
	05:00	1,033				1	1				
	06:00	1,128				1	1				
	07:00	1,190				1	1				
	08:00	1,311				1	1				
	09:00	1,317				1	1				
	10:00	1,320				1	1				
	11:00	1,301				1	1				
	12:00	1,276				1	1				
	13:00	1,252				1	1				
	14:00	1,253				1	1				
	15:00	1,352				1	1				
	16:00	1,403				1	1				
	17:00	1,590				1	1				
	18:00	1,704	1				1				
	19:00	1,719	1				1				
	20:00	1,711	1				1				
	21:00	1,653	1				1				
	22:00	1,498	1				1				
	23:00	1,334	1				1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 17 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 17 Δεκεμβρίου 2024	00:00	1,149	1				1				
	01:00	1,035	1				1				
	02:00	0,997	1				1				
	03:00	0,985	1				1				
	04:00	1,019	1				1				
	05:00	1,033	1				1				
	06:00	1,116	1				1				
	07:00	1,251	1				1				
	08:00	1,322	1				1				
	09:00	1,290	1				1				
	10:00	1,233				1	1				
	11:00	1,238				1	1				
	12:00	1,223				1	1				
	13:00	1,214				1	1				
	14:00	1,291				1	1				
	15:00	1,352				1	1				
	16:00	1,374				1	1				
	17:00	1,571				1	1				
	18:00	1,644				1	1				1
	19:00	1,698				1	1				1
	20:00	1,698				1	1				1
	21:00	1,641				1	1				1
	22:00	1,530				1	1				
	23:00	1,320				1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 18 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 18 Δεκεμβρίου 2024	00:00	1,172				1	1				
	01:00	1,080				1	1				
	02:00	1,023				1	1				
	03:00	1,007				1	1				
	04:00	1,042				1	1				
	05:00	1,048				1	1				
	06:00	1,164				1	1				
	07:00	1,304				1	1				
	08:00	1,326				1	1				
	09:00	1,315				1	1				
	10:00	1,291				1	1				
	11:00	1,318				1	1				
	12:00	1,327				1	1				
	13:00	1,608				1	1				
	14:00	1,916				1	1				1
	15:00	2,029				1	1				1
	16:00	2,138				1	1				1
	17:00	1,972				1	1				1
	18:00	1,834					1				1
	19:00	1,922					1				1
	20:00	1,835					1				1
	21:00	1,771					1				1
	22:00	1,612					1				1
	23:00	1,961				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 19 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 19 Δεκεμβρίου 2024	00:00	1,723				1	1				1
	01:00	1,536				1	1				1
	02:00	1,466				1	1				1
	03:00	1,438				1	1				1
	04:00	1,419				1	1				1
	05:00	1,462				1	1				1
	06:00	1,598				1	1				1
	07:00	1,915				1	1				1
	08:00	1,984				1	1				1
	09:00	1,968				1	1				1
	10:00	1,941				1	1				1
	11:00	1,925				1	1				1
	12:00	1,937				1	1				1
	13:00	1,939				1	1				1
	14:00	2,044				1	1				1
	15:00	2,202				1	1				1
	16:00	2,035				1	1				1
	17:00	2,100				1	1				1
	18:00	2,045				1	1				1
	19:00	2,056				1	1				1
	20:00	2,081				1	1				1
	21:00	2,072				1	1				1
	22:00	2,048				1	1				1
	23:00	2,003				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 20 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 20 Δεκεμβρίου 2024	00:00	1,712				1	1				1
	01:00	1,564				1	1				1
	02:00	1,498				1	1				1
	03:00	1,475				1	1				1
	04:00	1,506				1	1				1
	05:00	1,617				1	1				1
	06:00	1,772				1	1				1
	07:00	1,720				1	1				1
	08:00	1,923				1	1				1
	09:00	2,008				1	1				1
	10:00	2,097				1	1				1
	11:00	2,085				1	1				1
	12:00	2,146				1	1				1
	13:00	2,022				1	1				1
	14:00	1,903				1	1				1
	15:00	1,893				1	1				1
	16:00	1,991				1	1				1
	17:00	2,110				1	1				1
	18:00	2,004				1	1				1
	19:00	1,984				1	1				1
	20:00	2,116				1	1				1
	21:00	2,012				1	1				1
	22:00	1,920				1	1				1
	23:00	1,746				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 21 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 21 Δεκεμβρίου 2024	00:00	1,518					1				1
	01:00	1,371					1				1
	02:00	1,281					1				1
	03:00	1,227					1				1
	04:00	1,264					1				1
	05:00	1,300					1				1
	06:00	1,380					1				1
	07:00	1,547				1	1				1
	08:00	1,670				1	1				1
	09:00	1,931				1	1				1
	10:00	2,065				1	1				1
	11:00	2,158				1	1				1
	12:00	1,921				1	1				1
	13:00	2,271				1	1				1
	14:00	2,205				1	1				1
	15:00	2,194				1	1				1
	16:00	2,283				1	1				1
	17:00	2,298				1	1				1
	18:00	2,126				1	1				1
	19:00	2,092				1	1				1
	20:00	2,055				1	1				1
	21:00	1,951				1	1				1
	22:00	1,702				1	1				1
	23:00	1,428					1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 22 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 22 Δεκεμβρίου 2024	00:00	1,158					1				1
	01:00	0,984					1				1
	02:00	1,001					1				1
	03:00	0,986					1				1
	04:00	1,062					1				1
	05:00	1,086					1				1
	06:00	1,143					1				1
	07:00	1,258					1				1
	08:00	1,308					1				1
	09:00	1,351					1				1
	10:00	1,516					1				1
	11:00	2,075				1	1				1
	12:00	2,098				1	1				1
	13:00	2,131				1	1				1
	14:00	2,127				1	1				1
	15:00	2,117				1	1				1
	16:00	2,322				1	1				1
	17:00	2,542				1	1				1
	18:00	2,668				1	1				1
	19:00	2,254				1	1				1
	20:00	2,545				1	1				1
	21:00	2,417				1	1				1
	22:00	2,263				1	1				1
	23:00	1,983				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 23 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 23 Δεκεμβρίου 2024	00:00	1,705				1	1				1
	01:00	1,585				1	1				1
	02:00	1,528				1	1				1
	03:00	1,503				1	1				1
	04:00	1,509				1	1				1
	05:00	1,530				1	1				1
	06:00	1,639				1	1				1
	07:00	1,712				1	1				1
	08:00	2,043				1	1				1
	09:00	2,072				1	1				1
	10:00	1,995				1	1				1
	11:00	1,953				1	1				1
	12:00	1,974				1	1				1
	13:00	2,022				1	1				1
	14:00	2,012				1	1				1
	15:00	2,057				1	1				1
	16:00	2,121				1	1				1
	17:00	2,342				1	1				1
	18:00	2,483				1	1				1
	19:00	2,559				1	1				1
	20:00	2,548				1	1				1
	21:00	2,545				1	1				1
	22:00	2,277				1	1				1
	23:00	2,004				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 24 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 24 Δεκεμβρίου 2024	00:00	1,737				1	1				1
	01:00	1,563				1	1				1
	02:00	1,503				1	1				1
	03:00	1,471				1	1				1
	04:00	1,493				1	1				1
	05:00	1,490				1	1				1
	06:00	1,643				1	1				1
	07:00	1,823				1	1				1
	08:00	1,488				1	1				1
	09:00	2,262				1	1				1
	10:00	2,332				1	1				1
	11:00	2,324				1	1				1
	12:00	2,454				1	1				1
	13:00	2,105				1	1				1
	14:00	1,721					1				1
	15:00	2,100				1	1				1
	16:00	2,218				1	1				1
	17:00	2,387				1	1			1	1
	18:00	2,372				1	1			1	1
	19:00	2,323				1	1			1	1
	20:00	2,297				1	1				1
	21:00	2,037				1	1				1
	22:00	1,862				1	1				1
	23:00	2,074				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 25 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 25 Δεκεμβρίου 2024	00:00	2,062				1	1				1
	01:00	1,869				1	1				1
	02:00	1,744				1	1				1
	03:00	1,708				1	1				1
	04:00	1,748				1	1				1
	05:00	1,729				1	1				1
	06:00	1,743				1	1				1
	07:00	1,914				1	1				1
	08:00	2,261				1	1				1
	09:00	2,279				1	1				1
	10:00	2,158				1	1				1
	11:00	2,349				1	1				1
	12:00	2,212				1	1				1
	13:00	1,765				1	1				1
	14:00	1,493					1				1
	15:00	1,512					1				1
	16:00	1,584					1				1
	17:00	1,708					1				1
	18:00	2,009				1	1				1
	19:00	2,099				1	1				1
	20:00	2,064				1	1				1
	21:00	1,939				1	1				1
	22:00	1,909				1	1				1
	23:00	1,933				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 26 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 26 Δεκεμβρίου 2024	00:00	1,975				1	1				1
	01:00	1,817				1	1				1
	02:00	1,739				1	1				1
	03:00	1,693				1	1				1
	04:00	1,718				1	1				1
	05:00	1,767				1	1				1
	06:00	1,729				1	1				1
	07:00	1,864				1	1				1
	08:00	2,138				1	1				1
	09:00	2,282				1	1				1
	10:00	2,434				1	1				1
	11:00	2,301				1	1				1
	12:00	1,697					1				1
	13:00	1,697					1				1
	14:00	1,750					1				1
	15:00	1,730					1				1
	16:00	1,819					1				1
	17:00	2,319				1	1			1	1
	18:00	2,227				1	1			1	1
	19:00	1,993				1	1				1
	20:00	1,719					1				1
	21:00	1,664					1				1
	22:00	1,526					1				1
	23:00	1,302					1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 27 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Α Σ Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 27 Δεκεμβρίου 2024	00:00	1,010					1				1
	01:00	0,893									1
	02:00	0,856									1
	03:00	0,842									1
	04:00	0,861									1
	05:00	0,879									1
	06:00	1,031				1					1
	07:00	1,030				1					1
	08:00	1,208				1					1
	09:00	1,271				1					1
	10:00	1,762				1	1				1
	11:00	1,735				1	1				1
	12:00	1,775				1	1				1
	13:00	1,746				1	1				1
	14:00	1,722				1	1				1
	15:00	1,836				1	1				1
	16:00	2,003				1	1				1
	17:00	2,330				1	1				1
	18:00	2,431				1	1				1
	19:00	2,446				1	1				1
	20:00	2,631				1	1				1
	21:00	2,539				1	1				1
	22:00	2,311				1	1				1
	23:00	2,149				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 28 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 28 Δεκεμβρίου 2024	00:00	2,129				1	1				1
	01:00	1,972				1	1				1
	02:00	1,851				1	1				1
	03:00	1,818				1	1				1
	04:00	1,850				1	1				1
	05:00	1,844				1	1				1
	06:00	1,848				1	1				1
	07:00	2,082				1	1				1
	08:00	2,320				1	1				1
	09:00	2,197				1	1				1
	10:00	1,919				1	1				1
	11:00	2,078				1	1				1
	12:00	2,157				1	1				1
	13:00	2,269				1	1				1
	14:00	2,317				1	1				1
	15:00	2,305				1	1				1
	16:00	2,262				1	1				1
	17:00	2,518				1	1				1
	18:00	2,602				1	1				1
	19:00	2,636				1	1				1
	20:00	2,598				1	1				1
	21:00	2,471				1	1				1
	22:00	2,308				1	1				1
	23:00	2,095				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 29 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 29 Δεκεμβρίου 2024	00:00	1,895				1	1				1
	01:00	1,697				1	1				1
	02:00	1,608				1	1				1
	03:00	1,538				1	1				1
	04:00	1,554				1	1				1
	05:00	1,532				1	1				1
	06:00	1,620				1	1				1
	07:00	1,691				1	1				1
	08:00	1,906				1	1				1
	09:00	2,129				1	1				1
	10:00	2,312				1	1				1
	11:00	2,495				1	1				1
	12:00	2,546				1	1				1
	13:00	2,642				1	1				1
	14:00	2,241				1	1				1
	15:00	2,342				1	1				1
	16:00	2,396				1	1				1
	17:00	2,670				1	1				1
	18:00	2,740				1	1			1	1
	19:00	2,772				1	1			1	1
	20:00	2,733				1	1			1	1
	21:00	2,517				1	1				1
	22:00	2,319				1	1				1
	23:00	2,086				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 30 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 30 Δεκεμβρίου 2024	00:00	1,835				1	1				1
	01:00	1,779				1	1				1
	02:00	1,695				1	1				1
	03:00	1,662				1	1				1
	04:00	1,655				1	1				1
	05:00	1,708				1	1				1
	06:00	1,794				1	1				1
	07:00	1,980				1	1				1
	08:00	2,014				1	1				1
	09:00	2,083				1	1				1
	10:00	2,268				1	1				1
	11:00	2,219				1	1				1
	12:00	2,368				1	1				1
	13:00	2,474				1	1				1
	14:00	2,513				1	1				1
	15:00	2,270				1	1				1
	16:00	2,195				1	1				1
	17:00	2,356				1	1				1
	18:00	2,517				1	1			1	1
	19:00	2,424				1	1			1	1
	20:00	2,466				1	1			1	1
	21:00	2,316				1	1			1	1
	22:00	2,497				1	1				1
	23:00	2,186				1	1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης