

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 1 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η ε ρ ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Πέμπτη, 1 Μαΐου 2025	00:00	31,69			1	1		1	1	1			9
	01:00	30,21			1	1		1	1	1			6
	02:00	28,83			1	1		1	1	1			6
	03:00	27,80			1	1		1	1	1			6
	04:00	27,26			1	1		1	1	1			13
	05:00	27,65			1	1		1	1	1			11
	06:00	28,68			1	1		1	1	1			8
	07:00	31,67			1	1		1	1	1			10
	08:00	34,86			1	1		1	1	1			12
	09:00	37,76			1	1		1	1	1			15
	10:00	40,59			1	1		1	1	1			18
	11:00	41,91			1	1		1	1	1			17
	12:00	42,18			1	1		1	1	1			18
	13:00	42,82			1	1		1	1	1			19
	14:00	42,24			1	1		1	1	1			19
	15:00	40,78			1	1		1	1	1			19
	16:00	39,81			1	1		1	1	1			19
	17:00	40,04			1	1		1	1	1			19
	18:00	40,64			1	1		1	1	1			19
	19:00	41,61			1	1		1	1	1			21
	20:00	42,60			1	1		1	1	1			21
	21:00	41,76			1	1		1	1	1			17
	22:00	39,19			1	1		1	1	1			15
	23:00	35,18			1	1		1	1	1			12

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη. Μισθωμένη ισχύς 10MW. Οι Α/Σ 31 και 32 μπορούν να ενταχθούν σε έκτακτη ανάγκη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης