

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Παρασκευή, 2 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Παρασκευή, 2 Μαΐου 2025	00:00	32,58			1	1		1	1	1			10
	01:00	30,63			1	1		1	1	1			6
	02:00	28,95			1	1		1	1	1			5
	03:00	28,36			1	1		1	1	1			4
	04:00	27,97			1	1		1	1	1			4
	05:00	27,99			1	1		1	1	1			4
	06:00	29,56			1	1		1	1	1			5
	07:00	33,12			1	1		1	1	1			11
	08:00	35,72			1	1		1	1	1			13
	09:00	37,97			1	1		1	1	1			15
	10:00	38,57			1	1		1	1	1			16
	11:00	38,08			1	1		1	1	1			15
	12:00	37,16			1	1		1	1	1			15
	13:00	36,80			1	1		1	1	1			13
	14:00	35,95			1	1		1	1	1			13
	15:00	35,65			1	1		1	1	1			12
	16:00	36,56			1	1		1	1	1			14
	17:00	38,67			1	1		1	1	1			14
	18:00	38,41			1	1		1	1	1			16
	19:00	39,30			1	1		1	1	1			16
	20:00	42,31			1	1		1	1	1			19
	21:00	41,49			1	1		1	1	1			15
	22:00	38,87			1	1		1	1	1			15
	23:00	35,27			1	1		1	1	1			11

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη. Οι Α/Σ 31 και 32 μπορούν να ενταχθούν σε έκτακτη ανάγκη. Μισθωμένη ισχύς 10MW.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης