

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Σάββατο, 3 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Σάββατο, 3 Μαΐου 2025	00:00	32,54			1	1		1	1	1			9
	01:00	30,67			1	1		1	1	1			5
	02:00	29,66			1	1		1	1	1			5
	03:00	29,03			1	1		1	1	1			5
	04:00	28,59			1	1		1	1	1			4
	05:00	29,03			1	1		1	1	1			3
	06:00	29,69			1	1		1	1	1			2
	07:00	32,69			1	1		1	1	1			8
	08:00	35,06			1	1		1	1	1			9
	09:00	36,46			1	1		1	1	1			10
	10:00	37,05			1	1		1	1	1			12
	11:00	37,34			1	1		1	1	1			12
	12:00	37,15			1	1		1	1	1			11
	13:00	36,86			1	1		1	1	1			11
	14:00	35,88			1	1		1	1	1			11
	15:00	35,08			1	1		1	1	1			11
	16:00	34,62			1	1		1	1	1			11
	17:00	35,67			1	1		1	1	1			16
	18:00	36,43			1	1		1	1	1			16
	19:00	37,74			1	1		1	1	1			16
	20:00	41,17			1	1		1	1	1			16
	21:00	40,92			1	1		1	1	1			14
	22:00	38,25			1	1		1	1	1			14
	23:00	35,13			1	1		1	1	1			10

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη. Οι Α/Σ 31 και 32 μπορούν να ενταχθούν σε έκτακτη ανάγκη. Μισθωμένη ισχύς 10MW.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης