

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 4 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Κυριακή, 4 Μαΐου 2025	00:00	32,70			1	1		1	1	1			10
	01:00	30,81			1	1		1	1	1			6
	02:00	29,82			1	1		1	1	1			6
	03:00	28,91			1	1		1	1	1			4
	04:00	28,30			1	1		1	1	1			4
	05:00	28,05			1	1		1	1	1			2
	06:00	28,62			1	1		1	1	1			4
	07:00	31,13			1	1		1	1	1			8
	08:00	33,64			1	1		1	1	1			8
	09:00	34,90			1	1		1	1	1			10
	10:00	35,47			1	1		1	1	1			11
	11:00	35,65			1	1		1	1	1			10
	12:00	35,94			1	1		1	1	1			10
	13:00	35,76			1	1		1	1	1			11
	14:00	34,82			1	1		1	1	1			10
	15:00	33,74			1	1		1	1	1			9
	16:00	32,96			1	1		1	1	1			9
	17:00	33,52			1	1		1	1	1			9
	18:00	34,86			1	1		1	1	1			11
	19:00	36,23			1	1		1	1	1			11
	20:00	38,33			1	1		1	1	1			14
	21:00	38,76			1	1		1	1	1			11
	22:00	36,93			1	1		1	1	1			9
	23:00	34,28			1	1		1	1	1			9

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη. Οι Α/Σ 31 και 32 μπορούν να ενταχθούν σε έκτακτη ανάγκη. Μισθωμένη ισχύς 10MW.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης