

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 5 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Δευτέρα, 5 Μαΐου 2025	00:00	31,75			1	1		1	1	1			9
	01:00	29,82			1	1		1	1	1			4
	02:00	28,57			1	1		1	1	1			4
	03:00	28,20			1	1		1	1	1			3
	04:00	28,04			1	1		1	1	1			3
	05:00	28,17			1	1		1	1	1			12
	06:00	29,11			1	1		1	1	1			8
	07:00	32,67			1	1		1	1	1			10
	08:00	34,84			1	1		1	1	1			12
	09:00	36,03			1	1		1	1	1			12
	10:00	36,56			1	1		1	1	1			13
	11:00	36,80			1	1		1	1	1			13
	12:00	36,88			1	1		1	1	1			13
	13:00	36,91			1	1		1	1	1			13
	14:00	37,10			1	1		1	1	1			14
	15:00	36,91			1	1		1	1	1			14
	16:00	36,50			1	1		1	1	1			14
	17:00	36,50			1	1		1	1	1			14
	18:00	37,56			1	1		1	1	1			14
	19:00	38,67			1	1		1	1	1			15
	20:00	40,88			1	1		1	1	1			16
	21:00	39,93			1	1		1	1	1			15
	22:00	37,71			1	1		1	1	1			12
	23:00	34,36			1	1		1	1	1			10

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη. Μισθωμένη ισχύς 10MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης