

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 6 Μαρτίου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η ε ρ ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	Z (x1000)
Πέμπτη, 6 Μαρτίου 2025	00:00	15,19	1		1	1		1					
	01:00	14,24	1		1	1		1					
	02:00	13,75	1		1	1		1					
	03:00	13,33	1		1	1		1					
	04:00	13,33	1		1	1		1					
	05:00	13,39	1		1	1		1					
	06:00	13,12	1		1	1		1					
	07:00	13,86	1		1	1		1					
	08:00	8,01			1	1		1					4
	09:00	9,26	1		1	1		1					4
	10:00	14,49	1		1	1		1					
	11:00	15,02	1		1	1		1					
	12:00	15,68	1		1	1		1					
	13:00	15,35	1		1	1		1					
	14:00	15,68	1		1	1		1					
	15:00	15,65	1		1	1		1	1				
	16:00	16,12	1		1	1		1	1				
	17:00	17,00	1		1	1		1	1				
	18:00	19,05	1			1		1	1				
	19:00	21,32	1			1		1	1				1
	20:00	20,77	1			1		1	1				1
	21:00	19,18	1			1		1	1				
	22:00	18,12	1			1		1	1				
	23:00	16,35	1			1		1	1				

Διαθεσιμότητα φορητών Η/Ζ 5,5MW λόγω βλαβών. Γενική Διακοπή στις 08:30, λόγω βλάβης στη G1.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης