

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 6 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Τρίτη, 6 Μαΐου 2025	00:00	31,82			1	1		1	1	1			9
	01:00	30,20			1	1		1	1	1			5
	02:00	28,87			1	1		1	1	1			4
	03:00	28,17			1	1		1	1	1			4
	04:00	15,08			1	1		1	1				
	05:00	22,29			1	1		1			1		17
	06:00	29,36			1	1		1			1		17
	07:00	32,07			1	1		1	1		1		14
	08:00	35,04			1	1		1	1		1		13
	09:00	36,45			1	1			1	1	1		13
	10:00	36,45			1	1			1	1	1		13
	11:00	36,57			1	1			1	1	1		13
	12:00	36,69			1	1			1	1	1		13
	13:00	37,47			1	1			1	1	1		13
	14:00	37,06			1	1			1	1	1		13
	15:00	35,75			1	1			1	1	1		9
	16:00	35,66			1	1		1	1	1	1		9
	17:00	35,78			1	1		1	1	1	1		9
	18:00	36,21			1	1		1	1	1	1		9
	19:00	38,04			1	1		1	1	1	1		9
	20:00	40,01			1	1		1	1	1	1		9
	21:00	39,93			1	1		1	1	1	1		11
	22:00	37,72			1	1		1	1	1	1		10
	23:00	33,70			1	1		1	1	1	1		5

Ένα φορητό H/Z βρίσκεται σε βλάβη. Μισθωμένη ισχύς 10MW. Μερική διακοπή στις 04:15, λόγω βλάβης στον Α/Σ 30.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης