

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τετάρτη, 7 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Τετάρτη, 7 Μαΐου 2025	00:00	31,54			1	1		1	1	1	1		5
	01:00	30,02			1	1		1	1	1	1		
	02:00	29,06			1	1		1	1	1	1		
	03:00	28,23			1	1		1	1	1	1		
	04:00	27,80			1	1		1	1	1	1		
	05:00	27,90			1	1		1	1	1	1		2
	06:00	29,13			1	1		1	1	1	1		8
	07:00	32,44			1	1		1	1	1	1		8
	08:00	34,90			1	1		1	1	1	1		9
	09:00	36,56			1	1		1	1	1	1		9
	10:00	37,73			1	1		1	1	1	1		10
	11:00	38,58			1	1		1	1	1	1		9
	12:00	38,53			1	1		1	1	1		1	9
	13:00	38,48			1	1		1	1	1		1	9
	14:00	37,74			1	1		1	1		1	1	9
	15:00	37,61			1	1		1	1		1	1	9
	16:00	37,38			1	1		1	1		1	1	9
	17:00	37,80			1	1		1	1		1	1	9
	18:00	38,38			1	1		1	1		1	1	9
	19:00	39,83			1	1		1	1		1	1	9
	20:00	41,06			1	1		1	1		1	1	9
	21:00	40,26			1	1		1	1		1	1	7
	22:00	36,61			1	1		1	1		1	1	7
	23:00	33,46			1	1		1	1		1	1	3

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη. Μισθωμένη ισχύς 10MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης