

ΗΣ ΘΗΡΑΣ			Απολογισμός Λειτουργίας		Πέμπτη, 8 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η ε ρ ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Πέμπτη, 8 Μαΐου 2025	00:00	30,47			1	1		1	1		1	1	
	01:00	28,85			1	1		1	1		1	1	
	02:00	27,91			1	1		1	1		1	1	
	03:00	27,23			1	1		1	1		1	1	
	04:00	26,44			1	1		1	1		1	1	
	05:00	27,46			1	1		1	1		1	1	
	06:00	28,91			1	1		1	1		1	1	
	07:00	32,21			1	1		1	1		1	1	
	08:00	34,50			1	1		1	1		1	1	
	09:00	36,12			1	1		1	1		1	1	1
	10:00	37,37			1	1		1	1		1	1	3
	11:00	37,54			1	1		1	1		1	1	2
	12:00	37,80			1	1		1	1		1	1	2
	13:00	38,09			1	1		1	1		1	1	2
	14:00	37,55			1	1		1	1		1	1	2
	15:00	36,75			1	1		1	1		1	1	2
	16:00	36,46			1	1		1	1		1	1	2
	17:00	36,96			1	1		1	1		1	1	2
	18:00	37,79			1	1		1	1		1	1	3
	19:00	38,03			1	1		1	1		1	1	3
	20:00	40,70			1	1		1	1		1	1	5
	21:00	39,20			1	1		1	1		1	1	5
	22:00	37,62			1	1		1	1		1	1	2
	23:00	33,75			1	1		1	1		1	1	

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη. Μισθωμένη ισχύς 10MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης