

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Παρασκευή, 9 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Παρασκευή, 9 Μαΐου 2025	00:00	31,23			1	1		1	1		1	1	
	01:00	29,75			1	1		1	1		1	1	
	02:00	28,77			1	1		1	1		1	1	
	03:00	28,40			1	1		1	1		1	1	
	04:00	28,28			1	1		1	1		1	1	
	05:00	28,88			1	1		1	1		1	1	
	06:00	29,53			1	1		1	1		1	1	
	07:00	32,98			1	1		1	1		1	1	3
	08:00	35,33			1			1	1		1	1	5
	09:00	36,47			1			1	1		1	1	5
	10:00	37,38			1			1	1		1	1	4
	11:00	37,77			1	1		1	1		1	1	4
	12:00	38,11			1	1		1	1		1	1	4
	13:00	37,93			1	1		1	1		1	1	5
	14:00	38,11			1	1		1	1		1	1	5
	15:00	37,14			1	1		1	1		1	1	4
	16:00	37,39			1	1		1	1		1	1	4
	17:00	37,48			1	1		1	1		1	1	4
	18:00	37,98			1	1		1	1		1	1	4
	19:00	39,15			1	1		1	1		1	1	4
	20:00	41,30			1	1		1	1		1	1	6
	21:00	39,95			1	1		1	1		1	1	5
	22:00	36,92			1	1		1	1		1	1	2
	23:00	32,90			1	1		1	1		1	1	

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη. Μισθωμένη ισχύς 10MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης