

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 10 Απριλίου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Πέμπτη, 10 Απριλίου 2025	00:00	26,08	1			1		1		1		1	5
	01:00	24,25	1			1		1		1		1	1
	02:00	23,66	1			1		1		1		1	1
	03:00	23,13	1			1		1		1		1	1
	04:00	22,48	1			1		1		1		1	1
	05:00	22,86	1			1		1		1		1	1
	06:00	23,92	1			1		1		1		1	1
	07:00	26,34	1			1		1		1		1	1
	08:00	26,90	1					1		1		1	2
	09:00	27,37	1					1		1		1	2
	10:00	28,15	1					1		1		1	2
	11:00	28,31	1			1		1		1		1	1
	12:00	28,30	1			1		1		1		1	1
	13:00	29,02	1			1		1		1		1	1
	14:00	28,83	1			1		1		1		1	1
	15:00	28,60	1			1		1		1		1	1
	16:00	28,97	1			1		1		1		1	1
	17:00	29,30	1			1		1		1		1	1
	18:00	30,00	1			1		1		1		1	6
	19:00	33,91	1			1		1		1		1	10
	20:00	35,43	1			1		1		1		1	10
	21:00	35,08	1			1		1		1		1	9
	22:00	33,03	1			1		1		1		1	6
	23:00	28,07	1			1		1		1		1	4

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη. Μισθωμένη ισχύς 10MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης