

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 12 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η ε ρ ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Δευτέρα, 12 Μαΐου 2025	00:00	31,57			1	1		1	1		1	1	
	01:00	30,15			1	1		1	1		1	1	
	02:00	29,31			1	1		1	1		1	1	
	03:00	28,66			1	1		1	1		1	1	
	04:00	28,15			1	1		1	1		1	1	
	05:00	28,13			1	1		1	1		1	1	
	06:00	29,15			1	1		1	1		1	1	
	07:00	33,00				1		1	1		1	1	3
	08:00	35,98				1		1	1		1	1	5
	09:00	37,53				1		1	1		1	1	5
	10:00	38,34				1		1	1		1	1	6
	11:00	38,66				1		1	1		1	1	6
	12:00	39,31				1		1	1		1	1	6
	13:00	38,21				1		1	1		1	1	3
	14:00	38,17			1	1		1	1		1	1	8
	15:00	38,41			1	1		1	1		1	1	8
	16:00	37,50			1	1		1	1		1	1	8
	17:00	38,35			1	1		1	1		1	1	8
	18:00	39,78			1	1		1	1		1	1	7
	19:00	40,22			1	1		1	1		1	1	7
	20:00	41,04			1	1		1	1		1	1	6
	21:00	39,82			1	1		1	1		1	1	4
	22:00	37,45			1	1		1	1		1	1	4
	23:00	34,21			1	1		1	1		1	1	

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη. Μισθωμένη ισχύς 10MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης