

ΗΣ ΘΗΡΑΣ			Απολογισμός Λειτουργίας		Πέμπτη, 13 Μαρτίου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	Z (x16)
Πέμπτη, 13 Μαρτίου 2025	00:00	13,28			1	1				1			
	01:00	13,16			1	1				1			
	02:00	12,81			1	1				1			
	03:00	12,62			1	1				1			
	04:00	12,74			1	1				1			
	05:00	12,85			1	1				1			
	06:00	14,17			1	1				1			1
	07:00	14,27			1	1				1		1	
	08:00	15,30			1	1				1		1	
	09:00	15,93			1	1				1		1	
	10:00	16,23			1	1				1		1	
	11:00	16,24			1	1				1		1	
	12:00	16,41			1	1				1		1	
	13:00	16,65			1	1				1		1	
	14:00	16,45			1	1				1		1	
	15:00	16,39			1	1		1		1		1	
	16:00	16,59			1	1		1		1		1	
	17:00	16,76			1	1		1		1		1	
	18:00	18,07			1	1		1		1			2
	19:00	20,13			1	1		1		1			2
	20:00	20,13			1	1		1		1			2
	21:00	18,39			1	1		1		1			
	22:00	17,50			1	1		1		1			
	23:00	15,99			1	1		1		1			

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης