

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 13 Απριλίου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Κυριακή, 13 Απριλίου 2025	00:00	25,96	1		1	1		1		1		1	
	01:00	24,45	1		1	1		1		1		1	
	02:00	24,50	1		1	1		1		1		1	
	03:00	23,74	1		1	1		1		1		1	
	04:00	23,37	1		1	1		1		1		1	
	05:00	23,57	1		1	1		1		1		1	
	06:00	24,52	1		1	1		1		1		1	
	07:00	26,03	1		1	1		1		1		1	
	08:00	27,45	1		1	1		1		1		1	1
	09:00	28,27	1		1	1		1		1		1	1
	10:00	29,33	1		1	1		1		1		1	3
	11:00	29,30	1		1	1		1		1		1	4
	12:00	29,01	1		1	1		1		1		1	2
	13:00	29,52	1		1	1		1		1		1	2
	14:00	29,47	1		1	1		1		1		1	
	15:00	28,63	1		1	1		1		1		1	
	16:00	28,15	1		1	1		1		1		1	
	17:00	29,08	1		1	1		1		1		1	
	18:00	29,97	1		1	1		1		1		1	
	19:00	32,20	1		1	1		1		1		1	
	20:00	34,70	1		1	1		1		1		1	3
	21:00	34,98	1		1	1		1		1		1	2
	22:00	33,63	1		1	1		1		1		1	2
	23:00	29,74	1		1	1		1		1		1	

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη. Μισθωμένη ισχύς 10MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης