

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 14 Απριλίου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Δευτέρα, 14 Απριλίου 2025	00:00	26,07	1		1	1		1		1		1	
	01:00	25,11	1		1	1		1		1		1	
	02:00	24,49	1		1	1		1		1		1	
	03:00	23,19	1		1	1		1		1		1	
	04:00	22,90	1		1	1		1		1		1	
	05:00	23,24	1		1	1		1		1		1	
	06:00	24,05	1		1	1		1		1		1	
	07:00	26,23	1		1	1		1		1		1	
	08:00	28,01	1		1	1		1		1		1	
	09:00	28,95	1			1		1		1		1	
	10:00	29,15	1			1		1		1		1	
	11:00	29,20	1			1		1		1		1	
	12:00	28,82	1			1		1		1		1	
	13:00	29,42	1			1		1		1		1	
	14:00	29,15	1			1		1		1		1	
	15:00	28,05	1			1		1		1		1	
	16:00	28,37	1			1		1		1		1	
	17:00	28,73	1			1		1		1		1	
	18:00	30,13	1			1		1		1		1	3
	19:00	31,44	1			1		1		1		1	4
	20:00	35,72	1			1		1		1		1	6
	21:00	33,75	1			1		1		1		1	6
	22:00	30,51	1			1		1		1		1	4
	23:00	28,16	1			1		1		1		1	3

Ένα φορητό Η/Ζ βρίσκεται σε βλάβη. Μισθωμένη ισχύς 10MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης