

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 17 Ιουνίου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Τρίτη, 17 Ιουνίου 2025	00:00	38,18			1	1	1	1	1		1	1	
	01:00	36,14			1	1	1	1	1		1	1	
	02:00	34,32			1	1	1	1	1		1	1	
	03:00	33,30			1	1	1	1	1		1	1	
	04:00	32,83			1	1	1	1	1		1	1	
	05:00	32,96			1	1	1	1	1		1	1	
	06:00	33,62			1	1	1	1	1		1	1	
	07:00	37,56			1	1	1	1	1		1	1	
	08:00	41,27			1	1	1	1	1		1	1	3
	09:00	43,37			1	1	1	1	1		1	1	7
	10:00	45,22			1	1	1	1	1		1	1	8
	11:00	45,60			1	1	1	1	1		1	1	8
	12:00	46,87			1	1	1	1	1		1	1	8
	13:00	47,17			1	1	1	1	1		1	1	9
	14:00	46,41			1	1	1	1	1		1	1	9
	15:00	46,05			1	1	1	1	1		1	1	9
	16:00	46,48		1	1	1		1	1		1	1	9
	17:00	46,01		1	1	1		1	1		1	1	7
	18:00	47,03		1	1	1		1	1		1	1	7
	19:00	47,01		1	1	1		1	1		1	1	7
	20:00	47,40		1	1	1		1	1		1	1	7
	21:00	46,54		1	1	1		1	1		1	1	7
	22:00	44,99		1	1	1		1	1		1	1	4
	23:00	40,70		1	1	1		1	1		1	1	

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη. Μισθωμένη ισχύς 10MW. Οι Α/Σ 31 και 32 βρίσκονται σε δοκιμαστική λειτουργία.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης