

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 20 Μαρτίου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	Z (x100)
Πέμπτη, 20 Μαρτίου 2025	00:00	16,99			1	1		1		1			
	01:00	16,28			1	1		1		1			
	02:00	15,99			1	1		1		1			
	03:00	15,48			1	1		1		1			
	04:00	15,58			1	1		1		1			
	05:00	15,58			1	1		1		1			
	06:00	16,31			1	1		1		1			
	07:00	18,36			1	1		1		1			
	08:00	19,52			1	1		1		1			
	09:00	18,51			1	1		1		1			
	10:00	18,33	1		1	1		1					11
	11:00	20,42	1		1	1		1					11
	12:00	19,79	1		1	1		1					11
	13:00	19,86	1		1	1		1					11
	14:00	19,96	1		1	1		1		1			4
	15:00	20,39	1		1	1		1		1			5
	16:00	21,35	1		1	1		1					11
	17:00	22,50	1		1	1		1					11
	18:00	23,07	1		1	1		1					11
	19:00	23,87	1		1	1		1					13
	20:00	23,64	1		1	1		1					13
	21:00	22,08	1		1	1		1		1			11
	22:00	20,06	1		1	1		1		1			4
	23:00	18,36	1		1	1		1		1			3

Μερική διακοπή στις 09:50, λόγω βλάβης στο δίκτυο. Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης