

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 22 Απριλίου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Τρίτη, 22 Απριλίου 2025	00:00	25,77	1			1		1		1		1	
	01:00	24,08	1			1		1		1		1	
	02:00	23,33	1			1		1		1		1	
	03:00	22,94	1			1		1		1		1	
	04:00	22,85	1			1		1		1		1	
	05:00	23,00	1			1		1		1		1	
	06:00	23,82	1			1		1		1		1	
	07:00	26,50	1			1		1		1		1	5
	08:00	28,61	1			1		1		1		1	5
	09:00	30,67	1			1		1		1		1	8
	10:00	32,62	1			1		1		1		1	9
	11:00	34,16	1			1		1		1		1	11
	12:00	34,08	1			1		1		1		1	12
	13:00	34,93	1			1		1		1		1	12
	14:00	34,90	1			1		1		1		1	13
	15:00	33,93	1			1		1		1		1	13
	16:00	33,50	1			1		1		1		1	11
	17:00	33,57	1			1		1		1		1	11
	18:00	34,19	1		1	1		1		1		1	11
	19:00	34,53	1		1	1		1		1		1	9
	20:00	36,05	1		1	1		1		1		1	9
	21:00	35,23	1		1	1		1		1		1	8
	22:00	33,32	1		1	1		1		1		1	5
	23:00	29,16	1		1	1		1		1		1	2

Έξι φορητά Η/Ζ βρίσκονται σε βλάβη. Μισθωμένη ισχύς 10MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης