

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τετάρτη, 23 Απριλίου 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ημερήσιο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Τετάρτη, 23 Απριλίου 2025	00:00	26,95	1		1	1		1		1		1	
	01:00	25,57	1		1	1		1		1		1	
	02:00	24,83	1		1	1		1		1		1	
	03:00	24,14	1		1	1		1		1		1	
	04:00	23,94	1		1	1		1		1		1	
	05:00	24,32	1		1	1		1		1		1	
	06:00	25,30	1		1	1		1		1		1	
	07:00	27,85	1		1	1		1		1		1	2
	08:00	29,94	1		1	1		1		1		1	11
	09:00	31,32	1			1		1		1		1	12
	10:00	32,14	1			1		1		1		1	12
	11:00	31,89	1			1		1		1		1	12
	12:00	31,75	1			1		1		1		1	11
	13:00	32,05	1			1		1		1	1	1	11
	14:00	31,70	1			1		1		1	1	1	10
	15:00	30,38	1			1		1		1	1	1	9
	16:00	30,09	1			1		1		1	1	1	8
	17:00	31,75	1			1		1		1	1	1	8
	18:00	31,87	1			1		1		1	1	1	8
	19:00	32,76	1			1		1		1	1	1	8
	20:00	35,30	1			1		1		1	1	1	9
	21:00	34,88	1			1		1		1	1	1	8
	22:00	32,68	1			1		1		1	1	1	6
	23:00	29,33	1		1	1		1		1	1	1	

Έξι φορητά Η/Ζ βρίσκονται σε βλάβη. Μισθωμένη ισχύς 10MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης