

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας				Παρασκευή, 31 Ιανουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)				7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	12,000	12,000	1,100
Η ε ρ ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Παρασκευή, 31 Ιανουαρίου 2025	00:00	15,03	15,03	1		1			1		1			
	01:00	13,85	13,85	1		1			1		1			
	02:00	12,78	12,78	1		1			1					
	03:00	12,57	12,57	1		1			1					
	04:00	12,77	12,77	1		1			1					
	05:00	12,75	12,75	1		1			1					1
	06:00	13,98	13,98	1		1			1					2
	07:00	15,09	15,09	1		1			1					3
	08:00	15,16	15,16	1		1			1				1	
	09:00	14,91	14,91	1		1			1				1	
	10:00	14,67	14,67	1		1			1				1	
	11:00	14,47	14,47	1		1			1				1	
	12:00	14,63	14,63	1		1			1				1	
	13:00	14,78	14,78	1		1			1				1	
	14:00	15,02	15,02	1		1			1				1	
	15:00	15,33	15,33	1		1			1				1	
	16:00	16,05	16,05	1		1			1				1	
	17:00	16,58	16,58	1		1			1				1	
	18:00	18,47	18,47	1		1			1				1	
	19:00	19,49	19,49	1		1			1		1			
	20:00	20,10	20,10	1		1			1		1			
	21:00	19,13	19,13	1		1			1		1			
	22:00	17,34	17,34	1		1			1		1			
	23:00	15,75	15,75	1		1			1		1			

Διαθεσιμότητα φορητών Η/Ζ 5,5MW λόγω βλαβών.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης