

ΗΣ ΚΩ-ΚΑΛΥΜΝΟΥ			Απολογισμός Λειτουργίας										Παρασκευή, 9 Μαΐου 2025											
Αποδιδόμενη Ισχύς (MW)						9,000	11,000	11,000	11,000	16,000	16,000	11,000	11,500	11,500	33,000	1,500	1,800	1,800	5,880	5,880	5,880	8,250		
Α	Ρ	Σ	Ρ	Σ	Ρ	ΑΣΠ Κω										ΑΣΠ Καλύμνου						Εντολή περιορισμού των Αιολικών Πάρκων (MW)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (MW)	
						G1	G2	G3	G4	G5	G6	A/Σ G7	A/Σ G32	A/Σ G33	A/Σ G34	MTU 9-11	G1	G2	G3	G4	G5			G6
Παρασκευή, 9 Μαΐου 2025						1	1	1	1		1								1				9,14	8,85
	00:00	41,99	36,61	5,35	0,03						1								1				10,21	10,38
	01:00	39,06	33,64	5,42	0,00						1								1				10,61	10,56
	02:00	38,13	31,77	6,22	0,14						1								1				9,31	9,23
	03:00	36,84	30,34	6,43	0,07						1								1				8,91	8,94
	04:00	36,70	30,45	6,24	0,00						1								1				10,54	10,64
	05:00	38,35	32,05	6,29	0,00						1								1				13,28	13,31
	06:00	41,50	36,36	5,14	0,00						1								1				13,72	12,65
	07:00	46,06	40,50	5,56	0,00						1								1		1		12,18	12,84
	08:00	49,73	46,63	3,10	0,01	1	1	1	1	1	1								1			1	14,80	14,87
	09:00	51,87	44,41	7,45	0,01	1	1	1	1	1	1								1			1	15,05	14,86
	10:00	51,95	43,69	8,06	0,20	1	1	1	1	1	1								1			1	13,47	13,52
	11:00	50,52	43,47	6,85	0,20	1	1	1	1	1	1								1			1	15,12	15,20
	12:00	52,30	46,13	5,97	0,20	1	1	1	1	1	1								1			1	14,58	14,55
	13:00	51,60	45,65	5,74	0,21	1	1	1	1	1	1								1			1	14,63	14,87
	14:00	51,93	45,57	6,15	0,21	1	1	1	1	1	1								1			1	13,13	13,03
	15:00	49,94	43,74	5,99	0,20	1	1	1	1	1	1								1			1	11,93	11,89
	16:00	49,01	40,89	7,91	0,21	1	1	1	1	1	1								1			1	15,19	15,26
	17:00	52,57	43,15	9,21	0,21	1	1	1	1	1	1								1			1	16,10	16,10
	18:00	56,77	46,59	9,98	0,21	1	1	1	1	1	1								1			1	16,10	16,10
	19:00	59,63	49,67	9,96	0,01	1	1	1	1	1	1								1			1	16,10	16,10
	20:00	62,22	50,46	11,72	0,04	1	1	1	1	1	1								1			1	16,10	16,10
	21:00	58,83	46,89	11,58	0,36	1	1	1	1	1	1								1			1	16,10	16,10
	22:00	52,62	42,65	9,82	0,15	1	1	1	1	1	1								1			1	15,27	15,07
23:00	47,31	36,89	10,41	0,01	1	1	1	1	1	1								1				13,29	13,28	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης