

ΗΣ ΚΩ-ΚΑΛΥΜΝΟΥ			Απολογισμός Λειτουργίας										Παρασκευή, 16 Μαΐου 2025													
Αποδιδόμενη Ισχύς (MW)						9,000	11,000	11,000	11,000	16,000	16,000	11,000	11,500	11,500	33,000	1,500	1,800	1,800	5,880	5,880	5,880	8,250				
Α	Ρ	Ε	Τ	Η	Μ	ΑΣΠ Κω										ΑΣΠ Καλύμνου						Εντολή περιορισμού των Αιολικών Πάρκων (MW)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (MW)			
						G1	G2	G3	G4	G5	G6	A/Σ G7	A/Σ G32	A/Σ G33	A/Σ G34	MTU 9-11	G1	G2	G3	G4	G5			G6		
Παρασκευή, 16 Μαΐου 2025						00:00	40,87	39,71	1,15	0,00			1							1			8,14	8,40		
						01:00	38,15	36,64	1,51	0,00			1		1	1				1			7,90	7,94		
						02:00	37,13	35,28	1,85	0,00			1		1	1				1			6,77	6,68		
						03:00	36,62	35,09	1,53	0,00			1		1	1				1			6,25	6,25		
						04:00	36,75	31,52	4,96	0,28			1		1	1	1			1			6,30	6,42		
						05:00	38,98	31,74	6,79	0,46			1		1	1	1			1			8,56	8,85		
						06:00	42,48	32,26	9,70	0,51			1		1	1	1			1			11,87	11,88		
						07:00	48,86	35,75	12,62	0,49			1		1	1	1			1			15,97	16,07		
						08:00	53,56	41,38	11,66	0,52			1		1	1	1			1		1	16,10	16,10		
						09:00	54,44	44,30	9,38	0,76			1		1	1	1			1		1	16,10	16,10		
						10:00	53,83	41,04	12,08	0,71			1		1	1	1			1		1	16,10	16,10		
						11:00	51,58	38,14	12,86	0,59			1		1	1	1			1		1	16,10	16,10		
						12:00	51,02	37,78	12,56	0,69			1		1	1	1			1		1	16,10	16,10		
						13:00	51,11	37,92	12,39	0,80			1		1	1	1			1		1	16,10	16,10		
						14:00	49,65	38,15	11,04	0,46			1		1	1	1			1		1	15,77	15,59		
						15:00	46,95	36,70	9,93	0,32			1		1	1	1			1		1	13,87	13,59		
						16:00	43,89	34,91	8,68	0,30			1		1	1	1			1		1	11,02	10,93		
						17:00	49,95	40,56	8,93	0,45			1		1	1	1			1		1	13,31	13,52		
						18:00	56,73	44,35	11,84	0,54	1	1		1	1	1	1			1		1	16,10	16,10		
						19:00	58,95	46,01	12,50	0,43	1	1	1		1	1	1			1		1	16,09	16,07		
						20:00	61,48	48,35	12,59	0,54	1	1	1		1	1	1			1		1	16,10	16,10		
						21:00	58,83	45,65	12,64	0,55	1	1	1		1	1	1			1		1	16,10	16,10		
						22:00	52,18	40,11	11,65	0,42	1	1	1		1	1	1			1		1	13,85	13,50		
						23:00	46,44	34,43	11,70	0,31		1	1		1	1	1				1		13,74	14,27		

Το διάστημα από 14:50 έως 19:30 πραγματοποιήθηκαν προγραμματισμένες εργασίες στο δίκτυο. Μερική διακοπή στις 16:10, λόγω βλάβης στο δίκτυο.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης