

ΗΣ ΚΩ-ΚΑΛΥΜΝΟΥ			Απολογισμός Λειτουργίας										Τετάρτη, 21 Μαΐου 2025													
			Αποδιδόμενη Ισχύς (MW)				9,000	11,000	11,000	11,000	16,000	16,000	11,000	11,500	11,500	33,000	1,500	1,800	1,800	5,880	5,880	5,880	8,250			
Α	Χ	Ε	Σ	Τ	Ε	ΑΣΠ Κω										ΑΣΠ Καλύμνου						Εντολή περιορισμού των Αιολικών Πάρκων (MW)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (MW)			
						G1	G2	G3	G4	G5	G6	A/Σ G7	A/Σ G32	A/Σ G33	A/Σ G34	MTU 9-11	G1	G2	G3	G4	G5			G6		
Τετάρτη, 21 Μαΐου 2025		00:00	43,10	39,14	3,95	0,01				1	1	1									1		1	9,56	9,53	
		01:00	40,48	35,96	4,52	0,01				1	1	1	1								1			10,24	10,11	
		02:00	38,51	34,48	4,03	0,01				1	1	1	1								1			8,18	8,15	
		03:00	38,22	34,31	3,91	0,01				1	1	1	1								1			7,85	7,83	
		04:00	38,36	33,42	4,94	0,01				1	1	1	1								1			7,97	8,00	
		05:00	39,93	33,81	6,12	0,01				1	1	1	1								1			9,53	9,71	
		06:00	42,49	36,37	6,11	0,01				1	1	1	1								1			11,96	11,83	
		07:00	49,32	44,20	4,92	0,20				1	1	1	1								1		1	15,91	16,01	
		08:00	52,50	48,90	3,40	0,21				1	1	1	1								1		1	16,06	16,10	
		09:00	54,74	52,09	2,45	0,21	1	1		1	1	1	1								1		1	15,51	15,29	
		10:00	54,10	51,78	2,12	0,21	1	1	1	1	1	1	1								1		1	14,30	14,22	
		11:00	52,94	51,04	1,69	0,21	1	1		1	1	1	1								1		1	13,07	13,06	
		12:00	53,75	51,12	2,43	0,21	1	1		1	1	1	1								1		1	14,00	13,99	
		13:00	53,76	51,83	1,73	0,21	1	1	1	1	1	1	1								1		1	14,00	13,94	
		14:00	52,29	50,64	1,45	0,21	1	1		1	1	1	1								1		1	12,58	12,34	
		15:00	50,06	48,22	1,62	0,21	1	1		1	1	1	1								1		1	10,31	10,20	
		16:00	50,62	48,73	1,67	0,21	1	1		1	1	1	1								1		1	10,73	10,77	
		17:00	53,75	50,65	2,89	0,21	1	1		1	1	1	1								1		1	13,72	13,70	
		18:00	58,00	53,50	4,29	0,21	1	1		1	1	1	1			1					1		1	16,06	16,09	
		19:00	61,04	56,88	3,95	0,20	1	1		1	1	1	1								1		1	16,10	16,10	
		20:00	63,30	59,88	3,41	0,01	1	1		1	1	1	1			1					1		1	16,10	16,10	
		21:00	60,65	55,59	5,06	0,00	1	1		1	1	1	1			1					1		1	16,10	16,10	
		22:00	53,97	49,22	4,75	0,01	1	1	1	1	1	1	1			1					1		1	14,26	13,32	
		23:00	48,33	43,90	4,43	0,00	1	1	1	1	1	1	1								1		1	10,27	10,34	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης