

ΗΣ ΚΩ-ΚΑΛΥΜΝΟΥ			Απολογισμός Λειτουργίας										Κυριακή, 25 Μαΐου 2025													
Αποδιδόμενη Ισχύς (ΜW)						9,000	11,000	11,000	11,000	16,000	16,000	11,000	11,500	11,500	33,000	1,500	1,800	1,800	5,880	5,880	5,880	8,250				
Α	Σ	Ρ	Ε	Σ	Η	ΑΣΠ Κω										ΑΣΠ Καλύμνου						Εντολή περιορισμού των Αιολικών Πάρκων (ΜW)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (ΜW)			
						G1	G2	G3	G4	G5	G6	A/Σ G7	A/Σ G32	A/Σ G33	A/Σ G34	MTU 9-11	G1	G2	G3	G4	G5			G6		
Κυριακή, 25 Μαΐου 2025						00:00	49,32	44,63	4,68	0,01	1	1		1	1	1					1	1		10,75	10,36	
						01:00	46,37	40,22	6,13	0,01		1	1	1	1						1	1	1		10,87	10,93
						02:00	44,47	40,72	3,73	0,01			1	1	1						1	1			11,26	11,32
						03:00	43,22	39,52	3,68	0,01			1	1	1						1	1			10,01	9,83
						04:00	42,56	37,20	5,35	0,01			1	1	1	1					1	1			9,32	9,26
						05:00	43,72	37,18	6,54	0,01			1	1	1						1	1			10,38	10,58
						06:00	46,02	37,13	8,89	0,01			1	1	1						1	1			12,52	12,40
						07:00	51,26	40,94	10,31	0,01			1	1	1	1					1	1			15,97	16,01
						08:00	54,43	43,16	11,26	0,01			1	1	1						1	1			16,10	16,10
						09:00	58,11	46,38	11,71	0,02	1	1		1	1	1					1	1	1		16,10	16,10
						10:00	60,59	48,25	11,87	0,47	1	1	1		1						1	1	1	1	16,10	16,10
						11:00	63,00	50,85	11,75	0,41	1	1		1		1					1	1	1	1	16,10	16,10
						12:00	64,36	52,36	11,74	0,26	1	1		1	1	1					1	1		1	16,10	16,10
						13:00	65,44	55,03	9,98	0,43	1	1	1		1	1	1				1	1		1	16,10	16,10
						14:00	63,64	54,21	8,83	0,60	1	1		1	1	1					1	1		1	16,10	16,10
						15:00	61,05	57,63	3,03	0,38	1	1		1	1	1					1	1		1	16,10	16,10
						16:00	60,95	58,16	2,69	0,11	1	1	1		1	1	1	1			1	1		1	16,10	16,10
						17:00	61,95	59,33	2,62	0,00	1	1		1	1	1		1			1	1		1	16,10	16,10
						18:00	65,19	57,68	6,49	1,02	1	1		1	1	1		1			1	1		1	16,10	16,10
						19:00	65,87	59,37	5,47	1,02	1	1	1		1	1	1				1	1		1	16,10	16,10
						20:00	67,05	58,51	7,62	0,91	1	1		1	1	1		1			1	1		1	16,10	16,10
						21:00	65,02	55,33	8,83	0,87	1	1		1	1	1		1			1	1		1	16,10	16,10
						22:00	58,54	48,94	9,27	0,33	1	1		1	1	1		1			1	1		1	15,59	15,62
						23:00	52,57	47,08	5,44	0,05	1	1		1	1	1					1	1			14,01	15,42

Η μονάδα G11 βρίσκεται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης