

ΗΣ ΚΩ-ΚΑΛΥΜΝΟΥ			Απολογιστική Λειτουργία για την Προηγούμενη Ημέρα																			Τρίτη, 20 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)						9,000	11,000	11,000	11,000	16,000	16,000	11,000	11,500	11,500	33,000	1,500	1,800	1,800	5,880	5,880	5,880	8,250								
ΤΕ (MW)						5,360	5,452	5,452	5,452	8,250	8,250	5,000	5,000	5,000	6,600	0,640	0,922	0,922	2,900	2,900	2,900	4,125								
ΗΡΕΡΑ	Χρονική στιγμή	Πραγματικό Μέσο Όριο Φορτίο (MW)	Θερμική Παραγωγή (MW)	Αιολική Παραγωγή (MW)	Παραγωγή ΥΒΣ Τηλου (MW)	ΑΣΠ Κω										ΑΣΠ Καλύμνου										Στρεφόμενη εφεδρεία (MW)	Εντολή περιορισμού των Αιολικών Πάρκων (MW)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (MW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)
						61	62	63	64	65	66	A/Σ 67	A/Σ 632	A/Σ 633	A/Σ 634	MTU 9-11	61	62	63	64	65	66								
Τρίτη, 20 Μαΐου 2025	00:00	42,27	37,46	4,61	0,20		1		1	1	1													22,42	10,29	10,72	63%	5.016		
	01:00	39,96	35,87	3,88	0,20		1		1	1	1													24,01	9,46	9,42	60%	4.830		
	02:00	38,35	34,81	3,34	0,20		1		1	1	1													25,07	7,89	7,77	58%	4.706		
	03:00	37,63	35,07	2,36	0,21		1		1	1	1													24,81	7,13	7,24	59%	4.736		
	04:00	37,86	34,88	2,77	0,21		1		1	1	1													25,00	7,31	7,02	58%	4.714		
	05:00	39,48	37,04	2,23	0,21		1		1	1	1													22,84	8,85	8,98	62%	4.967		
	06:00	42,32	40,20	1,91	0,21		1		1	1	1													19,68	11,49	11,65	67%	5.340		
	07:00	48,69	47,35	1,13	0,21		1		1	1	1											1		20,78	14,50	14,54	70%	6.664		
	08:00	52,13	51,05	0,87	0,21	1	1		1	1	1												1	26,08	14,68	14,07	66%	7.110		
	09:00	54,18	52,74	1,24	0,21	1	1		1	1	1												1	24,39	14,37	14,31	68%	6.898		
	10:00	53,05	51,15	1,70	0,21	1	1		1	1	1												1	25,98	13,42	13,12	66%	6.714		
	11:00	51,19	49,26	1,72	0,21	1	1		1	1	1												1	27,87	11,48	11,35	64%	6.494		
	12:00	50,69	48,18	2,31	0,21	1	1		1	1	1												1	28,95	10,99	10,95	62%	6.370		
	13:00	52,09	48,83	3,06	0,21	1	1		1	1	1												1	28,30	12,31	12,27	63%	6.444		
	14:00	50,53	47,61	2,72	0,21	1	1		1	1	1												1	29,52	10,89	10,63	62%	6.304		
	15:00	48,62	43,81	4,61	0,21	1	1		1	1	1												1	33,32	8,78	8,68	57%	5.866		
	16:00	49,53	42,61	6,71	0,21	1	1		1	1	1												1	34,52	9,61	9,71	55%	5.729		
	17:00	52,80	45,78	6,82	0,21	1	1		1	1	1												1	31,35	12,66	13,02	59%	6.093		
	18:00	57,21	48,40	8,24	0,57	1	1		1	1	1												1	28,73	16,05	16,06	63%	6.395		
	19:00	60,28	53,69	6,11	0,48	1	1		1	1	1								1	1		1	29,32	16,10	16,10	65%	7.368			
	20:00	62,66	56,66	5,54	0,47	1	1		1	1	1								1	1		1	26,35	16,10	16,10	68%	7.369			
	21:00	60,58	54,68	5,73	0,16	1	1		1	1	1								1	1		1	28,33	16,05	15,98	66%	7.142			
	22:00	53,69	48,60	5,09	0,01	1	1		1	1	1								1	1		1	34,41	12,93	13,02	59%	6.446			
	23:00	47,68	42,92	4,75	0,01		1		1	1	1											1	25,21	13,47	13,76	63%	5.670			
		1183,48 MWh																								ΑΔΑ: 17,81		145.384 €		

Παρατηρήσεις:

Δεν προτείνεται οποιαδήποτε αλλαγή στην απολογιστική λειτουργία.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης