

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Απολογισμός Λειτουργίας		Τετάρτη, 30 Απριλίου 2025							
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400			
Η Ε Ρ Ε Ι Κ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7			
Τετάρτη, 30 Απριλίου 2025	00:00	65,9					1					
	01:00	62,5					1					
	02:00	63,1					1					
	03:00	61,3					1					
	04:00	65,4					1					
	05:00	63,0					1					
	06:00	58,9					1					
	07:00	51,2					1					
	08:00	53,5					1					
	09:00	56,4					1					
	10:00	52,2					1					
	11:00	51,7					1					
	12:00	59,8					1					
	13:00	60,4		1	1							
	14:00	59,1		1	1							
	15:00	56,1		1	1							
	16:00	62,4		1	1							
	17:00	69,3		1	1							
	18:00	62,2		1	1							
	19:00	65,4		1	1							
	20:00	75,9		1	1							
	21:00	91,7		1	1							
	22:00	75,5		1	1							
	23:00	71,3		1	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Απολογισμός Λειτουργίας	Πέμπτη, 1 Μαΐου 2025						
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 1 Μαΐου 2025	00:00	69,2		1	1				
	01:00	65,1		1	1				
	02:00	65,9		1	1				
	03:00	63,3		1	1				
	04:00	61,1		1	1				
	05:00	63,4		1	1				
	06:00	56,8		1	1				
	07:00	47,7		1	1				
	08:00	50,9		1	1				
	09:00	53,7		1	1				
	10:00	54,0		1	1				
	11:00	54,5		1	1				
	12:00	55,1		1	1				
	13:00	57,7		1	1				
	14:00	51,9		1	1				
	15:00	53,7		1	1				
	16:00	55,9		1	1				
	17:00	66,3		1	1				
	18:00	53,8		1	1				
	19:00	56,0		1	1				
	20:00	61,8		1	1				
	21:00	81,8		1	1				
	22:00	69,0		1	1				
	23:00	68,2		1	1				



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Απολογισμός Λειτουργίας		Παρασκευή, 2 Μαΐου 2025							
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400			
Η Ε Ρ Ε Ι Κ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7			
Παρασκευή, 2 Μαΐου 2025	00:00	66,4		1	1							
	01:00	64,6		1	1							
	02:00	61,8		1	1							
	03:00	62,3		1	1							
	04:00	61,8		1	1							
	05:00	60,2		1	1							
	06:00	56,8		1	1							
	07:00	52,2		1	1							
	08:00	60,6		1	1							
	09:00	56,6		1	1							
	10:00	63,0		1	1							
	11:00	53,8		1	1							
	12:00	57,7		1	1							
	13:00	54,5		1	1							
	14:00	63,1		1	1							
	15:00	53,9		1	1							
	16:00	53,0		1	1							
	17:00	58,1		1	1							
	18:00	54,9		1	1							
	19:00	55,0		1	1							
	20:00	70,3		1	1							
	21:00	93,4		1	1							
	22:00	82,1		1	1							
	23:00	74,6		1	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Απολογισμός Λειτουργίας		Σάββατο, 3 Μαΐου 2025							
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400			
Η Ε Ρ Ε Ι Κ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7			
Σάββατο, 3 Μαΐου 2025	00:00	70,3		1	1							
	01:00	68,4		1	1							
	02:00	64,8		1	1							
	03:00	65,0		1	1							
	04:00	63,0		1	1							
	05:00	62,6		1	1							
	06:00	55,2		1	1							
	07:00	55,0		1	1							
	08:00	57,5		1	1							
	09:00	57,0		1	1							
	10:00	59,4		1	1							
	11:00	64,9		1	1							
	12:00	69,5		1	1							
	13:00	66,4		1	1							
	14:00	64,9		1	1							
	15:00	74,1		1	1							
	16:00	72,7		1	1							
	17:00	69,2		1	1							
	18:00	75,4		1	1							
	19:00	67,3		1	1							
	20:00	70,3		1	1							
	21:00	97,0		1	1							
	22:00	90,3		1	1							
	23:00	75,7		1	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Απολογισμός Λειτουργίας		Κυριακή, 4 Μαΐου 2025							
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400			
Η Ε Ρ Ε Ι Κ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7			
Κυριακή, 4 Μαΐου 2025	00:00	74,3		1	1							
	01:00	66,3		1	1							
	02:00	67,0		1	1							
	03:00	67,0		1	1							
	04:00	62,8		1	1							
	05:00	60,8		1	1							
	06:00	55,2		1	1							
	07:00	48,9		1	1							
	08:00	66,1		1	1							
	09:00	61,3		1	1							
	10:00	63,4		1	1							
	11:00	63,9		1	1							
	12:00	70,2		1	1							
	13:00	61,4		1	1							
	14:00	59,0		1	1							
	15:00	56,1		1	1							
	16:00	63,5		1	1							
	17:00	72,3		1	1							
	18:00	59,8		1	1							
	19:00	71,5		1	1							
	20:00	74,8		1	1							
	21:00	89,0		1	1							
	22:00	80,1		1	1							
	23:00	75,3		1	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Απολογισμός Λειτουργίας	Δευτέρα, 5 Μαΐου 2025						
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 5 Μαΐου 2025	00:00	74,4		1	1				
	01:00	69,5		1	1				
	02:00	65,4		1	1				
	03:00	62,4		1	1				
	04:00	63,4		1	1				
	05:00	60,7		1	1				
	06:00	59,0		1	1				
	07:00	52,0		1	1				
	08:00	54,1		1	1				
	09:00	55,9		1	1				
	10:00	54,7		1	1				
	11:00	56,4		1	1				
	12:00	58,6		1	1				
	13:00	55,5		1	1				
	14:00	53,9		1	1				
	15:00	51,8		1	1				
	16:00	58,1		1	1				
	17:00	59,5		1	1				
	18:00	64,2		1	1				
	19:00	60,5		1	1				
	20:00	71,3		1	1				
	21:00	86,6		1	1				
	22:00	81,0		1	1				
	23:00	75,9		1	1				



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Απολογισμός Λειτουργίας	Τρίτη, 6 Μαΐου 2025						
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 6 Μαΐου 2025	00:00	69,0		1	1				
	01:00	69,0		1	1				
	02:00	64,1		1	1				
	03:00	64,1		1	1				
	04:00	64,3		1	1				
	05:00	64,5		1	1				
	06:00	59,8		1	1				
	07:00	59,4		1	1				
	08:00	60,9		1	1				
	09:00	61,3		1	1				
	10:00	64,3		1	1				
	11:00	57,1		1	1				
	12:00	60,9		1	1				
	13:00	57,1		1	1				
	14:00	59,8		1	1				
	15:00	65,8		1	1				
	16:00	63,2		1	1				
	17:00	62,1		1	1				
	18:00	65,4		1	1				
	19:00	65,3		1	1				
	20:00	73,6		1	1				
	21:00	95,3		1	1				
	22:00	84,3		1	1				
	23:00	79,0		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης