

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Πέμπτη, 19 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ρ Ε Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 19 Ιουνίου 2025	00:00	137					1		
	01:00	133					1		
	02:00	130					1		
	03:00	127					1		
	04:00	125					1		
	05:00	124					1		
	06:00	121					1		
	07:00	122					1		
	08:00	131					1		
	09:00	134					1		
	10:00	145					1		
	11:00	154					1		
	12:00	153					1		
	13:00	162			1		1		
	14:00	168			1		1		
	15:00	167			1		1		
	16:00	166			1		1		
	17:00	167			1		1		
	18:00	169			1		1		
	19:00	179			1		1		
	20:00	176			1		1		
	21:00	166			1		1		
	22:00	159			1		1		
	23:00	150					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Παρασκευή, 20 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 20 Ιουνίου 2025	00:00	137					1		
	01:00	133					1		
	02:00	132					1		
	03:00	130					1		
	04:00	127					1		
	05:00	127					1		
	06:00	124					1		
	07:00	127					1		
	08:00	136					1		
	09:00	140					1		
	10:00	148					1		
	11:00	154					1		
	12:00	152					1		
	13:00	158					1		
	14:00	163			1		1		
	15:00	165			1		1		
	16:00	176			1		1		
	17:00	177			1		1		
	18:00	177			1		1		
	19:00	184			1		1		
	20:00	180			1		1		
	21:00	170			1		1		
	22:00	164			1		1		
	23:00	157					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Σάββατο, 21 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 21 Ιουνίου 2025	00:00	141					1		
	01:00	137					1		
	02:00	135					1		
	03:00	133					1		
	04:00	131					1		
	05:00	129					1		
	06:00	128					1		
	07:00	129					1		
	08:00	134					1		
	09:00	140					1		
	10:00	151					1		
	11:00	163			1		1		
	12:00	168			1		1		
	13:00	175			1		1		
	14:00	181			1		1		
	15:00	182			1		1		
	16:00	188			1		1		
	17:00	186			1		1		
	18:00	183			1		1		
	19:00	186			1		1		
	20:00	182			1		1		
	21:00	171			1		1		
	22:00	165			1		1		
	23:00	157					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Κυριακή, 22 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 22 Ιουνίου 2025	00:00	141					1		
	01:00	140					1		
	02:00	139					1		
	03:00	137					1		
	04:00	135					1		
	05:00	134					1		
	06:00	132					1		
	07:00	133					1		
	08:00	138					1		
	09:00	146					1		
	10:00	158					1		
	11:00	172			1		1		
	12:00	177			1		1		
	13:00	183			1		1		
	14:00	187			1		1		
	15:00	189			1		1		
	16:00	193			1		1		
	17:00	191			1		1		
	18:00	187			1		1		
	19:00	188			1		1		
	20:00	184			1		1		
	21:00	173			1		1		
	22:00	165			1		1		
	23:00	155					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Δευτέρα, 23 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 23 Ιουνίου 2025	00:00	145					1		
	01:00	143					1		
	02:00	140					1		
	03:00	137					1		
	04:00	134					1		
	05:00	133					1		
	06:00	129					1		
	07:00	129					1		
	08:00	137					1		
	09:00	148					1		
	10:00	160			1		1		
	11:00	175			1		1		
	12:00	182			1		1		
	13:00	186			1		1		
	14:00	189			1		1		
	15:00	190			1		1		
	16:00	194			1		1		
	17:00	191			1		1		
	18:00	186			1		1		
	19:00	185			1		1		
	20:00	181			1		1		
	21:00	170			1		1		
	22:00	161			1		1		
	23:00	151					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Τρίτη, 24 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 24 Ιουνίου 2025	00:00	148					1		
	01:00	144					1		
	02:00	140					1		
	03:00	137					1		
	04:00	134					1		
	05:00	132					1		
	06:00	129					1		
	07:00	128					1		
	08:00	135					1		
	09:00	144					1		
	10:00	160			1		1		
	11:00	175			1		1		
	12:00	183			1		1		
	13:00	187			1		1		
	14:00	190			1		1		
	15:00	191			1		1		
	16:00	195			1		1		
	17:00	194			1		1		
	18:00	191			1		1		
	19:00	187			1		1		
	20:00	182			1		1		
	21:00	170			1		1		
	22:00	161			1		1		
	23:00	151					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Τετάρτη, 25 Ιουνίου 2025				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ε Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 25 Ιουνίου 2025	00:00	148					1		
	01:00	144					1		
	02:00	140					1		
	03:00	137					1		
	04:00	134					1		
	05:00	133					1		
	06:00	131					1		
	07:00	130					1		
	08:00	136					1		
	09:00	147					1		
	10:00	163			1		1		
	11:00	177			1		1		
	12:00	183			1		1		
	13:00	186			1		1		
	14:00	189			1		1		
	15:00	193			1		1		
	16:00	195			1		1		
	17:00	194			1		1		
	18:00	191			1		1		
	19:00	187			1		1		
	20:00	184			1		1		
	21:00	172			1		1		
	22:00	163			1		1		
	23:00	155					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης