

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τετάρτη, 4 Ιούνιος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	10,000	10,000	1,100
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Τετάρτη, 4 Ιούνιος 2025	00:00	35,74			1	1	1	1		1	1	1	
	01:00	33,20			1	1	1	1		1	1	1	
	02:00	32,11			1	1	1	1		1	1	1	
	03:00	31,05			1	1	1	1		1	1	1	
	04:00	30,98			1	1	1	1		1	1	1	
	05:00	30,92			1	1	1	1		1	1	1	
	06:00	32,33			1	1	1	1		1	1	1	
	07:00	36,33			1	1	1	1		1	1	1	
	08:00	39,50			1	1	1	1		1	1	1	
	09:00	41,35			1	1	1	1		1	1	1	
	10:00	41,80			1	1	1	1		1	1	1	
	11:00	41,96			1	1	1	1		1	1	1	1
	12:00	43,91			1	1	1	1		1	1	1	1
	13:00	44,49			1	1	1	1		1	1	1	3
	14:00	44,24			1	1	1	1		1	1	1	1
	15:00	43,39			1	1	1	1		1	1	1	1
	16:00	43,52		1	1	1	1	1		1	1	1	1
	17:00	43,40			1	1	1	1		1	1	1	3
	18:00	44,35			1	1	1	1		1	1	1	3
	19:00	44,99			1	1	1	1		1	1	1	3
	20:00	44,97			1	1	1	1		1	1	1	3
	21:00	45,29			1	1	1	1		1	1	1	2
	22:00	43,19			1	1	1	1		1	1	1	
	23:00	39,52			1	1	1	1		1	1	1	

Δύο φορητά Η/Ζ βρίσκονται σε βλάβη. Μισθωμένη ισχύς 10 MW. Η G31 & G32 είναι σε δοκιμαστική λειτουργία.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης