

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 5 Ιούνιος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	10,647	12,000	10,000	10,000	1,100
Η π ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Πέμπτη, 5 Ιούνιος 2025	00:00	36,11			1	1	1	1		1	1	1	
	01:00	33,04			1	1	1	1		1	1	1	
	02:00	32,11			1	1	1	1		1	1	1	
	03:00	31,69			1	1	1	1		1	1	1	
	04:00	31,20			1	1	1	1		1	1	1	
	05:00	31,38			1	1	1	1		1	1	1	
	06:00	32,27			1	1	1	1		1	1	1	
	07:00	36,49			1	1	1	1		1	1	1	
	08:00	40,20			1	1	1	1		1	1	1	
	09:00	42,39			1	1	1	1		1	1	1	
	10:00	43,63			1	1	1	1		1	1	1	1
	11:00	44,10			1	1	1	1	1		1	1	4
	12:00	44,78			1	1	1	1	1		1	1	4
	13:00	45,45		1	1	1	1	1	1		1	1	5
	14:00	45,49		1	1	1	1	1			1	1	7
	15:00	45,09		1	1	1	1	1			1	1	7
	16:00	44,87		1	1	1	1	1			1	1	7
	17:00	45,48		1	1	1	1	1			1	1	7
	18:00	45,46		1	1	1	1	1			1	1	7
	19:00	45,59		1	1	1	1	1			1	1	7
	20:00	45,93		1	1	1	1	1			1	1	7
	21:00	46,63		1	1	1	1	1			1	1	7
	22:00	44,21		1	1	1	1	1			1	1	7
	23:00	40,23		1	1	1	1	1			1	1	5

Δύο φορητά Η/Ζ βρίσκονται σε βλάβη. Μισθωμένη ισχύς 10 MW. Η G31 & G32 είναι σε δοκιμαστική λειτουργία.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης