

ΗΣ ΘΗΡΑΣ			Απολογισμός Λειτουργίας		Κυριακή, 15 Ιούνιος 2025								
Αποδιδόμενη Ισχύς (MW)			7,300	7,300	3,500	3,500	3,500	5,800	8,500	10,500	10,000	10,000	1,000
Η μ ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x26)
Κυριακή, 15 Ιούνιος 2025	00:00	37,84		1	1	1	1			1	1	1	
	01:00	35,89		1	1	1	1			1	1	1	
	02:00	34,75		1	1	1	1			1	1	1	
	03:00	34,22		1	1	1	1			1	1	1	
	04:00	33,53		1	1	1	1			1	1	1	
	05:00	33,04		1	1	1	1			1	1	1	
	06:00	34,01		1	1	1	1			1	1	1	
	07:00	37,51		1	1	1	1			1	1	1	
	08:00	40,33		1	1	1	1			1	1	1	1
	09:00	42,12		1		1	1			1	1	1	3
	10:00	43,54		1		1	1			1	1	1	4
	11:00	44,40		1	1	1	1			1	1	1	4
	12:00	45,69		1	1	1	1		1	1	1	1	7
	13:00	46,29		1	1	1	1		1		1	1	7
	14:00	47,42		1	1	1	1		1		1	1	6
	15:00	46,29		1	1	1	1		1		1	1	5
	16:00	45,58		1	1	1	1		1		1	1	5
	17:00	45,70		1	1	1	1		1		1	1	5
	18:00	46,85		1	1	1	1	1	1		1	1	4
	19:00	46,57		1	1		1	1	1		1	1	4
	20:00	46,59		1	1		1	1	1		1	1	4
	21:00	47,37		1	1		1	1	1		1	1	4
	22:00	45,15		1	1		1	1	1		1	1	4
	23:00	41,26		1	1		1	1	1		1	1	

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη. Μισθωμένη ισχύς 10 MW. Η G31 & G32 είναι σε δοκιμαστική λειτουργία έως 12 MW.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης