

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 5 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 5 Φεβρουαρίου 2025	00:00	0,958	1	1							
	01:00	0,842		1							
	02:00	0,781		1							
	03:00	0,785		1							
	04:00	0,768		1							
	05:00	0,787		1							
	06:00	0,877		1							
	07:00	0,896		1							
	08:00	0,950		1							
	09:00	0,948	1								
	10:00	0,920	1								
	11:00	0,988	1								1
	12:00	1,093	1								1
	13:00	1,168	1								1
	14:00	1,230	1								1
	15:00	1,281	1								1
	16:00	1,293	1								1
	17:00	1,422	1								1
	18:00	1,556	1								1
	19:00	1,510	1								1
	20:00	1,448	1								1
	21:00	1,296	1								1
	22:00	1,172	1								1
	23:00	1,034	1								1



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 6 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η ο ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 6 Φεβρουαρίου 2025	00:00	0,968	1								1
	01:00	0,898	1								
	02:00	0,849	1								
	03:00	0,839	1								
	04:00	0,783	1								
	05:00	0,807	1								
	06:00	0,915	1								
	07:00	0,977	1								1
	08:00	1,017	1								1
	09:00	1,151	1								1
	10:00	1,177	1								1
	11:00	1,179	1								1
	12:00	1,231	1								1
	13:00	1,219	1								1
	14:00	1,197	1								1
	15:00	1,315	1								1
	16:00	1,356	1								1
	17:00	1,431	1								1
	18:00	1,512	1								1
	19:00	1,471	1								1
	20:00	1,440	1								1
	21:00	1,320	1								1
	22:00	1,176	1								1
	23:00	1,028	1								1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 7 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 7 Φεβρουαρίου 2025	00:00	0,946	1								1
	01:00	0,861	1								
	02:00	0,884	1								
	03:00	0,858	1								
	04:00	0,778	1								
	05:00	0,819	1								
	06:00	0,897	1								
	07:00	0,943	1							1	
	08:00	0,992	1							1	
	09:00	1,004	1							1	
	10:00	0,988	1							1	
	11:00	1,018	1							1	
	12:00	1,002	1							1	
	13:00	1,140	1							1	
	14:00	1,220	1							1	
	15:00	1,289	1							1	
	16:00	1,343	1							1	
	17:00	1,475	1							1	
	18:00	1,588	1							1	
	19:00	1,551	1	1							
	20:00	1,490	1	1							
	21:00	1,390	1	1							
	22:00	1,172	1	1							
	23:00	1,058	1	1							



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 8 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 8 Φεβρουαρίου 2025	00:00	0,966	1	1							
	01:00	0,879	1								
	02:00	0,847	1								
	03:00	0,850	1								
	04:00	0,864	1								
	05:00	0,911	1								
	06:00	1,002	1							1	
	07:00	0,997	1							1	
	08:00	1,035	1							1	
	09:00	1,210	1							1	
	10:00	1,243	1							1	
	11:00	1,300	1							1	
	12:00	1,417	1							1	
	13:00	1,453	1							1	
	14:00	1,461	1							1	
	15:00	1,458	1							1	
	16:00	1,553	1							1	
	17:00	1,639	1	1							
	18:00	1,673	1	1							
	19:00	1,626	1	1							
	20:00	1,578	1	1							
	21:00	1,455	1	1							
	22:00	1,312	1	1							
	23:00	1,203	1	1							



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 9 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 9 Φεβρουαρίου 2025	00:00	1,090	1	1							
	01:00	0,974	1	1							
	02:00	0,935	1	1							
	03:00	0,946	1	1							
	04:00	0,988	1	1							
	05:00	0,997	1	1							
	06:00	1,011	1							1	
	07:00	1,045	1							1	
	08:00	1,165	1							1	
	09:00	1,237	1							1	
	10:00	1,284	1							1	
	11:00	1,304	1							1	
	12:00	1,375	1							1	
	13:00	1,437	1							1	
	14:00	1,332	1							1	
	15:00	1,378	1							1	
	16:00	1,413	1							1	
	17:00	1,476	1							1	
	18:00	1,542	1							1	
	19:00	1,495	1							1	
	20:00	1,504	1							1	
	21:00	1,397	1							1	
	22:00	1,222	1							1	
	23:00	1,089	1							1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 10 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 10 Φεβρουαρίου 2025	00:00	0,973	1							1	
	01:00	0,900	1	1							
	02:00	0,864	1	1							
	03:00	0,892	1	1							
	04:00	0,899	1	1							
	05:00	0,938	1	1							
	06:00	1,043	1	1							
	07:00	1,083	1	1							
	08:00	1,167	1	1							
	09:00	1,260	1	1							
	10:00	1,272	1	1							
	11:00	1,379	1	1							
	12:00	1,368	1	1							
	13:00	1,382	1	1							
	14:00	1,406	1	1							
	15:00	1,404	1	1							
	16:00	1,421	1	1							
	17:00	1,571	1	1							
	18:00	1,646	1	1							
	19:00	1,635	1	1							
	20:00	1,608	1	1							
	21:00	1,496	1	1							
	22:00	1,308	1	1							
	23:00	1,151	1	1							



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 11 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 11 Φεβρουαρίου 2025	00:00	1,018	1	1							
	01:00	0,933	1	1							
	02:00	0,904	1	1							
	03:00	0,881	1	1							
	04:00	0,900	1	1							
	05:00	0,972	1	1							
	06:00	1,071	1	1							
	07:00	1,147	1	1							
	08:00	1,082	1	1							
	09:00	1,088	1	1							
	10:00	1,086	1	1							
	11:00	1,102	1	1							
	12:00	1,138	1	1							
	13:00	1,062	1	1							
	14:00	1,092	1	1							
	15:00	1,220	1	1							
	16:00	1,362	1	1							
	17:00	1,563	1	1							
	18:00	1,719	1	1							
	19:00	1,712	1	1							
	20:00	1,725	1	1							
	21:00	1,605	1	1							
	22:00	1,401	1	1							
	23:00	1,167	1	1							



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης