

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 12 Μαρτίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Α Ρ Χ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 12 Μαρτίου 2025	00:00	0,856	1								
	01:00	0,809	1								
	02:00	0,793	1								
	03:00	0,777	1								
	04:00	0,799	1								
	05:00	0,785	1								
	06:00	0,846	1								
	07:00	0,864	1								
	08:00	0,898	1								
	09:00	0,935	1							1	
	10:00	0,986	1							1	
	11:00	0,923	1							1	
	12:00	0,930	1							1	
	13:00	0,899	1							1	
	14:00	1,014	1							1	
	15:00	1,053	1							1	
	16:00	1,084	1							1	
	17:00	1,188	1							1	
	18:00	1,323	1							1	
	19:00	1,381	1							1	
	20:00	1,360	1							1	
	21:00	1,204	1							1	
	22:00	1,132	1							1	
	23:00	0,978	1							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 13 Μαρτίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 13 Μαρτίου 2025	00:00	0,898	1								
	01:00	0,840	1								
	02:00	0,828	1								
	03:00	0,803	1								
	04:00	0,855	1								
	05:00	0,829	1								
	06:00	0,912	1								
	07:00	0,930	1							1	
	08:00	0,890	1							1	
	09:00	0,748	1								
	10:00	0,745	1								
	11:00	0,718	1								
	12:00	0,688	1								
	13:00	0,723	1								
	14:00	0,775	1								
	15:00	0,830	1								
	16:00	0,940	1							1	
	17:00	1,050	1							1	
	18:00	1,216	1							1	
	19:00	1,281	1							1	
	20:00	1,279	1							1	
	21:00	1,198	1							1	
	22:00	1,098	1							1	
	23:00	0,939	1							1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 14 Μαρτίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ρ Α Π Ε Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 14 Μαρτίου 2025	00:00	0,878	1								
	01:00	0,818	1								
	02:00	0,786	1								
	03:00	0,684	1								
	04:00	0,750	1								
	05:00	0,730	1								
	06:00	0,837	1								
	07:00	0,867	1								
	08:00	0,832	1								
	09:00	0,812	1								
	10:00	0,824	1								
	11:00	0,756	1								
	12:00	0,719	1								
	13:00	0,732	1								
	14:00	0,735	1								
	15:00	0,706	1								
	16:00	0,831	1								
	17:00	0,987	1							1	
	18:00	1,197	1							1	
	19:00	1,227	1							1	
	20:00	1,224	1							1	
	21:00	1,126	1							1	
	22:00	1,037	1							1	
	23:00	0,926	1							1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 15 Μαρτίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 15 Μαρτίου 2025	00:00	0,854	1								
	01:00	0,781	1								
	02:00	0,798	1								
	03:00	0,794	1								
	04:00	0,831	1								
	05:00	0,736	1								
	06:00	0,781	1								
	07:00	0,766	1								
	08:00	0,809	1								
	09:00	0,811	1								
	10:00	0,743	1								
	11:00	0,715	1								
	12:00	0,738	1								
	13:00	0,747	1								
	14:00	0,810	1								
	15:00	0,817	1								
	16:00	0,874	1							1	
	17:00	1,005	1							1	
	18:00	1,163	1							1	
	19:00	1,188	1							1	
	20:00	1,197	1							1	
	21:00	1,082	1							1	
	22:00	1,013	1							1	
	23:00	0,916	1							1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 16 Μαρτίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Α Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 16 Μαρτίου 2025	00:00	0,871	1								
	01:00	0,808	1								
	02:00	0,735	1								
	03:00	0,689	1								
	04:00	0,740	1								
	05:00	0,741	1								
	06:00	0,834	1								
	07:00	0,834	1								
	08:00	0,792	1								
	09:00	0,760	1								
	10:00	0,771	1								
	11:00	0,718	1								
	12:00	0,753	1								
	13:00	0,763	1								
	14:00	0,793	1								
	15:00	0,765	1								
	16:00	0,859	1								
	17:00	0,942	1							1	
	18:00	1,000	1							1	
	19:00	1,004	1							1	
	20:00	1,030	1							1	
	21:00	0,896	1							1	
	22:00	0,823	1							1	
	23:00	0,791	1								

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 17 Μαρτίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Α Ρ Χ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 17 Μαρτίου 2025	00:00	0,762	1								
	01:00	0,720	1								
	02:00	0,708	1								
	03:00	0,728	1								
	04:00	0,722	1								
	05:00	0,677	1								
	06:00	0,733	1								
	07:00	0,731	1								
	08:00	0,733	1								
	09:00	0,735	1								
	10:00	0,821	1								
	11:00	0,719	1								
	12:00	0,738	1								
	13:00	0,720	1								
	14:00	0,723	1								
	15:00	0,755	1								
	16:00	0,872	1								
	17:00	0,906	1							1	
	18:00	1,039	1							1	
	19:00	1,064	1							1	
	20:00	1,090	1							1	
	21:00	1,045	1							1	
	22:00	0,966	1							1	
	23:00	0,935	1							1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 18 Μαρτίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 18 Μαρτίου 2025	00:00	0,836	1								
	01:00	0,786	1								
	02:00	0,762	1								
	03:00	0,754	1								
	04:00	0,779	1								
	05:00	0,778	1								
	06:00	0,838	1								
	07:00	0,817	1								
	08:00	0,801	1								
	09:00	0,767	1								
	10:00	0,757	1								
	11:00	0,672	1								
	12:00	0,703	1								
	13:00	0,678	1								
	14:00	0,741	1								
	15:00	0,831	1								
	16:00	0,982	1	1							
	17:00	1,168	1	1							
	18:00	1,262	1	1							
	19:00	1,328	1	1							
	20:00	1,359	1	1							
	21:00	1,209	1	1							
	22:00	1,107	1	1							
	23:00	0,970	1	1							



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης