

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 14 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 14 Μαΐου 2025	00:00	0,977		1						1	
	01:00	0,884		1					1	1	
	02:00	0,859		1					1		
	03:00	0,884							1		
	04:00	0,869							1		
	05:00	0,892							1		
	06:00	0,944							1	1	
	07:00	0,938							1	1	
	08:00	0,942							1	1	
	09:00	0,882							1	1	
	10:00	0,946							1	1	
	11:00	0,968							1	1	
	12:00	0,992							1	1	
	13:00	0,981							1	1	
	14:00	1,020							1	1	
	15:00	0,982							1	1	
	16:00	0,996							1	1	
	17:00	1,043							1	1	
	18:00	1,135							1	1	
	19:00	1,220							1	1	
	20:00	1,267							1	1	
	21:00	1,326							1	1	
	22:00	1,213							1	1	
	23:00	1,098							1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 15 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 15 Μαΐου 2025	00:00	1,017							1	1	
	01:00	0,941							1	1	
	02:00	0,867							1	1	
	03:00	0,862							1		
	04:00	0,850							1		
	05:00	0,886							1		
	06:00	0,932							1		
	07:00	0,956							1		
	08:00	0,988							1		
	09:00	0,986							1	1	
	10:00	0,960							1	1	
	11:00	0,964							1	1	
	12:00	0,962							1	1	
	13:00	0,983							1	1	
	14:00	0,972							1	1	
	15:00	0,966							1	1	
	16:00	1,034							1	1	
	17:00	1,035							1	1	
	18:00	1,176							1	1	
	19:00	1,254							1	1	
	20:00	1,357							1	1	
	21:00	1,314							1	1	
	22:00	1,227							1	1	
	23:00	1,041							1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 16 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Α Ρ Χ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 16 Μαΐου 2025	00:00	0,951							1	1	
	01:00	0,883							1	1	
	02:00	0,877							1		
	03:00	0,903							1		
	04:00	0,882							1		
	05:00	0,915							1		
	06:00	0,979							1		
	07:00	0,988							1		
	08:00	1,016							1	1	
	09:00	1,006							1	1	
	10:00	1,074							1	1	
	11:00	1,099							1	1	
	12:00	1,102							1	1	
	13:00	1,119							1	1	
	14:00	1,042							1	1	
	15:00	1,086							1	1	
	16:00	1,153							1	1	
	17:00	1,190							1	1	
	18:00	1,302							1	1	
	19:00	1,316							1	1	
	20:00	1,395							1	1	
	21:00	1,399							1	1	
	22:00	1,255							1	1	
	23:00	1,112							1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 17 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 17 Μαΐου 2025	00:00	1,018							1	1	
	01:00	0,946							1	1	
	02:00	0,944							1	1	
	03:00	0,947							1	1	
	04:00	0,938							1	1	
	05:00	0,985							1	1	
	06:00	1,037							1	1	
	07:00	1,018							1	1	
	08:00	1,016							1	1	
	09:00	1,049							1	1	
	10:00	1,047							1	1	
	11:00	1,084							1	1	
	12:00	1,122							1	1	
	13:00	1,095							1	1	
	14:00	1,115							1	1	
	15:00	1,142							1	1	
	16:00	1,164							1	1	
	17:00	1,192							1	1	
	18:00	1,242							1	1	
	19:00	1,296							1	1	
	20:00	1,399							1	1	
	21:00	1,407							1	1	
	22:00	1,282							1	1	
	23:00	1,150							1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 18 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 18 Μαΐου 2025	00:00	1,109							1	1	
	01:00	1,019							1	1	
	02:00	0,956							1	1	
	03:00	0,960							1	1	
	04:00	0,929							1	1	
	05:00	0,968							1	1	
	06:00	1,011							1	1	
	07:00	0,969							1	1	
	08:00	0,984							1	1	
	09:00	0,972							1	1	
	10:00	0,994							1	1	
	11:00	1,052							1	1	
	12:00	1,073							1	1	
	13:00	1,071							1	1	
	14:00	1,065							1	1	
	15:00	1,033							1	1	
	16:00	1,033							1	1	
	17:00	1,083							1	1	
	18:00	1,168							1	1	
	19:00	1,219							1	1	
	20:00	1,274							1	1	
	21:00	1,314							1	1	
	22:00	1,220							1	1	
	23:00	1,102							1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 19 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 19 Μαΐου 2025	00:00	1,016							1	1	
	01:00	0,932							1	1	
	02:00	0,904							1	1	
	03:00	0,925							1	1	
	04:00	0,921							1	1	
	05:00	0,942							1	1	
	06:00	0,960							1	1	
	07:00	0,973							1	1	
	08:00	0,974							1	1	
	09:00	0,972							1	1	
	10:00	0,982							1	1	
	11:00	1,004							1	1	
	12:00	0,980							1	1	
	13:00	0,982							1	1	
	14:00	1,013							1	1	
	15:00	0,969							1	1	
	16:00	0,986							1	1	
	17:00	1,036							1	1	
	18:00	1,132							1	1	
	19:00	1,220							1	1	
	20:00	1,314							1	1	
	21:00	1,381							1	1	
	22:00	1,217							1	1	
	23:00	1,083							1	1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 20 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Α Ρ Χ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 20 Μαΐου 2025	00:00	1,026							1	1	
	01:00	0,921							1	1	
	02:00	0,877							1	1	
	03:00	0,909							1	1	
	04:00	0,927							1	1	
	05:00	0,898							1	1	
	06:00	0,967							1	1	
	07:00	0,943							1	1	
	08:00	1,020							1	1	
	09:00	1,058							1	1	
	10:00	1,024							1	1	
	11:00	1,017							1	1	
	12:00	1,066							1	1	
	13:00	1,069							1	1	
	14:00	1,073							1	1	
	15:00	1,037							1	1	
	16:00	1,058							1	1	
	17:00	1,095							1	1	
	18:00	1,228							1	1	
	19:00	1,305							1	1	
	20:00	1,338							1	1	
	21:00	1,423							1	1	
	22:00	1,248							1	1	
	23:00	1,098							1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης