

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 19 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 19 Φεβρουαρίου 2025	00:00	0,998	1							1	
	01:00	0,935	1							1	
	02:00	0,815	1							1	
	03:00	0,778	1								
	04:00	0,779	1								
	05:00	0,789	1								
	06:00	0,876	1								
	07:00	0,940		1						1	
	08:00	0,981		1						1	
	09:00	1,100	1	1							
	10:00	1,162	1	1							
	11:00	1,241	1	1							
	12:00	1,364	1	1							
	13:00	1,408	1	1							
	14:00	1,307	1	1							
	15:00	1,287	1	1							
	16:00	1,371	1	1							
	17:00	1,536	1	1							
	18:00	1,683	1	1							
	19:00	1,620	1	1							
	20:00	1,519	1	1							
	21:00	1,420	1	1							
	22:00	1,252	1	1							
	23:00	1,080	1	1							



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 20 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 20 Φεβρουαρίου 2025	00:00	0,946	1	1							
	01:00	0,917	1	1							
	02:00	0,868	1								
	03:00	0,906	1								
	04:00	0,970	1								
	05:00	0,982	1	1							
	06:00	1,079	1	1							
	07:00	1,134	1	1							
	08:00	1,207	1	1							
	09:00	1,322	1	1							
	10:00	1,356	1	1							
	11:00	1,410	1	1							
	12:00	1,443	1	1							
	13:00	1,367	1	1							
	14:00	1,406	1	1							
	15:00	1,399	1	1							
	16:00	1,386	1	1							
	17:00	1,415	1	1							
	18:00	1,502	1	1							
	19:00	1,559	1	1							
	20:00	1,526	1	1							
	21:00	1,406	1	1							
	22:00	1,281	1	1							
	23:00	1,152	1	1							



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 21 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 21 Φεβρουαρίου 2025	00:00	1,036	1	1							
	01:00	0,967	1	1							
	02:00	0,906	1	1							
	03:00	0,892	1								
	04:00	0,905	1								
	05:00	0,938	1	1							
	06:00	1,002	1	1							
	07:00	1,074	1	1							
	08:00	1,152	1	1							
	09:00	1,282	1	1							
	10:00	1,377	1	1							
	11:00	1,460	1	1							
	12:00	1,487	1	1							
	13:00	1,505	1	1							
	14:00	1,515	1	1							
	15:00	1,526	1	1							
	16:00	1,598	1	1							
	17:00	1,710	1	1							
	18:00	1,783	1	1							
	19:00	1,723	1	1							
	20:00	1,641	1	1							
	21:00	1,532	1	1							
	22:00	1,377	1	1							
	23:00	1,207	1	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 22 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 22 Φεβρουαρίου 2025	00:00	1,104	1	1							
	01:00	1,012	1	1							
	02:00	0,966	1	1							
	03:00	0,976	1	1							
	04:00	1,002	1	1							
	05:00	0,964	1	1							
	06:00	1,045	1	1							
	07:00	1,085	1	1							
	08:00	1,189	1	1							
	09:00	1,280	1	1							
	10:00	1,319	1	1							
	11:00	1,337	1	1							
	12:00	1,516	1	1							
	13:00	1,542	1	1							
	14:00	1,509	1	1							
	15:00	1,522	1	1							
	16:00	1,656	1	1							
	17:00	1,754	1	1							
	18:00	1,852	1	1							
	19:00	1,820	1	1							
	20:00	1,699	1	1							
	21:00	1,555	1	1							
	22:00	1,393	1	1							
	23:00	1,217	1	1							



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 23 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 23 Φεβρουαρίου 2025	00:00	1,090	1	1							
	01:00	1,012	1	1							
	02:00	0,948	1	1							
	03:00	0,940	1	1							
	04:00	1,013	1	1							
	05:00	1,021	1	1							
	06:00	1,092	1	1							
	07:00	1,127	1	1							
	08:00	1,179	1	1							
	09:00	1,216	1	1							
	10:00	1,222	1	1							
	11:00	1,174	1	1							
	12:00	1,176	1	1							
	13:00	1,210	1	1							
	14:00	1,190	1	1							
	15:00	1,175	1	1							
	16:00	1,199	1	1							
	17:00	1,352	1	1							
	18:00	1,557	1	1							
	19:00	1,604	1	1							
	20:00	1,539	1	1							
	21:00	1,495	1	1							
	22:00	1,344	1	1							
	23:00	1,221	1	1							



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 24 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 24 Φεβρουαρίου 2025	00:00	1,077	1	1							
	01:00	0,978	1	1							
	02:00	0,927	1	1							
	03:00	0,921	1	1							
	04:00	0,958	1	1							
	05:00	0,933	1	1							
	06:00	1,011	1	1							
	07:00	1,076	1							1	
	08:00	1,124	1							1	
	09:00	1,165	1							1	
	10:00	1,223	1							1	
	11:00	1,232	1							1	
	12:00	1,278	1							1	
	13:00	1,241	1							1	
	14:00	1,238	1							1	
	15:00	1,269	1							1	
	16:00	1,321	1							1	
	17:00	1,488	1	1							
	18:00	1,578	1	1							
	19:00	1,636	1	1							
	20:00	1,670	1	1							
	21:00	1,539	1	1							
	22:00	1,356	1	1							
	23:00	1,213	1	1							



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 25 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 25 Φεβρουαρίου 2025	00:00	1,090	1	1							
	01:00	0,967	1	1							
	02:00	0,882	1	1							
	03:00	0,862	1	1							
	04:00	0,900	1	1							
	05:00	0,926	1	1							
	06:00	0,994	1	1							
	07:00	1,060	1	1							
	08:00	1,082	1							1	
	09:00	1,005	1							1	
	10:00	0,960	1							1	
	11:00	0,965	1							1	
	12:00	0,964	1							1	
	13:00	1,032	1							1	
	14:00	1,015	1							1	
	15:00	1,022	1							1	
	16:00	1,150	1							1	
	17:00	1,200	1							1	
	18:00	1,386	1							1	
	19:00	1,529	1							1	
	20:00	1,487	1							1	
	21:00	1,395	1							1	
	22:00	1,260	1							1	
	23:00	1,152	1							1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης