

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 28 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Α Ρ Χ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 28 Μαΐου 2025	00:00	1,039		1					1		
	01:00	0,959		1					1		
	02:00	0,950		1					1		
	03:00	0,928		1					1		
	04:00	0,932		1					1		
	05:00	0,971		1					1		
	06:00	1,010		1					1		
	07:00	1,050		1					1		
	08:00	1,075		1					1		
	09:00	1,094		1					1		
	10:00	1,135		1					1		
	11:00	1,193		1					1		
	12:00	1,194		1					1		
	13:00	1,284		1					1		
	14:00	1,248		1					1		
	15:00	1,178		1					1		
	16:00	1,208		1					1		
	17:00	1,266		1					1		
	18:00	1,292		1					1		
	19:00	1,349		1					1		
	20:00	1,458		1					1		
	21:00	1,530		1					1		
	22:00	1,390		1					1		
	23:00	1,252		1					1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 29 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 29 Μαΐου 2025	00:00	1,136		1					1		
	01:00	1,031		1					1		
	02:00	0,984		1					1		
	03:00	0,986		1					1		
	04:00	0,985		1					1		
	05:00	1,029		1					1		
	06:00	1,069		1					1		
	07:00	1,078		1					1		
	08:00	1,120		1					1		
	09:00	1,157		1					1		
	10:00	1,179		1					1		
	11:00	1,232		1					1		
	12:00	1,264		1					1		
	13:00	1,310		1					1		
	14:00	1,356		1					1		
	15:00	1,295		1					1		
	16:00	1,287		1					1		
	17:00	1,348		1					1		
	18:00	1,445		1					1		
	19:00	1,509		1					1		
	20:00	1,557		1					1		
	21:00	1,555		1					1		
	22:00	1,409		1					1		
	23:00	1,225		1					1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 30 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 30 Μαΐου 2025	00:00	1,121		1					1		
	01:00	1,032		1					1		
	02:00	0,999		1					1		
	03:00	0,999		1					1		
	04:00	0,969		1					1		
	05:00	1,025		1					1		
	06:00	1,066		1					1		
	07:00	1,121		1					1		
	08:00	1,176		1					1		
	09:00	1,192		1					1		
	10:00	1,184		1					1		
	11:00	1,228		1					1		
	12:00	1,338		1					1		
	13:00	1,390		1					1		
	14:00	1,334		1					1		
	15:00	1,292		1					1		
	16:00	1,278		1					1		
	17:00	1,394		1					1		
	18:00	1,508		1					1		
	19:00	1,578		1					1		
	20:00	1,655		1					1		
	21:00	1,714		1					1		
	22:00	1,575		1					1		
	23:00	1,336		1					1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 31 Μαΐου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 31 Μαΐου 2025	00:00	1,195		1					1		
	01:00	1,127		1					1		
	02:00	1,043		1					1		
	03:00	1,046		1					1		
	04:00	1,021		1					1		
	05:00	1,064		1					1		
	06:00	1,180		1					1		
	07:00	1,184		1					1		
	08:00	1,226		1					1		
	09:00	1,323		1					1		
	10:00	1,411		1					1		
	11:00	1,452		1					1		
	12:00	1,501		1					1		
	13:00	1,500		1					1		
	14:00	1,490		1					1		
	15:00	1,489		1					1		
	16:00	1,470		1					1		
	17:00	1,457		1					1		
	18:00	1,504		1					1		
	19:00	1,521		1					1		
	20:00	1,565		1					1		
	21:00	1,643		1					1		
	22:00	1,501		1					1		
	23:00	1,386		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 1 Ιουνίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ρ Α Ξ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 1 Ιουνίου 2025	00:00	1,276		1					1		
	01:00	1,154		1					1		
	02:00	1,071		1					1		
	03:00	1,077		1					1		
	04:00	1,087		1					1		
	05:00	1,101		1					1		
	06:00	1,079		1					1		
	07:00	1,142		1					1		
	08:00	1,203		1					1		
	09:00	1,209		1					1		
	10:00	1,275		1					1		
	11:00	1,366		1					1		
	12:00	1,406		1					1		
	13:00	1,455		1					1		
	14:00	1,397		1					1		
	15:00	1,417		1					1		
	16:00	1,368		1					1		
	17:00	1,353		1					1		
	18:00	1,472		1					1		
	19:00	1,501		1					1		
	20:00	1,569		1					1		
	21:00	1,610		1					1		
	22:00	1,460		1					1		
	23:00	1,324		1					1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 2 Ιουνίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 2 Ιουνίου 2025	00:00	1,213		1					1		
	01:00	1,113		1					1		
	02:00	1,043		1					1		
	03:00	1,040		1					1		
	04:00	1,035		1					1		
	05:00	1,075		1					1		
	06:00	1,132		1					1		
	07:00	1,197		1					1		
	08:00	1,272		1					1		
	09:00	1,308		1					1		
	10:00	1,319		1					1		
	11:00	1,382		1					1		
	12:00	1,421		1					1		
	13:00	1,409		1					1		
	14:00	1,430		1					1		
	15:00	1,395		1					1		
	16:00	1,386		1					1		
	17:00	1,378		1					1		
	18:00	1,447		1					1		
	19:00	1,501		1					1		
	20:00	1,586		1					1		
	21:00	1,647		1					1		
	22:00	1,454		1					1		
	23:00	1,325		1					1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 3 Ιουνίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ρ Α Π Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 3 Ιουνίου 2025	00:00	1,212		1					1		
	01:00	1,107							1	1	
	02:00	1,062							1	1	
	03:00	1,061							1	1	
	04:00	1,052							1	1	
	05:00	1,070							1	1	
	06:00	1,101							1	1	
	07:00	1,163							1	1	
	08:00	1,202							1	1	
	09:00	1,265							1	1	
	10:00	1,330							1	1	
	11:00	1,348							1	1	
	12:00	1,408							1	1	
	13:00	1,426							1	1	
	14:00	1,417							1	1	
	15:00	1,394		1					1		
	16:00	1,402		1					1		
	17:00	1,420		1					1		
	18:00	1,513		1					1		
	19:00	1,581		1					1		
	20:00	1,638		1					1		
	21:00	1,730		1					1		
	22:00	1,596		1					1		
	23:00	1,383		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης