

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 29 Ιανουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Α Ρ Χ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 29 Ιανουαρίου 2025	00:00	0,835	1						1		
	01:00	0,752	1								
	02:00	0,734	1								
	03:00	0,733	1								
	04:00	0,775	1								
	05:00	0,800	1								
	06:00	0,854	1								
	07:00	0,841	1								
	08:00	0,834	1								
	09:00	0,813	1								
	10:00	0,778	1								
	11:00	0,804	1								
	12:00	0,813	1								
	13:00	0,818	1								
	14:00	0,875	1						1		
	15:00	0,954	1						1		
	16:00	0,983	1						1		
	17:00	1,217	1						1		
	18:00	1,389	1						1		
	19:00	1,353	1						1		
	20:00	1,293	1						1		
	21:00	1,171	1						1		
	22:00	1,035	1						1		
	23:00	0,938	1						1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 30 Ιανουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η ο ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 30 Ιανουαρίου 2025	00:00	0,832	1						1		
	01:00	0,757	1								
	02:00	0,741	1								
	03:00	0,732	1								
	04:00	0,717	1								
	05:00	0,754	1								
	06:00	0,876	1								
	07:00	0,903	1								
	08:00	0,986	1								
	09:00	0,944	1								
	10:00	0,860	1								
	11:00	1,049	1	1							
	12:00	1,083	1	1							
	13:00	1,108	1	1							
	14:00	1,106	1	1							
	15:00	1,015	1	1							
	16:00	0,982	1	1							
	17:00	1,152	1	1							
	18:00	1,343	1	1							
	19:00	1,365	1	1							
	20:00	1,343	1	1							
	21:00	1,216	1	1							
	22:00	1,068	1	1							
	23:00	0,914	1	1							



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 31 Ιανουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 31 Ιανουαρίου 2025	00:00	0,840	1	1							
	01:00	0,761	1								
	02:00	0,746	1								
	03:00	0,738	1								
	04:00	0,732	1								
	05:00	0,744	1								
	06:00	0,820	1								
	07:00	0,839	1								
	08:00	0,847	1								
	09:00	0,829	1								
	10:00	0,783	1								
	11:00	0,754	1								
	12:00	0,789	1								
	13:00	0,789	1								
	14:00	0,825	1								
	15:00	0,798	1								
	16:00	0,900	1								
	17:00	1,087	1							1	
	18:00	1,300	1							1	
	19:00	1,306	1							1	
	20:00	1,283	1							1	
	21:00	1,189	1							1	
	22:00	1,061	1							1	
	23:00	0,972	1							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 1 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 1 Φεβρουαρίου 2025	00:00	0,925	1							1	
	01:00	0,859		1						1	
	02:00	0,796		1							
	03:00	0,774		1							
	04:00	0,732		1							
	05:00	0,757		1							
	06:00	0,844		1							
	07:00	0,822		1							
	08:00	0,800		1							
	09:00	0,790		1							
	10:00	0,737		1							
	11:00	0,769		1							
	12:00	0,769		1							
	13:00	0,811		1							
	14:00	0,852		1							
	15:00	0,872		1							
	16:00	0,999		1					1		
	17:00	1,139		1					1		
	18:00	1,294		1					1		
	19:00	1,323		1					1		
	20:00	1,293		1					1		
	21:00	1,196		1					1		
	22:00	1,088		1					1		
	23:00	0,994		1					1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 2 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 2 Φεβρουαρίου 2025	00:00	0,886		1					1		
	01:00	0,835		1							
	02:00	0,828		1							
	03:00	0,844		1							
	04:00	0,832		1							
	05:00	0,817		1							
	06:00	0,851		1							
	07:00	0,854		1							
	08:00	0,828		1							
	09:00	0,822		1							
	10:00	0,769		1							
	11:00	0,776		1							
	12:00	0,784	1	1							
	13:00	0,775	1								
	14:00	0,837	1								
	15:00	0,909	1	1							
	16:00	0,980	1	1							
	17:00	1,101	1	1							
	18:00	1,214	1	1							
	19:00	1,210	1	1							
	20:00	1,208	1	1							
	21:00	1,149	1	1							
	22:00	1,033	1	1							
	23:00	0,952	1	1							



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 3 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 3 Φεβρουαρίου 2025	00:00	0,864	1	1							
	01:00	0,776	1								
	02:00	0,754	1								
	03:00	0,744	1								
	04:00	0,749	1								
	05:00	0,801	1								
	06:00	0,883	1								
	07:00	0,916	1								
	08:00	0,908	1								
	09:00	0,827	1								
	10:00	0,756	1								
	11:00	0,725	1								
	12:00	0,754	1								
	13:00	0,878	1								
	14:00	0,883	1	1							
	15:00	0,819	1	1							
	16:00	0,916	1	1							
	17:00	1,055	1	1							
	18:00	1,235	1	1							
	19:00	1,301	1	1							
	20:00	1,305	1	1							
	21:00	1,209	1	1							
	22:00	1,022	1	1							
	23:00	0,921	1	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 4 Φεβρουαρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η ο ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 4 Φεβρουαρίου 2025	00:00	0,859	1	1							
	01:00	0,806	1								
	02:00	0,760	1								
	03:00	0,754	1								
	04:00	0,753	1								
	05:00	0,771	1								
	06:00	0,840	1								
	07:00	0,826	1								
	08:00	0,815	1								
	09:00	0,913	1								
	10:00	0,971	1							1	
	11:00	1,095	1							1	
	12:00	1,189	1							1	
	13:00	1,216	1							1	
	14:00	1,153	1							1	
	15:00	1,137	1							1	
	16:00	1,211	1							1	
	17:00	1,375	1							1	
	18:00	1,465	1							1	
	19:00	1,461	1							1	
	20:00	1,414	1							1	
	21:00	1,311	1							1	
	22:00	1,159	1							1	
	23:00	1,072	1							1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης