

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Πέμπτη, 15 Μαΐου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ε Ρ Ρ Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 15 Μαΐου 2025	00:00	0,913									1
	01:00	0,843									1
	02:00	0,809									1
	03:00	0,806									1
	04:00	0,805									1
	05:00	0,812									1
	06:00	0,858									1
	07:00	0,867									1
	08:00	0,892									1
	09:00	0,905									1
	10:00	0,908									1
	11:00	0,921									1
	12:00	0,916									1
	13:00	0,904									1
	14:00	0,892									1
	15:00	0,898									1
	16:00	0,925									1
	17:00	1,008		1							1
	18:00	1,108		1							1
	19:00	1,197		1							1
	20:00	1,273		1							1
	21:00	1,270		1							1
	22:00	1,167		1							1
	23:00	1,029		1							1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Παρασκευή, 16 Μαΐου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 16 Μαΐου 2025	00:00	0,887									1
	01:00	0,824									1
	02:00	0,788									1
	03:00	0,774									1
	04:00	0,772									1
	05:00	0,789									1
	06:00	0,838									1
	07:00	0,874									1
	08:00	0,912									1
	09:00	0,888									1
	10:00	0,900									1
	11:00	0,912									1
	12:00	0,919									1
	13:00	0,922									1
	14:00	0,922									1
	15:00	0,917									1
	16:00	0,934		1							1
	17:00	0,993		1							1
	18:00	1,079		1							1
	19:00	1,186		1							1
	20:00	1,291		1							1
	21:00	1,298		1							1
	22:00	1,192		1							1
	23:00	1,041		1							1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Σάββατο, 17 Μαΐου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 17 Μαΐου 2025	00:00	0,910									1
	01:00	0,849									1
	02:00	0,810									1
	03:00	0,795									1
	04:00	0,794									1
	05:00	0,813									1
	06:00	0,860									1
	07:00	0,891									1
	08:00	0,917									1
	09:00	0,938		1							1
	10:00	0,959		1							1
	11:00	0,971		1							1
	12:00	0,978		1							1
	13:00	0,975		1							1
	14:00	0,974		1							1
	15:00	0,981		1							1
	16:00	1,001		1							1
	17:00	1,055		1							1
	18:00	1,136		1							1
	19:00	1,234		1							1
	20:00	1,329		1							1
	21:00	1,328		1							1
	22:00	1,217		1							1
	23:00	1,056		1							1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Κυριακή, 18 Μαΐου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 18 Μαΐου 2025	00:00	0,944									1
	01:00	0,874									1
	02:00	0,827									1
	03:00	0,800									1
	04:00	0,794									1
	05:00	0,810									1
	06:00	0,852									1
	07:00	0,882									1
	08:00	0,904									1
	09:00	0,922									1
	10:00	0,956		1							1
	11:00	0,966		1							1
	12:00	0,960		1							1
	13:00	0,941		1							1
	14:00	0,922									1
	15:00	0,901									1
	16:00	0,903									1
	17:00	0,933		1							1
	18:00	0,986		1							1
	19:00	1,065		1							1
	20:00	1,161		1							1
	21:00	1,197		1							1
	22:00	1,115		1							1
	23:00	0,985		1							1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Δευτέρα, 19 Μαΐου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 19 Μαΐου 2025	00:00	0,861									1
	01:00	0,804									1
	02:00	0,769									1
	03:00	0,755									1
	04:00	0,756									1
	05:00	0,774									1
	06:00	0,814									1
	07:00	0,840									1
	08:00	0,853									1
	09:00	0,866									1
	10:00	0,887									1
	11:00	0,893									1
	12:00	0,881									1
	13:00	0,864									1
	14:00	0,856									1
	15:00	0,853									1
	16:00	0,871									1
	17:00	0,910									1
	18:00	0,976		1							1
	19:00	1,068		1							1
	20:00	1,180		1							1
	21:00	1,211		1							1
	22:00	1,115		1							1
	23:00	0,966		1							1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τρίτη, 20 Μαΐου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 20 Μαΐου 2025	00:00	0,825									1
	01:00	0,777									1
	02:00	0,749									1
	03:00	0,744									1
	04:00	0,747									1
	05:00	0,771									1
	06:00	0,815									1
	07:00	0,848									1
	08:00	0,869									1
	09:00	0,880									1
	10:00	0,885									1
	11:00	0,906									1
	12:00	0,898									1
	13:00	0,877									1
	14:00	0,856									1
	15:00	0,860									1
	16:00	0,885									1
	17:00	0,941		1							1
	18:00	1,007		1							1
	19:00	1,093		1							1
	20:00	1,183		1							1
	21:00	1,196		1							1
	22:00	1,095		1							1
	23:00	0,953		1							1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τετάρτη, 21 Μαΐου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 21 Μαΐου 2025	00:00	0,816									1
	01:00	0,769									1
	02:00	0,743									1
	03:00	0,739									1
	04:00	0,744									1
	05:00	0,760									1
	06:00	0,801									1
	07:00	0,840									1
	08:00	0,867									1
	09:00	0,896									1
	10:00	0,930		1							1
	11:00	0,952		1							1
	12:00	0,946		1							1
	13:00	0,934		1							1
	14:00	0,916									1
	15:00	0,909									1
	16:00	0,922									1
	17:00	0,965		1							1
	18:00	1,027		1							1
	19:00	1,109		1							1
	20:00	1,187		1							1
	21:00	1,197		1							1
	22:00	1,106		1							1
	23:00	0,969		1							1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης