

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Πέμπτη, 30 Ιανουαρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ε Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 30 Ιανουαρίου 2025	00:00	0,821		1							
	01:00	0,762		1							
	02:00	0,729		1							
	03:00	0,718		1							
	04:00	0,741		1							
	05:00	0,773		1							
	06:00	0,821		1							
	07:00	0,865		1							
	08:00	0,875		1							
	09:00	0,854		1							
	10:00	0,854		1							
	11:00	0,865		1							
	12:00	0,899		1							
	13:00	0,893		1							
	14:00	0,943		1					1		
	15:00	0,956		1					1		
	16:00	1,012		1					1		
	17:00	1,142		1					1		
	18:00	1,274		1					1		
	19:00	1,275		1					1		
	20:00	1,242		1					1		
	21:00	1,146		1					1		
	22:00	1,027		1					1		
	23:00	0,902		1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Παρασκευή, 31 Ιανουαρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 31 Ιανουαρίου 2025	00:00	0,825		1							
	01:00	0,769		1							
	02:00	0,735		1							
	03:00	0,719		1							
	04:00	0,731		1							
	05:00	0,764		1							
	06:00	0,821		1							
	07:00	0,878		1							
	08:00	0,905		1							
	09:00	0,913		1							
	10:00	0,939		1							
	11:00	0,932		1							
	12:00	0,920		1							
	13:00	0,945		1					1		
	14:00	0,987		1					1		
	15:00	0,971		1					1		
	16:00	1,037		1					1		
	17:00	1,159		1					1		
	18:00	1,315		1					1		
	19:00	1,329		1					1		
	20:00	1,295		1					1		
	21:00	1,200		1					1		
	22:00	1,074		1					1		
	23:00	0,937		1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Σάββατο, 1 Φεβρουαρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 1 Φεβρουαρίου 2025	00:00	0,851		1							
	01:00	0,798		1							
	02:00	0,760		1							
	03:00	0,741		1							
	04:00	0,747		1							
	05:00	0,774		1							
	06:00	0,833		1							
	07:00	0,891		1							
	08:00	0,939		1							
	09:00	0,946		1							
	10:00	0,944		1							
	11:00	0,938		1							
	12:00	0,936		1							
	13:00	0,936		1							
	14:00	0,968		1					1		
	15:00	1,000		1					1		
	16:00	1,065		1					1		
	17:00	1,180		1					1		
	18:00	1,328		1					1		
	19:00	1,368		1					1		
	20:00	1,344		1					1		
	21:00	1,256		1					1		
	22:00	1,133		1					1		
	23:00	0,993		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Κυριακή, 2 Φεβρουαρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 2 Φεβρουαρίου 2025	00:00	0,877		1							
	01:00	0,829		1							
	02:00	0,789		1							
	03:00	0,764		1							
	04:00	0,758		1							
	05:00	0,776		1							
	06:00	0,824		1							
	07:00	0,871		1							
	08:00	0,922		1							
	09:00	0,918		1							
	10:00	0,907		1							
	11:00	0,917		1							
	12:00	0,931		1							
	13:00	0,926		1							
	14:00	0,940		1							
	15:00	0,962		1					1		
	16:00	1,018		1					1		
	17:00	1,124		1					1		
	18:00	1,255		1					1		
	19:00	1,282		1					1		
	20:00	1,253		1					1		
	21:00	1,168		1					1		
	22:00	1,064		1					1		
	23:00	0,941		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Δευτέρα, 3 Φεβρουαρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 3 Φεβρουαρίου 2025	00:00	0,827		1							
	01:00	0,779		1							
	02:00	0,747		1							
	03:00	0,731		1							
	04:00	0,737		1							
	05:00	0,767		1							
	06:00	0,828		1							
	07:00	0,880		1							
	08:00	0,926		1							
	09:00	0,917		1							
	10:00	0,954		1					1		
	11:00	0,976		1					1		
	12:00	0,991		1					1		
	13:00	1,027		1					1		
	14:00	1,064		1					1		
	15:00	1,087		1					1		
	16:00	1,133		1					1		
	17:00	1,197		1					1		
	18:00	1,294		1					1		
	19:00	1,313		1					1		
	20:00	1,282		1					1		
	21:00	1,217		1					1		
	22:00	1,113		1					1		
	23:00	0,983		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τρίτη, 4 Φεβρουαρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 4 Φεβρουαρίου 2025	00:00	0,829		1							
	01:00	0,780		1							
	02:00	0,747		1							
	03:00	0,736		1							
	04:00	0,745		1							
	05:00	0,781		1							
	06:00	0,852		1							
	07:00	0,917		1							
	08:00	0,966		1					1		
	09:00	0,959		1					1		
	10:00	0,942		1					1		
	11:00	0,949		1					1		
	12:00	0,952		1					1		
	13:00	0,970		1					1		
	14:00	1,007		1					1		
	15:00	1,050		1					1		
	16:00	1,130		1					1		
	17:00	1,248		1					1		
	18:00	1,374		1					1		
	19:00	1,384		1					1		
	20:00	1,350		1					1		
	21:00	1,271		1					1		
	22:00	1,153		1					1		
	23:00	1,008		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τετάρτη, 5 Φεβρουαρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	0,400	0,400	0,400	0,400	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 5 Φεβρουαρίου 2025	00:00	0,835		1							
	01:00	0,789		1							
	02:00	0,755		1							
	03:00	0,742		1							
	04:00	0,754		1							
	05:00	0,793		1							
	06:00	0,862		1							
	07:00	0,936		1							
	08:00	1,004		1					1		
	09:00	1,023		1					1		
	10:00	1,027		1					1		
	11:00	1,019		1					1		
	12:00	1,008		1					1		
	13:00	1,018		1					1		
	14:00	1,055		1					1		
	15:00	1,091		1					1		
	16:00	1,174		1					1		
	17:00	1,300		1					1		
	18:00	1,420		1					1		
	19:00	1,430		1					1		
	20:00	1,393		1					1		
	21:00	1,298		1					1		
	22:00	1,168		1					1		
	23:00	1,010		1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης