

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Σάββατο, 3 Μαΐου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η μ ε ρ α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Σάββατο, 3 Μαΐου 2025	00:00	0,391	1			1				
	01:00	0,373	1			1				
	02:00	0,353	1			1				
	03:00	0,342	1			1				
	04:00	0,335	1			1				
	05:00	0,334	1			1				
	06:00	0,347	1			1				
	07:00	0,374	1			1				
	08:00	0,403	1			1				
	09:00	0,426	1			1				
	10:00	0,432	1			1				
	11:00	0,427	1			1				
	12:00	0,423	1			1				
	13:00	0,435	1			1				
	14:00	0,436	1			1				
	15:00	0,446	1			1				
	16:00	0,449	1			1				
	17:00	0,460	1			1				
	18:00	0,473	1			1				
	19:00	0,496	1			1				
	20:00	0,508	1			1				
	21:00	0,490	1			1				
	22:00	0,455	1			1				
	23:00	0,406	1			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 4 Μαΐου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Κυριακή, 4 Μαΐου 2025	00:00	0,381	1			1				
	01:00	0,365	1			1				
	02:00	0,349	1			1				
	03:00	0,335	1			1				
	04:00	0,320	1			1				
	05:00	0,318	1			1				
	06:00	0,327	1			1				
	07:00	0,352	1			1				
	08:00	0,386	1			1				
	09:00	0,416	1			1				
	10:00	0,418	1			1				
	11:00	0,409	1			1				
	12:00	0,413	1			1				
	13:00	0,418	1			1				
	14:00	0,424	1			1				
	15:00	0,425	1			1				
	16:00	0,434	1			1				
	17:00	0,442	1			1				
	18:00	0,458	1			1				
	19:00	0,478	1			1				
	20:00	0,491	1			1				
	21:00	0,479	1			1				
	22:00	0,442	1			1				
	23:00	0,396	1			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 5 Μαΐου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Δευτέρα, 5 Μαΐου 2025	00:00	0,341	1			1				
	01:00	0,330	1			1				
	02:00	0,321	1			1				
	03:00	0,312	1			1				
	04:00	0,306	1			1				
	05:00	0,309	1			1				
	06:00	0,327	1			1				
	07:00	0,361	1			1				
	08:00	0,384	1			1				
	09:00	0,386	1			1				
	10:00	0,379	1			1				
	11:00	0,377	1			1				
	12:00	0,384	1			1				
	13:00	0,393	1			1				
	14:00	0,406	1			1				
	15:00	0,411	1			1				
	16:00	0,415	1			1				
	17:00	0,428	1			1				
	18:00	0,457	1			1				
	19:00	0,479	1			1				
	20:00	0,489	1			1				
	21:00	0,472	1			1				
	22:00	0,438	1			1				
	23:00	0,390	1			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 6 Μαΐου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Τρίτη, 6 Μαΐου 2025	00:00	0,356	1			1				
	01:00	0,344	1			1				
	02:00	0,335	1			1				
	03:00	0,330	1			1				
	04:00	0,325	1			1				
	05:00	0,327	1			1				
	06:00	0,344	1			1				
	07:00	0,369	1			1				
	08:00	0,393	1			1				
	09:00	0,409	1			1				
	10:00	0,416	1			1				
	11:00	0,424	1			1				
	12:00	0,430	1			1				
	13:00	0,442	1			1				
	14:00	0,443	1			1				
	15:00	0,437	1			1				
	16:00	0,436	1			1				
	17:00	0,440	1			1				
	18:00	0,460	1			1				
	19:00	0,476	1			1				
	20:00	0,484	1			1				
	21:00	0,468	1			1				
	22:00	0,433	1			1				
	23:00	0,385	1			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 7 Μαΐου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Τετάρτη, 7 Μαΐου 2025	00:00	0,366	1			1				
	01:00	0,358	1			1				
	02:00	0,351	1			1				
	03:00	0,339	1			1				
	04:00	0,335	1			1				
	05:00	0,336	1			1				
	06:00	0,351	1			1				
	07:00	0,375	1			1				
	08:00	0,400	1			1				
	09:00	0,413	1			1				
	10:00	0,411	1			1				
	11:00	0,410	1			1				
	12:00	0,429	1			1				
	13:00	0,456	1			1				
	14:00	0,460	1			1				
	15:00	0,460	1			1				
	16:00	0,462	1			1				
	17:00	0,467	1			1				
	18:00	0,479	1			1				
	19:00	0,496	1			1				
	20:00	0,501	1			1				
	21:00	0,482	1			1				
	22:00	0,447	1			1				
	23:00	0,399	1			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 8 Μαΐου 2025			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Ρ Ρ Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Πέμπτη, 8 Μαΐου 2025	00:00	0,382	1			1				
	01:00	0,366	1			1				
	02:00	0,354	1			1				
	03:00	0,339	1			1				
	04:00	0,335	1			1				
	05:00	0,338	1			1				
	06:00	0,347	1			1				
	07:00	0,377	1			1				
	08:00	0,410	1			1				
	09:00	0,437	1			1				
	10:00	0,456	1			1				
	11:00	0,460	1			1				
	12:00	0,460	1			1				
	13:00	0,468	1			1				
	14:00	0,471	1			1				
	15:00	0,469	1			1				
	16:00	0,465	1			1				
	17:00	0,469	1			1				
	18:00	0,477	1			1				
	19:00	0,496	1			1				
	20:00	0,500	1			1				
	21:00	0,482	1			1				
	22:00	0,449	1			1				
	23:00	0,397	1			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης