

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Σάββατο, 15 Ιανουάριος 2022		Προτεινόμενος ΗΕΠ Θήρας																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		15,41	14,13	13,33	12,93	12,90	13,05	14,16	15,23	16,54	17,98	19,48	20,42	21,57	21,79	21,73	21,46	21,92	23,80	24,15	24,26	22,46	21,42	19,84	18,17	448,12	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G2 (WARTSILA W18V32)	7,3																									Διαθέσιμη	
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	-																										Σε βλάβη
G29 (Α/Σ GE10B1)	-																										Σε βλάβη
11 ΦΟΡΗΤΑ Η/Ζ	9													2	2	2	2	2	5	5	5	3	2				Διαθέσιμη

[illegible]

[illegible]

[illegible]

Τετάρτη, 19 Ιανουάριος 2022		Προτεινόμενος ΗΕΠ Θήρας																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		15,74	14,34	13,57	13,14	13,11	13,26	14,45	15,56	16,62	18,18	18,82	19,11	19,64	19,85	20,30	20,77	21,77	25,27	24,76	24,04	21,63	20,75	19,40	17,84	441,93	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G2 (WARTSILA W18V32)	-																									Σε βλάβη	
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (WARTSILA 12V32D)	3,5										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (WARTSILA 12V32D)	3,5	1	1					1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G30 (Α/Σ TURBOMACH)	-																									Σε βλάβη	
G29 (Α/Σ GE10B1)	-																									Σε βλάβη	
9 ΦΟΡΗΤΑ Η/Ζ	9																	1	5	5	4	1				Διαθέσιμη	

Πέμπτη, 20 Ιανουάριος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		15,88	14,54	13,74	13,28	13,23	13,39	14,60	15,93	16,75	18,64	19,84	20,41	20,86	21,15	21,38	21,56	22,15	24,93	24,98	24,70	22,63	21,51	19,78	18,23	454,05
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	-																									Σε βλάβη
G4 (WARTSILA 12V32D)	3,5												1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	-																									Σε βλάβη
G29 (Α/Σ GE10B1)	-																									Σε βλάβη
9 ΦΟΡΗΤΑ Η/Ζ	9																		2	2	2					Διαθέσιμη

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Παρασκευή, 28 Ιανουάριος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		17,84	16,38	15,45	15,04	14,89	14,99	15,81	17,91	19,72	21,70	24,11	25,01	25,96	25,52	25,22	24,99	25,25	26,06	26,67	26,31	25,13	24,14	22,38	20,39	516,89
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5											1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	-																									Σε βλάβη
G29 (Α/Σ GE10B1)	-																									Σε βλάβη
9 ΦΟΡΗΤΑ Η/Ζ	9																									Διαθέσιμη

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Τετάρτη, 16 Μάρτιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		19,55	17,89	17,10	16,44	16,23	16,66	17,89	19,98	21,56	22,49	22,40	22,38	22,46	22,67	23,29	24,86	26,59	27,88	29,59	29,59	27,39	27,14	25,93	22,13	540,11
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (A/Σ GE10B1)	-																									Σε βλάβη
10 ΦΟΡΗΤΑ Η/Ζ	11																2	4	6	8	8	6	5	4		Διαθέσιμη

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Τρίτη, 15 Μάρτιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		19,55	17,80	16,88	16,30	16,27	16,49	17,31	18,54	20,73	23,07	23,83	25,82	25,84	26,78	26,37	26,66	28,09	28,05	29,67	30,22	29,17	27,42	25,28	23,12	559,26
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (A/Σ GE10B1)	-																									Σε βλάβη
10 ΦΟΡΗΤΑ Η/Ζ	11											1	3	3	4	4	4	6	6	7	8	7	5	2		Διαθέσιμη

Παρασκευή, 1 Απρίλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		18,64	16,93	16,12	15,50	15,18	15,40	16,24	17,18	18,09	18,86	19,10	19,02	18,85	18,78	18,68	18,78	19,39	19,86	20,87	22,33	23,53	23,22	21,98	20,51	453,03	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (WARTSILA 12V32D)	3,5	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (WARTSILA 12V32D)	3,5																			1	1	1	1	1	1	Διαθέσιμη	
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση	
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G30 (Α/Σ TURBOMACH)	12																									Διαθέσιμη	
G29 (Α/Σ GE10B1)	-																									Σε βλάβη	
12 ΦΟΡΗΤΑ Η/Ζ	13,2																									Διαθέσιμη	

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Σάββατο, 9 Απρίλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		21,52	20,14	19,13	18,61	18,32	18,62	19,74	21,63	23,35	23,80	24,11	24,04	23,94	24,80	25,62	25,34	25,23	25,44	25,77	26,34	27,28	26,21	25,33	23,32	557,65
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (A/Σ GE10B1)	-																									Σε βλάβη
12 ΦΟΡΗΤΑ Η/Ζ	13,2									1	1	1	1	2	3	3	3	3	3	3	4	5	4	3		Διαθέσιμη

Κυριακή, 10 Απρίλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		20,80	19,84	18,96	18,37	18,08	18,42	19,41	21,03	22,69	23,19	23,42	23,51	23,60	25,08	25,42	25,07	25,02	25,06	25,33	25,95	26,76	25,75	24,94	23,12	548,83
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (A/Σ GE10B1)	-																									Σε βλάβη
12 ΦΟΡΗΤΑ Η/Ζ	13,2											1	1	1	3	3	3	3	3	3	4	5	4	3		Διαθέσιμη

Δευτέρα, 11 Απρίλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		21,45	20,16	19,22	18,68	18,40	18,76	19,89	21,67	23,47	24,15	24,22	24,30	24,26	25,31	25,66	25,44	25,57	25,73	26,06	26,72	27,35	26,82	25,86	24,18	563,33	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (WARTSILA 12V32D)	3,5	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση	
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G30 (Α/Σ TURBOMACH)	12																									Διαθέσιμη	
G29 (Α/Σ GE10B1)	-																									Σε βλάβη	
12 ΦΟΡΗΤΑ Η/Ζ	13,2										1	1	1	1	3	3	3	3	3	4	5	5	5	4	2	Διαθέσιμη	

Τρίτη, 12 Απρίλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		21,15	19,69	18,55	17,82	17,59	17,97	18,90	20,56	20,97	20,80	20,65	20,30	20,11	23,44	23,69	23,74	23,85	24,16	23,64	23,78	25,17	24,26	24,00	22,53	517,31
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (A/Σ GE10B1)	-																									Σε βλάβη
12 ΦΟΡΗΤΑ Η/Ζ	13,2	1													1	1	1	1	1	1	1	2	1	1		Διαθέσιμη

Τετάρτη, 13 Απρίλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		21,18	19,55	18,54	18,08	17,79	18,03	19,64	20,93	23,25	24,78	25,63	26,13	26,06	25,95	25,53	24,83	25,15	25,50	26,33	27,81	29,66	28,49	26,22	23,62	568,69
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (A/Σ GE10B1)	-																									Σε βλάβη
12 ΦΟΡΗΤΑ Η/Ζ	13,2										2	3	4	4	4	3	3	3	3	4	6	8	7	4	1	Διαθέσιμη

[illegible]

[illegible]

[illegible]

Κυριακή, 17 Απρίλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		22,97	21,27	20,15	19,66	19,36	19,61	20,78	22,98	24,86	25,62	26,63	27,25	26,90	26,61	26,45	26,17	26,11	26,37	27,35	28,88	31,53	31,22	29,28	26,33	604,33	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1													1	1	1	1	Διαθέσιμη	
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση	
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G30 (Α/Σ TURBOMACH)	12									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G29 (Α/Σ GE10B1)	-																									Σε βλάβη	
12 ΦΟΡΗΤΑ Η/Ζ	13,2																									Διαθέσιμη	

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Σάββατο, 28 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		29,71	27,88	26,29	25,75	24,83	25,13	26,69	33,38	36,32	36,61	37,17	37,63	39,00	38,78	38,50	37,79	37,68	37,72	39,46	41,30	41,20	38,94	36,26	31,34	825,36
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	-																									Σε βλάβη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (A/Σ GE10B1)	10,647	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2								1	4	5	5	6	8	7	7	6	6	6	8	10	10	7	4		Διαθέσιμη

Κυριακή, 29 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		29,12	27,33	25,77	25,24	24,33	24,63	26,16	32,72	35,60	35,89	36,43	36,88	38,23	38,02	37,74	37,05	36,93	36,97	38,68	40,48	40,38	38,17	35,54	30,72	809,02
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	-																									Σε βλάβη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (A/Σ GE10B1)	10,647	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2									3	4	4	5	7	6	6	5	5	5	7	9	9	6	3		Διαθέσιμη

Δευτέρα, 30 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		30,01	28,16	26,55	26,01	25,07	25,38	26,95	33,71	36,68	36,98	37,54	38,00	39,39	39,17	38,88	38,17	38,05	38,09	39,85	41,71	41,61	39,33	36,62	31,65	833,54
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	-																									Σε βλάβη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (A/Σ GE10B1)	10,647	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2								1	5	5	6	6	8	8	7	6	6	6	9	11	11	8	5		Διαθέσιμη

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Σάββατο, 7 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		29,85	27,33	25,72	25,19	24,90	25,13	26,15	28,90	32,73	34,64	34,64	34,44	34,37	34,31	33,60	33,08	32,97	33,30	34,14	34,82	35,79	35,53	33,41	32,00	756,93
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	-																									Σε βλάβη
10 ΦΟΡΗΤΑ Η/Ζ	10										2	2	2	2	2	1	1	1	1	2	3	4	4	1		Διαθέσιμη

Κυριακή, 8 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		29,94	27,45	25,99	25,22	25,08	25,34	26,22	28,34	31,26	33,20	34,31	34,29	34,21	33,98	33,52	32,90	32,76	33,17	33,98	34,66	35,40	35,09	33,59	32,33	752,26
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	-																									Σε βλάβη
10 ΦΟΡΗΤΑ Η/Ζ	10										1	2	2	2	2	1	1	1	1	2	2	3	3	1		Διαθέσιμη

Δευτέρα, 9 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		30,26	27,63	26,23	25,58	25,37	25,60	26,60	28,63	32,12	34,56	34,93	35,17	35,06	35,05	34,65	33,86	33,61	34,06	34,92	35,68	36,42	36,08	34,52	32,88	769,47
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	-																									Σε βλάβη
10 ΦΟΡΗΤΑ Η/Ζ	10										2	3	3	3	3	2	1	1	2	3	4	5	4	2		Διαθέσιμη

Τρίτη, 10 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		28,50	26,25	24,92	24,12	24,07	24,20	25,51	29,43	32,73	33,92	33,87	33,67	33,61	33,52	33,15	32,71	32,25	33,00	34,12	35,11	37,12	35,64	31,61	29,75	742,78
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	-																									Σε βλάβη
10 ΦΟΡΗΤΑ Η/Ζ	10										1	1	1	1	1	1	1	1	1	2	3	6	4			Διαθέσιμη

Τετάρτη, 11 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		28,29	26,00	24,72	23,87	23,78	24,26	25,37	28,54	32,06	33,42	33,51	33,30	33,24	33,22	33,18	32,54	32,11	33,09	34,02	35,31	37,24	35,64	31,75	29,74	738,21
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	-																									Σε βλάβη
10 ΦΟΡΗΤΑ Η/Ζ	10																			1	3	6	4			Διαθέσιμη

Πέμπτη, 12 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		28,50	26,19	24,84	24,08	23,88	24,34	25,50	28,75	32,14	33,85	33,56	33,37	33,31	33,52	33,32	32,90	32,65	33,39	34,46	35,55	37,23	36,01	32,07	29,82	743,24
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	-																									Σε βλάβη
10 ΦΟΡΗΤΑ Η/Ζ	10										1	1	1	1	1	1	1	1	1	2	4	6	5			Διαθέσιμη

Παρασκευή, 13 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		28,89	26,51	25,21	24,45	24,27	24,67	25,82	29,15	32,44	33,88	33,82	33,77	33,68	33,75	33,56	33,25	33,05	33,34	34,13	35,49	37,32	35,90	32,49	30,41	749,25
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	-																									Σε βλάβη
10 ΦΟΡΗΤΑ Η/Ζ	10										1	1	1	1	1	1	1	1	1	2	4	6	4			Διαθέσιμη

Σάββατο, 14 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		28,25	25,91	24,76	24,08	23,97	24,09	25,41	29,38	32,54	33,29	33,62	33,35	33,03	32,89	32,83	32,16	31,85	31,92	32,70	34,38	36,65	34,55	31,61	29,80	733,04
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	10,647																									Διαθέσιμη
10 ΦΟΡΗΤΑ Η/Ζ	11																				2	5	2			Διαθέσιμη

Κυριακή, 15 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		28,96	26,61	25,24	24,56	24,21	24,77	25,95	29,45	32,82	34,57	34,18	33,07	32,94	32,85	32,43	31,76	31,68	32,84	34,37	35,88	37,33	36,32	32,70	30,56	746,08
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	10,647																									Διαθέσιμη
10 ΦΟΡΗΤΑ Η/Ζ	11										2	2								2	4	6	5			Διαθέσιμη

Δευτέρα, 16 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		29,16	26,82	25,44	24,71	24,44	24,96	26,16	29,67	33,26	34,88	34,49	33,69	33,40	33,29	33,07	32,57	32,26	33,21	34,82	36,28	37,70	36,67	32,89	30,74	754,59
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	-																									Σε συντήρηση
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	10,647																									Διαθέσιμη
10 ΦΟΡΗΤΑ Η/Ζ	11									1	3	2	1	1	1	1	1	1	1	3	5	6	5			Διαθέσιμη

Τρίτη, 17 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		29,00	26,33	25,29	24,51	24,34	24,86	26,18	29,85	32,85	34,73	34,62	34,43	34,33	34,31	34,19	33,58	33,17	33,95	35,12	36,37	38,27	36,76	32,74	30,92	760,69
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	10,647																									Διαθέσιμη
10 ΦΟΡΗΤΑ Η/Ζ	11																				1	3	1			Διαθέσιμη

Τετάρτη, 18 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		29,05	26,31	25,45	24,62	24,29	24,86	26,32	30,99	32,64	34,60	35,44	35,30	35,22	35,12	34,67	34,09	33,76	34,29	35,85	36,84	38,91	37,22	33,04	31,80	770,70
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	10,647																									Διαθέσιμη
10 ΦΟΡΗΤΑ Η/Ζ	11																				1	4	2			Διαθέσιμη

Πέμπτη, 19 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		28,02	25,80	24,61	23,77	23,49	23,95	25,26	29,13	31,72	33,62	34,02	34,05	34,08	34,21	33,72	32,98	32,57	33,25	34,57	35,49	37,38	35,73	31,94	30,21	743,57
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	-																									Σε βλάβη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	10,647																									Διαθέσιμη
10 ΦΟΡΗΤΑ Η/Ζ	11										1	2	2	2	2	2	1	1	1	1	2	4	6	4		Διαθέσιμη

Παρασκευή, 20 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		27,86	25,87	24,70	23,79	23,44	23,70	24,80	30,10	32,34	33,44	34,91	35,31	35,64	36,11	34,90	34,01	33,85	34,52	35,66	36,39	38,45	36,21	32,47	30,23	758,69
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	-																									Σε βλάβη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	10,647																									Διαθέσιμη
11 ΦΟΡΗΤΑ Η/Ζ	12,1										1	3	3	4	4	3	2	2	2	4	5	7	4			Διαθέσιμη

Σάββατο, 21 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		30,26	27,88	26,72	25,84	25,60	26,12	27,70	32,79	35,11	36,84	38,06	38,76	39,19	39,26	37,13	36,42	36,89	37,34	38,61	39,76	41,91	40,32	35,52	33,10	827,15
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	-																									Σε βλάβη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	10,647																									Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2									2	5	6	7	8	8	5	5	5	5	7	9	11	9	3		Διαθέσιμη

Κυριακή, 22 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		30,32	27,94	26,70	25,93	25,62	26,01	27,25	32,52	35,35	36,66	37,87	38,44	38,83	38,88	36,95	36,08	36,26	37,07	38,56	39,34	41,46	39,89	35,55	32,70	822,19
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	-																									Σε βλάβη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	10,647																									Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2									3	5	6	7	7	7	5	5	5	5	7	8	11	9	4		Διαθέσιμη

Δευτέρα, 23 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		30,13	27,57	26,51	25,86	25,75	26,32	27,66	32,99	35,77	36,89	38,08	38,96	39,32	38,91	36,00	35,50	36,64	37,22	38,59	39,68	42,15	41,16	35,78	32,75	826,18
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	-																									Σε βλάβη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	10,647																									Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2									4	5	6	7	8	8	4	4	4	5	7	8	11	10	3		Διαθέσιμη

Τρίτη, 24 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		29,24	26,95	25,82	25,13	24,95	25,33	26,80	31,97	33,93	35,43	36,24	36,05	35,69	35,44	33,79	33,35	33,56	34,08	35,52	36,38	38,37	36,90	32,96	30,88	774,73
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	-																									Σε βλάβη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	10,647																									Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2								1	3	4	4	4	4	3	1	1	1	1	3	4	7	5			Διαθέσιμη

Τετάρτη, 25 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		27,60	25,48	24,35	23,65	23,39	23,62	24,72	29,60	32,11	33,61	34,41	33,32	33,02	32,83	31,65	31,12	30,80	31,35	32,87	33,76	35,59	34,40	30,80	28,71	722,75
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	-																									Σε βλάβη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (Α/Σ GE10B1)	10,647	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2									1	3	4	3	2	2					2	3	6	4			Διαθέσιμη

Πέμπτη, 26 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		23,18	20,98	20,02	19,39	19,38	19,68	20,34	25,25	28,16	29,71	30,16	30,13	30,10	29,99	29,30	28,56	28,01	29,02	30,64	31,07	32,73	32,50	28,18	25,81	642,29
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5										1	1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
G4 (WARTSILA 12V32D)	-																									Σε βλάβη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (A/Σ GE10B1)	10,647	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2																					2	2			Διαθέσιμη

Παρασκευή, 27 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		29,71	27,88	26,29	25,75	24,83	25,13	26,69	33,38	36,32	36,61	37,17	37,63	39,00	38,78	38,50	37,79	37,68	37,72	39,46	41,30	41,20	38,94	36,26	31,34	825,36
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	-																									Σε βλάβη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (A/Σ GE10B1)	10,647	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2								1	4	4	5	5	7	7	6	6	5	5	7	9	9	7	4		Διαθέσιμη

Τρίτη, 31 Μάιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		30,31	28,23	26,76	26,21	25,44	25,12	26,97	31,15	34,85	37,26	38,87	40,28	41,16	41,79	41,00	40,09	40,05	40,30	41,17	41,64	41,69	39,94	38,44	35,30	854,03
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (Α/Σ GE10B1)	10,647	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2									1	4	6	8	9	10	9	8	8	8	9	9	9	8	6	2	Διαθέσιμη

Τετάρτη, 1 Ιούnius 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		30,99	28,61	27,20	26,64	25,97	25,47	27,11	30,45	35,13	37,58	39,40	41,11	41,45	41,69	41,19	40,65	40,60	40,94	41,44	41,69	41,83	40,26	39,26	36,29	862,94
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (A/Σ GE10B1)	10,647	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2									1	4	6	9	9	9	9	8	8	8	9	9	9	8	6	2	Διαθέσιμη

Πέμπτη, 2 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		31,78	29,44	27,94	27,32	26,57	26,51	27,82	32,26	36,34	38,63	39,60	40,69	41,03	41,15	40,75	40,25	40,16	40,42	41,33	42,10	42,19	41,26	39,28	35,98	870,82
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (Α/Σ GE10B1)	10,647	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2								1	3	6	7	9	9	9	9	8	8	8	9	10	10	9	7	3	Διαθέσιμη

Παρασκευή, 3 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		32,44	29,99	28,54	27,65	26,86	26,84	28,39	32,01	36,95	40,30	40,82	41,25	41,61	42,25	42,90	42,72	42,33	42,08	42,84	43,00	42,80	40,07	39,57	37,14	891,37
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12																									Διαθέσιμη
G29 (Α/Σ GE10B1)	10,647	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2									3	8	8	9	9	10	10	10	10	10	10	10	10	8	7	4	Διαθέσιμη

Σάββατο, 4 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		32,80	30,33	28,93	27,88	27,21	27,18	28,55	32,26	37,42	40,32	40,90	41,21	41,41	41,96	42,67	42,95	42,78	42,85	43,88	44,30	43,74	41,10	39,90	36,81	899,32
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12												1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	10,647	1	1	1	1	1	1	1	1	1	1															Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2									4	8	9	7	7	8	8	9	9	9	10	10	10	7	5	1	Διαθέσιμη

Κυριακή, 5 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		32,69	30,23	28,84	28,02	27,33	27,02	28,50	31,84	36,27	39,98	40,93	42,11	42,35	42,99	42,74	42,33	42,14	42,26	43,11	43,56	43,33	41,42	40,17	37,08	897,23
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	12												1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	10,647	1	1	1	1	1	1	1	1	1	1															Διαθέσιμη
12 ΦΟΡΗΤΑ Η/Ζ	13,2									3	7	8	8	8	9	9	8	8	8	9	9	9	7	5	1	Διαθέσιμη

[illegible]

[illegible]

Τετάρτη, 8 Ιούnius 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		34,18	31,35	30,15	29,21	28,48	28,48	28,89	31,95	35,17	38,65	40,43	42,39	43,17	43,23	43,18	42,53	42,86	43,95	44,34	45,03	46,08	46,10	41,13	36,94	917,87
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	12																		1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	10,647	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
13 ΦΟΡΗΤΑ Η/Ζ	14,3									1	6	8	10	11	11	11	11	11	1	1	1	2	2	6	1	Διαθέσιμη

Πέμπτη, 9 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		33,42	30,96	29,66	28,73	28,09	28,07	28,54	31,91	35,65	38,74	40,05	41,37	41,98	42,51	42,07	41,28	41,53	42,05	42,94	43,31	44,43	44,73	39,92	35,24	897,18	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G30 (Α/Σ TURBOMACH)	12																			1	1	1	1	1	1	Διαθέσιμη	
G29 (Α/Σ GE10B1)	10,647	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη	
13 ΦΟΡΗΤΑ Η/Ζ	14,3									2	6	7	9	10	11	10	9	9	10							Διαθέσιμη	

Σάββατο, 11 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		32,21	31,12	29,73	28,67	27,85	28,01	30,08	34,58	37,19	39,48	42,02	42,23	42,18	43,21	41,55	40,57	41,57	40,75	40,78	43,05	45,94	46,75	40,73	38,51	908,75
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
16 ΦΟΡΗΤΑ Η/Ζ	15											1	1	1	2						2	5	6			Διαθέσιμη

Κυριακή, 12 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		32,14	30,62	29,80	28,75	27,95	28,07	27,43	30,14	31,57	35,82	38,80	40,64	41,77	43,31	42,63	40,91	41,02	40,50	40,84	42,99	43,26	43,72	40,88	37,59	881,12
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
16 ΦΟΡΗΤΑ Η/Ζ	15														2	1						2	2	3		Διαθέσιμη

Δευτέρα, 13 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		32,28	31,20	29,68	28,64	28,04	27,98	29,32	34,38	37,17	39,10	41,59	41,72	41,62	43,04	42,53	41,46	41,14	40,31	40,47	42,63	42,66	42,15	39,60	37,80	896,51
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
16 ΦΟΡΗΤΑ Η/Ζ	15														2	1						1	1	1		Διαθέσιμη

Τρίτη, 14 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		32,98	32,13	30,41	29,40	28,71	28,74	29,96	34,85	37,88	40,16	42,20	42,02	42,27	43,89	43,22	42,13	42,07	41,06	40,86	43,08	43,28	43,67	41,24	37,72	913,92
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
16 ΦΟΡΗΤΑ Η/Ζ	15											1	1	1	3	2	1	1			2	2	3			Διαθέσιμη

Τετάρτη, 15 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		34,21	31,47	30,10	29,11	28,43	28,36	29,90	32,31	35,40	39,38	41,70	42,55	43,01	43,80	43,20	42,26	42,44	42,76	43,57	44,04	44,80	45,08	40,91	37,70	916,48
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ Η/Ζ	16,5											1	2	3	3	3	2	2	2	3	4	5	5	1		Διαθέσιμη

Πέμπτη, 16 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		34,92	32,17	30,48	29,50	28,83	28,73	31,26	33,75	37,10	41,09	43,05	43,52	43,90	44,42	44,06	43,34	43,59	44,17	45,16	45,21	45,58	45,26	41,35	38,95	939,37
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ Η/Ζ	16,5								1	5	9	2	2	2	2	2	2	2	2	3	3	4	4			Διαθέσιμη

Παρασκευή, 17 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		35,68	32,86	30,73	29,90	29,26	29,05	31,80	33,94	37,07	41,63	44,14	44,62	45,08	45,59	45,55	44,53	43,73	43,55	44,19	45,78	45,62	45,50	41,64	39,34	950,77
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5	1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ Η/Ζ	16,5								1	5	9	3	3	3	3	3	2	2	2	2	4	4	4			Διαθέσιμη

Σάββατο, 18 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		36,11	33,36	31,21	30,38	29,77	29,58	32,49	35,92	38,83	43,00	44,07	44,44	45,40	45,94	46,04	44,81	43,17	43,52	44,36	46,20	45,90	45,53	41,97	40,14	962,15
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5	1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ Η/Ζ	15								3	6	2	2	2	3	4	4	3	1	1	2	4	4	4			Διαθέσιμη

Κυριακή, 19 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		35,83	33,14	31,25	30,26	29,66	29,46	31,93	35,42	38,97	42,36	43,69	44,09	44,93	45,52	45,66	44,60	44,38	44,97	45,85	45,87	45,63	45,31	42,10	40,35	961,23
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ Η/Ζ	15								2	6	1	1	1	2	3	3	2	2	2	3	3	3	3			Διαθέσιμη

Δευτέρα, 20 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		35,94	33,27	31,35	30,42	29,82	29,56	31,90	36,04	39,09	43,19	43,94	44,40	45,46	45,89	46,03	44,91	44,17	44,66	45,48	46,01	45,54	44,96	42,02	40,35	964,40
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ Η/Ζ	15								3	6	2	2	2	3	4	4	3	3	3	3	3	3	3			Διαθέσιμη

Τρίτη, 21 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		36,23	33,42	31,51	30,65	30,07	29,89	32,02	35,60	38,75	42,79	44,03	44,47	45,23	45,46	45,77	44,70	43,91	44,68	45,62	46,04	45,67	45,18	42,22	40,36	964,27
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5	1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ Η/Ζ	15								2	6	2	2	2	3	4	4	3	3	3	4	4	4	3			Διαθέσιμη

Τετάρτη, 22 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		35,17	32,49	30,98	30,14	29,63	29,39	30,30	36,12	38,28	40,82	42,39	42,94	43,99	44,19	44,29	43,31	42,48	44,31	45,35	44,31	43,50	42,43	40,91	39,49	937,20
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ Η/Ζ	15											2	3	4	4	4	3	2	4	5	4	3	2	1		Διαθέσιμη

Πέμπτη, 23 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		35,10	32,25	30,25	29,51	28,88	28,67	29,38	35,74	37,89	38,63	41,33	41,81	44,08	44,22	44,85	44,38	44,27	45,95	45,90	46,00	45,18	43,71	41,36	40,36	939,68
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ Η/Ζ	15													2	2	3	2	2	4	4	4	4	2			Διαθέσιμη

Παρασκευή, 24 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		36,00	33,18	31,32	30,09	29,37	29,27	30,41	35,23	38,75	44,19	45,14	45,30	47,12	48,55	48,77	48,18	47,85	49,56	49,64	48,79	48,10	48,72	45,54	40,58	999,65
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ Η/Ζ	15										4	5	5	7	9	9	9	8	10	10	9	8	9	6		Διαθέσιμη

Σάββατο, 25 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		36,14	33,43	31,73	30,65	29,97	29,81	30,89	35,08	40,00	44,10	44,14	45,59	46,89	48,37	47,93	46,74	46,78	48,07	48,32	48,14	48,02	48,52	45,44	41,86	996,60
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ Η/Ζ	15										4	4	6	7	9	8	7	7	8	9	9	8	9	6	2	Διαθέσιμη

Κυριακή, 26 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		35,61	32,78	31,00	29,85	29,21	29,14	30,10	35,69	39,74	43,90	43,96	44,15	45,61	47,38	47,05	46,07	45,63	46,75	47,48	46,83	46,37	46,97	45,02	40,73	977,01
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ Η/Ζ	15										4	4	4	6	8	7	6	6	7	8	7	7	7	5		Διαθέσιμη

Δευτέρα, 27 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		36,35	33,50	31,63	30,39	29,67	29,56	30,71	35,58	39,14	44,63	45,58	45,75	47,59	50,04	49,25	48,66	48,32	50,05	50,13	49,28	48,57	49,20	45,99	40,98	1.010,56
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ Η/Ζ	15										5	6	6	8	11	10	9	9	11	11	10	9	10	6	1	Διαθέσιμη

Τρίτη, 28 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		37,95	35,81	32,75	32,05	31,50	31,23	32,16	38,28	41,27	44,53	46,09	46,60	48,25	49,52	49,21	48,30	47,90	48,49	48,70	48,01	47,48	47,15	43,47	40,94	1.017,62
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ Η/Ζ	15										4	6	6	8	10	10	9	9	9	9	8	7	7	3		Διαθέσιμη

Τετάρτη, 29 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		37,52	35,40	32,83	32,16	31,37	31,09	32,01	37,86	41,18	44,59	45,66	45,99	47,65	49,61	49,11	48,24	47,94	48,70	49,16	48,50	48,16	48,26	44,05	41,24	1.018,30
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ Η/Ζ	14										4	5	6	8	10	10	9	9	9	9	9	9	9	3		Διαθέσιμη

Πέμπτη, 30 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		37,72	35,62	32,87	32,55	31,61	31,33	32,41	39,16	42,26	44,90	45,63	46,35	47,46	49,25	48,64	48,02	47,71	48,34	49,11	48,79	48,48	48,10	45,58	42,46	1.024,35
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ Η/Ζ	14								1	4	5	6	7	10	10	9	9	9	9	9	9	9	9	6	2	Διαθέσιμη

Παρασκευή, 10 Ιούνιος 2022		Προτεινόμενος ΗΕΠ Θήρας																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		33,13	32,26	30,42	29,52	28,99	28,80	29,64	31,87	38,19	40,53	40,97	41,34	41,68	42,74	42,29	41,42	41,12	41,30	42,21	42,36	42,67	42,95	39,36	35,08	900,84	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G30 (Α/Σ TURBOMACH)	10,5									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
16 ΦΟΡΗΤΑ Η/Ζ	14														2	1				1	1	2	3			Διαθέσιμη	

Πέμπτη, 7 Ιούλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		36,68	36,07	33,97	33,70	31,88	31,80	33,66	39,60	42,65	43,48	44,91	45,74	45,96	45,76	47,43	47,12	46,53	46,52	47,62	47,60	47,20	47,65	44,93	39,01	1.007,47
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5																									Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ + 20 ΜΙΣΘΩΜΕΝΑ Η/Ζ	34	5	5	3	3	1	1	3	10	13	14	15	16	17	16	18	18	17	17	18	18	18	18	15	9	Διαθέσιμη

Παρασκευή, 1 Ιούλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		37,35	35,46	33,26	32,66	31,73	31,48	34,12	39,64	42,11	44,41	45,66	46,96	47,59	48,84	48,15	47,65	47,30	47,95	48,79	48,64	48,43	48,07	45,88	42,01	1.024,15
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1	1					1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ Η/Ζ	14									1	4	5	7	8	9	9	8	8	8	9	9	9	9	6	1	Διαθέσιμη

Σάββατο, 2 Ιούλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		38,66	36,65	34,83	32,81	32,68	32,49	35,02	41,02	43,10	46,13	47,46	48,08	49,01	50,74	50,35	49,74	49,40	50,01	50,58	50,07	49,59	49,52	47,28	42,40	1.057,62
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ Η/Ζ	14	7	5	3				3	1	2	6	7	8	9	11	11	10	10	10	11	11	10	10	7	1	Διαθέσιμη

Κυριακή, 3 Ιούλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		38,48	36,41	34,44	32,89	32,35	32,15	33,72	40,61	42,91	45,94	46,99	47,30	48,46	50,41	49,95	49,40	49,07	49,65	50,23	49,70	49,18	49,19	46,92	42,37	1.048,72
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ Η/Ζ	14	7	5	2				1	1	2	6	7	7	9	11	10	10	10	10	11	11	10	10	7	1	Διαθέσιμη

Δευτέρα, 4 Ιούλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		38,65	36,60	34,70	32,85	32,58	32,38	34,44	41,43	43,09	46,13	47,32	47,79	48,83	50,68	50,25	49,67	49,39	49,93	50,51	49,99	49,48	49,46	47,19	42,47	1.055,79
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ Η/Ζ	14	7	5	3				2	2	2	6	7	8	9	11	11	10	10	10	11	10	10	10	7	1	Διαθέσιμη

Τρίτη, 5 Ιούλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		37,64	34,53	33,60	32,59	31,26	31,43	35,74	40,24	42,53	43,69	45,63	48,41	47,98	47,89	48,15	47,26	46,80	47,47	48,40	48,22	48,22	47,94	47,12	40,06	1.022,82
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5	1	1					1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ + 20 ΜΙΣΘΩΜΕΝΑ Η/Ζ	34									2	4	6	9	8	8	9	8	7	8	9	9	9	8	7		Διαθέσιμη

Τετάρτη, 6 Ιούλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		39,27	35,27	33,85	32,75	31,23	31,57	32,61	38,95	43,13	43,77	44,94	46,82	47,23	47,18	47,97	47,51	47,02	47,05	48,05	47,92	47,74	48,10	46,26	40,10	1.016,28
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5																									Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ + 20 ΜΙΣΘΩΜΕΝΑ Η/Ζ	34	7	5	3	2			1	9	13	14	15	18	18	18	19	18	18	18	19	19	19	19	17	10	Διαθέσιμη

Παρασκευή, 8 Ιούλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		35,77	34,91	34,70	33,42	32,34	31,97	34,83	39,80	42,64	44,15	46,36	46,77	46,57	46,53	48,15	47,43	46,87	47,31	48,01	48,36	47,75	47,68	46,47	38,73	1.017,50
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5																									Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ + 20 ΜΙΣΘΩΜΕΝΑ Η/Ζ	34	5	4	4	3	2	1	4	10	13	15	17	17	17	17	19	18	18	18	19	19	19	18	17	9	Διαθέσιμη

Σάββατο, 9 Ιούλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		36,78	33,63	34,64	32,61	32,27	32,20	34,01	38,63	42,56	45,50	47,30	47,82	47,97	47,85	47,95	48,08	47,53	47,42	47,94	48,00	47,78	47,68	47,42	41,22	1.024,76
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5																									Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ + 20 ΜΙΣΘΩΜΕΝΑ Η/Ζ	34	6	3	4	2	2	1	3	9	13	16	18	19	19	19	19	19	18	18	19	19	19	18	18	11	Διαθέσιμη

Κυριακή, 10 Ιούλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		36,92	34,26	34,32	32,28	31,94	32,18	33,95	35,56	41,24	44,07	46,31	46,82	46,96	46,86	47,33	47,09	47,26	47,40	47,41	47,90	47,63	47,24	46,10	39,16	1.008,18
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5																									Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ + 20 ΜΙΣΘΩΜΕΝΑ Η/Ζ	34	7	4	4	2	1	1	3	5	11	15	17	18	18	18	18	18	18	18	18	19	18	18	17	9	Διαθέσιμη

Δευτέρα, 11 Ιούλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		38,27	34,95	34,81	32,50	32,12	32,02	33,62	37,23	41,61	43,32	45,67	46,77	47,11	47,11	47,77	47,36	46,91	46,88	47,37	47,89	47,36	47,28	44,87	39,12	1.009,91
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5																									Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ + 20 ΜΙΣΘΩΜΕΝΑ Η/Ζ	34	8	4	4	2	1	1	3	7	12	14	16	17	18	18	19	18	18	18	18	19	18	18	15	9	Διαθέσιμη

Τρίτη, 12 Ιούλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		38,05	35,40	34,28	33,50	32,38	32,66	37,32	39,74	42,55	46,66	46,78	47,05	47,81	47,77	49,04	48,97	49,18	49,55	50,18	49,85	49,30	49,38	48,13	39,18	1.044,70
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5																									Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ + 20 ΜΙΣΘΩΜΕΝΑ Η/Ζ	34	8	5	4	3	2	2	7	10	13	17	18	18	19	19	20	20	20	21	21	21	20	20	19	9	Διαθέσιμη

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Τετάρτη, 27 Ιούλιος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		40,96	37,66	36,02	34,30	33,96	34,45	36,64	39,69	46,62	47,54	49,08	50,55	52,00	52,63	52,78	52,26	51,70	52,26	53,22	53,35	53,06	52,96	51,53	41,14	1.106,38
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5														1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5																									Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
14 ΦΟΡΗΤΑ + 20 ΜΙΣΘΩΜΕΝΑ Η/Ζ	34	14	9	7	5	5	5	7	11	21	20	20	22	24	21	21	21	21	21	21	21	21	21	20	10	Διαθέσιμη

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Σάββατο, 6 Αύγουστος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		40,20	36,56	35,78	35,67	34,40	34,39	35,16	39,75	46,75	47,40	48,52	49,31	50,58	51,31	51,49	51,07	50,78	50,94	51,96	51,61	51,30	51,17	49,27	43,50	1.088,92
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3																									Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1				1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1																1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
13 ΦΟΡΗΤΑ + 20 ΜΙΣΘΩΜΕΝΑ Η/Ζ	33	5							4	20	20	20	20	20	20	20	20	20	20	21	20	20	20	20	10	Διαθέσιμη

Κυριακή, 7 Αύγουστος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		39,64	36,73	36,10	35,58	34,02	34,18	34,84	39,84	46,65	46,62	47,63	48,76	49,57	49,93	50,69	50,56	50,21	50,39	51,97	51,26	50,84	50,86	49,21	45,69	1.081,78
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3																									Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1				1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1																1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
13 ΦΟΡΗΤΑ + 20 ΜΙΣΘΩΜΕΝΑ Η/Ζ	33	5							4	20	20	20	20	20	20	20	20	20	20	21	20	20	20	20	10	Διαθέσιμη

Δευτέρα, 8 Αύγουστος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		41,12	36,93	36,83	35,48	35,58	35,32	36,14	42,04	49,02	49,22	49,40	50,53	51,73	52,64	53,06	52,42	52,28	52,17	52,56	52,64	52,72	52,80	50,56	48,52	1.121,69
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3																									Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1				1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1																1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
13 ΦΟΡΗΤΑ + 20 ΜΙΣΘΩΜΕΝΑ Η/Ζ	33	5							7	20	20	20	20	20	20	20	20	20	20	21	20	20	20	20	12	Διαθέσιμη

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Πέμπτη, 1 Σεπτέμβριος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		36,36	36,56	35,71	34,47	33,40	32,88	34,05	37,51	46,68	45,60	48,33	49,87	51,20	52,45	52,42	51,53	51,04	51,32	51,42	50,55	51,93	49,37	46,61	33,33	1.064,59
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1	1									1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (Α/Σ TURBOMACH)	10,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (Α/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ + 10 ΜΙΣΘΩΜΕΝΑ Η/Ζ	25								3	10	10	10	12	13	14	14	13	13	13	13	12	15	10	10		Διαθέσιμη

Παρασκευή, 2 Σεπτέμβριος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		38,72	35,91	35,28	34,73	34,73	34,73	35,90	45,64	45,75	48,27	49,11	50,67	51,89	52,05	51,22	51,09	51,44	51,78	50,87	52,14	48,22	47,38	38,07	1.070,32	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32) G2 (WARTSILA W18V32) G3 (WARTSILA 12V32D) G4 (WARTSILA 12V32D) G6 (WARTSILA 12V32D) G8 (WARTSILA W12V32) G30 (A/Σ TURBOMACH) G29 (A/Σ GE10B1) 15 ΦΟΡΗΤΑ + 10 ΜΙΣΘΩΜΕΝΑ Η/Ζ	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
	3,5											1	1	1	1	1	1	1	1	1	1	1				Διαθέσιμη
	3,5									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
	10,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
	25	3									10	10	10	10	11	12	12	12	12	12	12	12	11	10		Διαθέσιμη

[illegible]

Δευτέρα, 5 Σεπτέμβριος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		35,73	34,77	34,34	33,53	32,40	32,68	33,47	35,74	41,53	46,03	46,73	48,25	49,64	50,65	50,43	50,13	49,61	49,71	50,12	49,55	50,88	49,81	41,06	35,02	1.031,81
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5												1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5										1	1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ + 10 ΜΙΣΘΩΜΕΝΑ Η/Ζ	25									10	10	10	10	10	11	11	11	10	10	10	10	11	10	10		Διαθέσιμη

Τρίτη, 6 Σεπτέμβριος 2022		Προτεινόμενος ΗΕΠ Θήρας																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		39,09	36,50	35,93	34,91	34,14	33,50	34,59	37,20	45,29	45,64	48,03	50,21	51,65	53,11	52,66	51,10	50,83	51,06	51,53	51,80	52,27	50,65	48,86	38,90	1.079,47
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (WARTSILA W18V32)	7,3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (WARTSILA 12V32D)	3,5	1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (WARTSILA 12V32D)	3,5								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (WARTSILA 12V32D)	3,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (WARTSILA W12V32)	5,8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G30 (A/Σ TURBOMACH)	10,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G29 (A/Σ GE10B1)	8,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
15 ΦΟΡΗΤΑ + 10 ΜΙΣΘΩΜΕΝΑ Η/Ζ	25									10	10	10	10	11	12	12	11	11	11	11	11	11	11	10		Διαθέσιμη

[illegible]

[illegible]

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή				9/9/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16+10)
Παρασκευή	09/09/22 0:00	39,02	1	1	1	1		1	1	1	
	09/09/22 1:00	36,20	1	1	1			1	1	1	
	09/09/22 2:00	34,69	1	1	1			1	1	1	
	09/09/22 3:00	33,56	1	1	1			1	1	1	
	09/09/22 4:00	32,83	1	1	1			1	1	1	
	09/09/22 5:00	32,71	1	1	1			1	1	1	
	09/09/22 6:00	34,07	1	1	1			1	1	1	
	09/09/22 7:00	36,81	1	1	1	1		1	1	1	
	09/09/22 8:00	41,76	1	1	1	1		1	1	1	10
	09/09/22 9:00	44,44	1	1	1	1		1	1	1	10
	09/09/22 10:00	45,97	1	1	1	1		1	1	1	10
	09/09/22 11:00	46,71	1	1	1	1		1	1	1	10
	09/09/22 12:00	47,41	1	1	1	1		1	1	1	10
	09/09/22 13:00	47,99	1	1	1	1		1	1	1	10
	09/09/22 14:00	48,16	1	1	1	1		1	1	1	10
	09/09/22 15:00	47,10	1	1	1	1		1	1	1	10
	09/09/22 16:00	46,43	1	1	1	1		1	1	1	10
	09/09/22 17:00	46,79	1	1	1	1		1	1	1	10
	09/09/22 18:00	47,63	1	1	1	1		1	1	1	10
	09/09/22 19:00	48,03	1	1	1	1		1	1	1	10
09/09/22 20:00	48,88	1	1	1	1		1	1	1	11	
09/09/22 21:00	47,45	1	1	1	1		1	1	1	10	
09/09/22 22:00	44,84	1	1	1	1		1	1	1	10	
09/09/22 23:00	38,22	1	1	1	1		1	1	1		
Παρατηρήσεις:											
• Από 01/09/2022 βρίσκεται στον ΑΣΠ Θήρας 10MW πρόσθετη μισθωμένη ισχύς.											
• 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.											
		Μη διαθεσιμότητα μονάδας λόγω συντήρησης.									
		Μη διαθεσιμότητα μονάδας λόγω βλάβης.									

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο				10/9/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16+10)
Σάββατο	10/09/22 0:00	38,90	1	1	1	1		1	1	1	
	10/09/22 1:00	36,11	1	1	1			1	1	1	
	10/09/22 2:00	34,78	1	1	1			1	1	1	
	10/09/22 3:00	33,67	1	1	1			1	1	1	
	10/09/22 4:00	32,96	1	1	1			1	1	1	
	10/09/22 5:00	32,81	1	1	1			1	1	1	
	10/09/22 6:00	34,07	1	1	1			1	1	1	
	10/09/22 7:00	36,91	1	1	1			1	1	1	1
	10/09/22 8:00	41,77	1	1	1			1	1	1	10
	10/09/22 9:00	44,37	1	1	1			1	1	1	10
	10/09/22 10:00	45,93	1	1	1	1		1	1	1	10
	10/09/22 11:00	46,72	1	1	1	1		1	1	1	10
	10/09/22 12:00	47,51	1	1	1	1		1	1	1	10
	10/09/22 13:00	48,12	1	1	1	1		1	1	1	10
	10/09/22 14:00	48,23	1	1	1	1		1	1	1	10
	10/09/22 15:00	47,13	1	1	1	1		1	1	1	10
	10/09/22 16:00	46,50	1	1	1	1		1	1	1	10
	10/09/22 17:00	46,77	1	1	1	1		1	1	1	10
	10/09/22 18:00	47,64	1	1	1	1		1	1	1	10
	10/09/22 19:00	48,00	1	1	1	1		1	1	1	10
10/09/22 20:00	49,02	1	1	1	1		1	1	1	11	
10/09/22 21:00	47,89	1	1	1	1		1	1	1	10	
10/09/22 22:00	45,17	1	1	1	1		1	1	1	10	
10/09/22 23:00	38,11	1	1	1	1		1	1	1		

Παρατηρήσεις:

- Από 01/09/2022 βρίσκεται στον ΑΣΠ Θήρας 10MW πρόσθετη μισθωμένη ισχύς.
- 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή				11/9/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16+10)
Κυριακή	11/09/22 0:00	37,74	1	1	1	1		1	1	1	
	11/09/22 1:00	35,75	1	1	1			1	1	1	
	11/09/22 2:00	34,44	1	1	1			1	1	1	
	11/09/22 3:00	33,33	1	1	1			1	1	1	
	11/09/22 4:00	32,63	1	1	1			1	1	1	
	11/09/22 5:00	32,48	1	1	1			1	1	1	
	11/09/22 6:00	33,73	1	1	1			1	1	1	
	11/09/22 7:00	36,17	1	1	1			1	1	1	
	11/09/22 8:00	41,35	1	1	1			1	1	1	10
	11/09/22 9:00	43,93	1	1	1			1	1	1	10
	11/09/22 10:00	45,47	1	1	1	1		1	1	1	10
	11/09/22 11:00	46,25	1	1	1	1		1	1	1	10
	11/09/22 12:00	47,03	1	1	1	1		1	1	1	10
	11/09/22 13:00	47,64	1	1	1	1		1	1	1	10
	11/09/22 14:00	47,75	1	1	1	1		1	1	1	10
	11/09/22 15:00	46,66	1	1	1	1		1	1	1	10
	11/09/22 16:00	46,04	1	1	1	1		1	1	1	10
	11/09/22 17:00	46,30	1	1	1	1		1	1	1	10
	11/09/22 18:00	47,17	1	1	1	1		1	1	1	10
	11/09/22 19:00	47,52	1	1	1	1		1	1	1	10
11/09/22 20:00	48,53	1	1	1	1		1	1	1	11	
11/09/22 21:00	47,41	1	1	1	1		1	1	1	10	
11/09/22 22:00	44,71	1	1	1	1		1	1	1	10	
11/09/22 23:00	38,49	1	1	1	1		1	1	1		
Παρατηρήσεις:											
• Από 01/09/2022 βρίσκεται στον ΑΣΠ Θήρας 10MW πρόσθετη μισθωμένη ισχύς.											
• 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.											
		Μη διαθεσιμότητα μονάδας λόγω συντήρησης.									
		Μη διαθεσιμότητα μονάδας λόγω βλάβης.									

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα				12/9/2022	
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1	
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16+10)	
Δευτέρα	12/09/22 0:00	38,16	1	1	1	1		1	1	1		
	12/09/22 1:00	35,80	1	1	1			1	1	1		
	12/09/22 2:00	34,23	1	1	1	1		1	1	1		
	12/09/22 3:00	33,15	1	1	1			1	1	1		
	12/09/22 4:00	32,48	1	1	1			1	1	1		
	12/09/22 5:00	32,40	1	1	1			1	1	1		
	12/09/22 6:00	33,62	1	1	1			1	1	1		
	12/09/22 7:00	36,19	1	1	1	1		1	1	1		
	12/09/22 8:00	41,38	1	1	1	1		1	1	1	10	
	12/09/22 9:00	43,98	1	1	1			1	1	1	10	
	12/09/22 10:00	45,48	1	1	1	1		1	1	1	10	
	12/09/22 11:00	46,29	1	1	1	1		1	1	1	10	
	12/09/22 12:00	47,25	1	1	1	1	1		1	1	1	10
	12/09/22 13:00	47,81	1	1	1	1	1		1	1	1	10
	12/09/22 14:00	47,87	1	1	1	1	1		1	1	1	10
	12/09/22 15:00	46,83	1	1	1	1	1		1	1	1	10
	12/09/22 16:00	46,20	1	1	1	1	1		1	1	1	10
	12/09/22 17:00	46,47	1	1	1	1	1		1	1	1	10
	12/09/22 18:00	47,38	1	1	1	1	1		1	1	1	10
	12/09/22 19:00	47,70	1	1	1	1	1		1	1	1	10
12/09/22 20:00	48,76	1	1	1	1	1		1	1	1	11	
12/09/22 21:00	47,45	1	1	1	1	1		1	1	1	10	
12/09/22 22:00	44,84	1	1	1	1	1		1	1	1	10	
12/09/22 23:00	38,07	1	1	1	1	1		1	1	1		

Παρατηρήσεις:

- Από 01/09/2022 βρίσκεται στον ΑΣΠ Θήρας 10MW πρόσθετη μισθωμένη ισχύς.
- 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα				13/9/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16+10)
Δευτέρα	13/09/22 0:00	38,42	1	1	1	1		1	1	1	
	13/09/22 1:00	36,22	1	1	1			1	1	1	
	13/09/22 2:00	34,45	1	1	1	1		1	1	1	
	13/09/22 3:00	33,40	1	1	1			1	1	1	
	13/09/22 4:00	32,64	1	1	1			1	1	1	
	13/09/22 5:00	32,47	1	1	1			1	1	1	
	13/09/22 6:00	33,62	1	1	1			1	1	1	
	13/09/22 7:00	35,88	1	1	1	1		1	1	1	
	13/09/22 8:00	41,74	1	1	1	1		1	1	1	10
	13/09/22 9:00	44,50	1	1	1			1	1	1	10
	13/09/22 10:00	46,24	1	1	1	1		1	1	1	10
	13/09/22 11:00	47,01	1	1	1	1		1	1	1	10
	13/09/22 12:00	48,23	1	1	1	1	1	1	1	1	10
	13/09/22 13:00	48,87	1	1	1	1	1	1	1	1	10
	13/09/22 14:00	49,02	1	1	1	1	1	1	1	1	10
	13/09/22 15:00	48,02	1	1	1	1	1	1	1	1	10
	13/09/22 16:00	47,43	1	1	1	1	1	1	1	1	10
	13/09/22 17:00	47,68	1	1	1	1	1	1	1	1	10
	13/09/22 18:00	48,56	1	1	1	1	1	1	1	1	10
	13/09/22 19:00	48,79	1	1	1	1	1	1	1	1	10
13/09/22 20:00	49,88	1	1	1	1	1	1	1	1	10	
13/09/22 21:00	48,52	1	1	1	1	1	1	1	1	10	
13/09/22 22:00	46,09	1	1	1	1		1	1	1	10	
13/09/22 23:00	38,27	1	1	1	1		1	1	1		

Παρατηρήσεις:

- Από 01/09/2022 βρίσκεται στον ΑΣΠ Θήρας 10MW πρόσθετη μισθωμένη ισχύς.
- 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη				14/9/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16+10)
Τετάρτη	14/09/22 0:00	38,30	1	1	1	1		1	1	1	
	14/09/22 1:00	36,56	1	1	1	1		1	1	1	
	14/09/22 2:00	34,76	1	1	1			1	1	1	
	14/09/22 3:00	33,53	1	1	1			1	1	1	
	14/09/22 4:00	32,74	1	1	1			1	1	1	
	14/09/22 5:00	32,40	1	1	1			1	1	1	
	14/09/22 6:00	33,44	1	1	1			1	1	1	
	14/09/22 7:00	34,79	1	1	1			1	1	1	
	14/09/22 8:00	41,83	1	1	1			1	1	1	10
	14/09/22 9:00	44,81	1	1	1	1		1	1	1	10
	14/09/22 10:00	46,90	1	1	1	1		1	1	1	10
	14/09/22 11:00	47,75	1	1	1	1	1	1	1	1	10
	14/09/22 12:00	49,38	1	1	1	1	1	1	1	1	10
	14/09/22 13:00	50,05	1	1	1	1	1	1	1	1	10
	14/09/22 14:00	50,14	1	1	1	1	1	1	1	1	10
	14/09/22 15:00	49,42	1	1	1	1	1	1	1	1	10
	14/09/22 16:00	48,85	1	1	1	1	1	1	1	1	10
	14/09/22 17:00	49,04	1	1	1	1	1	1	1	1	10
	14/09/22 18:00	49,57	1	1	1	1	1	1	1	1	10
	14/09/22 19:00	49,96	1	1	1	1	1	1	1	1	10
14/09/22 20:00	50,63	1	1	1	1	1	1	1	1	11	
14/09/22 21:00	49,03	1	1	1	1	1	1	1	1	10	
14/09/22 22:00	46,83	1	1	1	1		1	1	1	10	
14/09/22 23:00	38,54	1	1	1	1		1	1	1		
Παρατηρήσεις:											
• Από 01/09/2022 βρίσκεται στον ΑΣΠ Θήρας 10MW πρόσθετη μισθωμένη ισχύς.											
• 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.											
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη				15/9/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16+10)
Πέμπτη	15/09/22 0:00	37,99	1	1	1	1		1	1	1	
	15/09/22 1:00	36,70	1	1	1	1		1	1	1	
	15/09/22 2:00	34,91	1	1	1	1		1	1	1	
	15/09/22 3:00	33,65	1	1	1	1		1	1	1	
	15/09/22 4:00	32,91	1	1	1	1		1	1	1	
	15/09/22 5:00	32,51	1	1	1	1		1	1	1	
	15/09/22 6:00	33,73	1	1	1	1		1	1	1	
	15/09/22 7:00	34,78	1	1	1	1		1	1	1	
	15/09/22 8:00	41,78	1	1	1	1		1	1	1	10
	15/09/22 9:00	44,61	1	1	1	1		1	1	1	10
	15/09/22 10:00	46,49	1	1	1	1		1	1	1	10
	15/09/22 11:00	47,08	1	1	1	1		1	1	1	10
	15/09/22 12:00	48,65	1	1	1	1	1	1	1	1	10
	15/09/22 13:00	49,27	1	1	1	1	1	1	1	1	10
	15/09/22 14:00	49,25	1	1	1	1	1	1	1	1	10
	15/09/22 15:00	48,55	1	1	1	1	1	1	1	1	10
	15/09/22 16:00	47,92	1	1	1	1	1	1	1	1	10
	15/09/22 17:00	48,32	1	1	1	1	1	1	1	1	10
	15/09/22 18:00	48,77	1	1	1	1	1	1	1	1	10
	15/09/22 19:00	49,04	1	1	1	1	1	1	1	1	10
15/09/22 20:00	49,93	1	1	1	1	1	1	1	1	10	
15/09/22 21:00	48,56	1	1	1	1	1	1	1	1	10	
15/09/22 22:00	45,73	1	1	1	1		1	1	1	10	
15/09/22 23:00	38,33	1	1	1	1		1	1	1	3	
Παρατηρήσεις:											
• Από 01/09/2022 βρίσκεται στον ΑΣΠ Θήρας 10MW πρόσθετη μισθωμένη ισχύς.											
• 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.											
		Μη διαθεσιμότητα μονάδας λόγω συντήρησης.									
		Μη διαθεσιμότητα μονάδας λόγω βλάβης.									

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή				16/9/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16+10)
Παρασκευή	16/09/22 0:00	37,07	1	1	1	1		1	1	1	
	16/09/22 1:00	35,81	1	1	1	1		1	1	1	
	16/09/22 2:00	34,04	1	1	1	1		1	1	1	
	16/09/22 3:00	32,89	1	1	1	1		1	1	1	
	16/09/22 4:00	32,18	1	1	1	1		1	1	1	
	16/09/22 5:00	31,80	1	1	1	1		1	1	1	
	16/09/22 6:00	33,19	1	1	1	1		1	1	1	
	16/09/22 7:00	34,43	1	1	1	1		1	1	1	
	16/09/22 8:00	41,13	1	1	1	1		1	1	1	10
	16/09/22 9:00	43,82	1	1	1	1		1	1	1	10
	16/09/22 10:00	45,52	1	1	1	1		1	1	1	10
	16/09/22 11:00	46,31	1	1	1	1		1	1	1	10
	16/09/22 12:00	47,00	1	1	1	1		1	1	1	10
	16/09/22 13:00	47,99	1	1	1	1	1	1	1	1	10
	16/09/22 14:00	47,90	1	1	1	1	1	1	1	1	10
	16/09/22 15:00	47,19	1	1	1	1	1	1	1	1	10
	16/09/22 16:00	46,43	1	1	1	1	1	1	1	1	10
	16/09/22 17:00	47,01	1	1	1	1	1	1	1	1	10
	16/09/22 18:00	47,67	1	1	1	1	1	1	1	1	10
	16/09/22 19:00	48,07	1	1	1	1	1	1	1	1	10
16/09/22 20:00	48,97	1	1	1	1	1	1	1	1	10	
16/09/22 21:00	47,50	1	1	1	1	1	1	1	1	10	
16/09/22 22:00	44,71	1	1	1	1		1	1	1	10	
16/09/22 23:00	37,68	1	1	1	1		1	1	1		
Παρατηρήσεις:											
• Από 01/09/2022 βρίσκεται στον ΑΣΠ Θήρας 10MW πρόσθετη μισθωμένη ισχύς.											
• 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.											
		Μη διαθεσιμότητα μονάδας λόγω συντήρησης.									
		Μη διαθεσιμότητα μονάδας λόγω βλάβης.									

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο 17/9/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	17/09/22 0:00	36,90	1	1	1	1		1	1	1	
	17/09/22 1:00	35,26	1	1	1	1		1	1	1	
	17/09/22 2:00	33,52	1	1	1	1		1	1	1	
	17/09/22 3:00	32,41	1	1	1	1		1	1	1	
	17/09/22 4:00	31,57	1	1	1	1		1	1	1	
	17/09/22 5:00	31,44	1	1	1	1		1	1	1	
	17/09/22 6:00	33,33	1	1	1	1		1	1	1	
	17/09/22 7:00	34,57	1	1	1	1		1	1	1	
	17/09/22 8:00	41,42	1	1	1	1	1	1	1	1	
	17/09/22 9:00	43,14	1	1	1	1	1	1	1	1	2
	17/09/22 10:00	45,30	1	1	1	1	1	1	1	1	5
	17/09/22 11:00	45,66	1	1	1	1	1	1	1	1	5
	17/09/22 12:00	46,87	1	1	1	1	1	1	1	1	7
	17/09/22 13:00	47,66	1	1	1	1	1	1	1	1	8
	17/09/22 14:00	47,67	1	1	1	1	1	1	1	1	8
	17/09/22 15:00	46,88	1	1	1	1	1	1	1	1	8
	17/09/22 16:00	46,15	1	1	1	1	1	1	1	1	8
	17/09/22 17:00	46,81	1	1	1	1	1	1	1	1	8
	17/09/22 18:00	47,64	1	1	1	1	1	1	1	1	8
17/09/22 19:00	48,07	1	1	1	1	1	1	1	1	8	
17/09/22 20:00	49,11	1	1	1	1	1	1	1	1	9	
17/09/22 21:00	47,96	1	1	1	1	1	1	1	1	8	
17/09/22 22:00	46,18	1	1	1	1	1	1	1	1	6	
17/09/22 23:00	37,67	1	1	1	1	1	1	1	1		

Παρατηρήσεις:

- 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή 18/9/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Κυριακή	18/09/22 0:00	37,09	1	1	1	1		1	1	1	
	18/09/22 1:00	35,44	1	1	1	1		1	1	1	
	18/09/22 2:00	33,68	1	1	1	1		1	1	1	
	18/09/22 3:00	32,57	1	1	1	1		1	1	1	
	18/09/22 4:00	31,73	1	1	1	1		1	1	1	
	18/09/22 5:00	31,60	1	1	1	1		1	1	1	
	18/09/22 6:00	33,49	1	1	1	1		1	1	1	
	18/09/22 7:00	34,75	1	1	1	1		1	1	1	
	18/09/22 8:00	41,63	1	1	1	1	1	1	1	1	
	18/09/22 9:00	43,36	1	1	1	1	1	1	1	1	3
	18/09/22 10:00	45,52	1	1	1	1	1	1	1	1	5
	18/09/22 11:00	45,89	1	1	1	1	1	1	1	1	6
	18/09/22 12:00	47,10	1	1	1	1	1	1	1	1	7
	18/09/22 13:00	47,90	1	1	1	1	1	1	1	1	8
	18/09/22 14:00	47,90	1	1	1	1	1	1	1	1	8
	18/09/22 15:00	47,11	1	1	1	1	1	1	1	1	8
	18/09/22 16:00	46,38	1	1	1	1	1	1	1	1	8
	18/09/22 17:00	47,04	1	1	1	1	1	1	1	1	8
	18/09/22 18:00	47,88	1	1	1	1	1	1	1	1	8
	18/09/22 19:00	48,31	1	1	1	1	1	1	1	1	9
18/09/22 20:00	49,36	1	1	1	1	1	1	1	1	10	
18/09/22 21:00	48,20	1	1	1	1	1	1	1	1	8	
18/09/22 22:00	46,41	1	1	1	1	1	1	1	1	6	
18/09/22 23:00	37,86	1	1	1	1	1	1	1	1		

Παρατηρήσεις:

- 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα				19/9/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	19/09/22 0:00	36,30	1	1	1	1		1	1	1	
	19/09/22 1:00	34,76	1	1	1	1		1	1	1	
	19/09/22 2:00	33,08	1	1	1	1		1	1	1	
	19/09/22 3:00	31,92	1	1	1	1		1	1	1	
	19/09/22 4:00	31,00	1	1	1	1		1	1	1	
	19/09/22 5:00	31,06	1	1	1	1		1	1	1	
	19/09/22 6:00	33,62	1	1	1	1		1	1	1	
	19/09/22 7:00	34,82	1	1	1	1		1	1	1	
	19/09/22 8:00	41,74	1	1	1	1	1	1	1	1	1
	19/09/22 9:00	42,85	1	1	1	1	1	1	1	1	2
	19/09/22 10:00	44,81	1	1	1	1	1	1	1	1	5
	19/09/22 11:00	45,28	1	1	1	1	1	1	1	1	5
	19/09/22 12:00	46,20	1	1	1	1	1	1	1	1	6
	19/09/22 13:00	47,09	1	1	1	1	1	1	1	1	7
	19/09/22 14:00	47,09	1	1	1	1	1	1	1	1	7
	19/09/22 15:00	46,24	1	1	1	1	1	1	1	1	7
	19/09/22 16:00	45,56	1	1	1	1	1	1	1	1	7
	19/09/22 17:00	46,16	1	1	1	1	1	1	1	1	7
	19/09/22 18:00	47,16	1	1	1	1	1	1	1	1	7
	19/09/22 19:00	47,58	1	1	1	1	1	1	1	1	8
19/09/22 20:00	48,81	1	1	1	1	1	1	1	1	9	
19/09/22 21:00	48,19	1	1	1	1	1	1	1	1	8	
19/09/22 22:00	47,15	1	1	1	1	1	1	1	1	7	
19/09/22 23:00	37,34	1	1	1	1	1	1	1	1		

Παρατηρήσεις:

- 1 εκ των 16 H/Z βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα 20/9/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	20/09/22 0:00	36,02	1	1	1	1		1	1	1	
	20/09/22 1:00	34,21	1	1	1	1		1	1	1	
	20/09/22 2:00	32,79	1	1	1	1		1	1	1	
	20/09/22 3:00	31,86	1	1	1	1		1	1	1	
	20/09/22 4:00	31,18	1	1	1	1		1	1	1	
	20/09/22 5:00	31,21	1	1	1	1		1	1	1	
	20/09/22 6:00	33,18	1	1	1	1		1	1	1	
	20/09/22 7:00	35,74	1	1	1	1		1	1	1	
	20/09/22 8:00	41,95	1	1	1	1	1	1	1	1	1
	20/09/22 9:00	44,35	1	1	1	1	1	1	1	1	3
	20/09/22 10:00	45,88	1	1	1	1	1	1	1	1	5
	20/09/22 11:00	46,96	1	1	1	1	1	1	1	1	6
	20/09/22 12:00	47,88	1	1	1	1	1	1	1	1	7
	20/09/22 13:00	49,51	1	1	1	1	1	1	1	1	9
	20/09/22 14:00	48,40	1	1	1	1	1	1	1	1	8
	20/09/22 15:00	47,21	1	1	1	1	1	1	1	1	7
	20/09/22 16:00	47,17	1	1	1	1	1	1	1	1	7
	20/09/22 17:00	47,94	1	1	1	1	1	1	1	1	8
	20/09/22 18:00	48,28	1	1	1	1	1	1	1	1	8
	20/09/22 19:00	48,61	1	1	1	1	1	1	1	1	8
20/09/22 20:00	49,03	1	1	1	1	1	1	1	1	9	
20/09/22 21:00	46,51	1	1	1	1	1	1	1	1	6	
20/09/22 22:00	44,11	1	1	1	1	1	1	1	1	4	
20/09/22 23:00	39,63	1	1	1	1	1	1	1	1		

Παρατηρήσεις:

- 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 21/9/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	21/09/22 0:00	36,09	1	1	1	1		1	1	1	
	21/09/22 1:00	34,28	1	1	1	1		1	1	1	
	21/09/22 2:00	32,69	1	1	1	1		1	1	1	
	21/09/22 3:00	31,88	1	1	1	1		1	1	1	
	21/09/22 4:00	31,30	1	1	1	1		1	1	1	
	21/09/22 5:00	31,28	1	1	1	1		1	1	1	
	21/09/22 6:00	33,78	1	1	1	1		1	1	1	
	21/09/22 7:00	35,65	1	1	1	1		1	1	1	
	21/09/22 8:00	41,60	1	1	1	1	1	1	1	1	
	21/09/22 9:00	43,29	1	1	1	1	1	1	1	1	2
	21/09/22 10:00	44,93	1	1	1	1	1	1	1	1	4
	21/09/22 11:00	45,83	1	1	1	1	1	1	1	1	5
	21/09/22 12:00	46,52	1	1	1	1	1	1	1	1	6
	21/09/22 13:00	47,77	1	1	1	1	1	1	1	1	8
	21/09/22 14:00	47,14	1	1	1	1	1	1	1	1	7
	21/09/22 15:00	46,50	1	1	1	1	1	1	1	1	6
	21/09/22 16:00	45,90	1	1	1	1	1	1	1	1	6
	21/09/22 17:00	46,44	1	1	1	1	1	1	1	1	6
	21/09/22 18:00	47,13	1	1	1	1	1	1	1	1	7
	21/09/22 19:00	47,86	1	1	1	1	1	1	1	1	8
21/09/22 20:00	48,36	1	1	1	1	1	1	1	1	8	
21/09/22 21:00	46,20	1	1	1	1	1	1	1	1	6	
21/09/22 22:00	43,41	1	1	1	1	1	1	1	1	3	
21/09/22 23:00	38,63	1	1	1	1	1	1	1	1		
Παρατηρήσεις:											
• 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.											
		Μη διαθεσιμότητα μονάδας λόγω συντήρησης.									
		Μη διαθεσιμότητα μονάδας λόγω βλάβης.									

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη 22/9/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	22/09/22 0:00	36,75	1	1	1	1		1	1	1	
	22/09/22 1:00	33,88	1	1	1			1	1	1	
	22/09/22 2:00	31,96	1	1	1			1	1	1	
	22/09/22 3:00	31,08	1	1	1			1	1	1	
	22/09/22 4:00	30,81	1	1	1			1	1	1	
	22/09/22 5:00	30,86	1	1	1			1	1	1	
	22/09/22 6:00	33,74	1	1	1			1	1	1	
	22/09/22 7:00	35,60	1	1	1			1	1	1	
	22/09/22 8:00	41,63	1	1	1	1	1	1	1	1	
	22/09/22 9:00	43,04	1	1	1	1	1	1	1	1	2
	22/09/22 10:00	44,60	1	1	1	1	1	1	1	1	4
	22/09/22 11:00	45,33	1	1	1	1	1	1	1	1	5
	22/09/22 12:00	46,12	1	1	1	1	1	1	1	1	6
	22/09/22 13:00	46,91	1	1	1	1	1	1	1	1	7
	22/09/22 14:00	46,76	1	1	1	1	1	1	1	1	7
	22/09/22 15:00	46,05	1	1	1	1	1	1	1	1	6
	22/09/22 16:00	45,38	1	1	1	1	1	1	1	1	5
	22/09/22 17:00	45,53	1	1	1	1	1	1	1	1	5
	22/09/22 18:00	46,08	1	1	1	1	1	1	1	1	6
	22/09/22 19:00	47,13	1	1	1	1	1	1	1	1	7
22/09/22 20:00	47,38	1	1	1	1	1	1	1	1	7	
22/09/22 21:00	44,35	1	1	1	1	1	1	1	1	4	
22/09/22 22:00	40,13	1	1	1	1	1	1	1	1		
22/09/22 23:00	39,04	1	1	1	1	1	1	1	1		

Παρατηρήσεις:

- 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή 23/9/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	23/09/22 0:00	36,11	1	1	1	1		1	1	1	
	23/09/22 1:00	33,31	1	1	1			1	1	1	
	23/09/22 2:00	31,50	1	1	1			1	1	1	
	23/09/22 3:00	30,59	1	1	1			1	1	1	
	23/09/22 4:00	30,28	1	1	1			1	1	1	
	23/09/22 5:00	30,89	1	1	1			1	1	1	
	23/09/22 6:00	33,54	1	1	1			1	1	1	
	23/09/22 7:00	35,23	1	1	1			1	1	1	
	23/09/22 8:00	41,16	1	1	1	1	1	1	1	1	
	23/09/22 9:00	42,18	1	1	1	1	1	1	1	1	1
	23/09/22 10:00	43,95	1	1	1	1	1	1	1	1	3
	23/09/22 11:00	44,54	1	1	1	1	1	1	1	1	4
	23/09/22 12:00	45,63	1	1	1	1	1	1	1	1	5
	23/09/22 13:00	45,91	1	1	1	1	1	1	1	1	5
	23/09/22 14:00	45,73	1	1	1	1	1	1	1	1	5
	23/09/22 15:00	44,87	1	1	1	1	1	1	1	1	4
	23/09/22 16:00	44,58	1	1	1	1	1	1	1	1	4
	23/09/22 17:00	44,53	1	1	1	1	1	1	1	1	4
	23/09/22 18:00	45,18	1	1	1	1	1	1	1	1	5
	23/09/22 19:00	47,01	1	1	1	1	1	1	1	1	7
23/09/22 20:00	47,11	1	1	1	1	1	1	1	1	7	
23/09/22 21:00	43,49	1	1	1	1	1	1	1	1	3	
23/09/22 22:00	40,03	1	1	1	1	1	1	1	1		
23/09/22 23:00	38,66	1	1	1	1	1	1	1	1		

Παρατηρήσεις:

- 1 εκ των 16 H/Z βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο 24/9/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	24/09/22 0:00	35,75	1	1	1			1	1	1	
	24/09/22 1:00	33,07	1	1	1			1	1	1	
	24/09/22 2:00	31,48	1	1	1			1	1	1	
	24/09/22 3:00	30,53	1	1	1			1	1	1	
	24/09/22 4:00	30,12	1	1	1			1	1	1	
	24/09/22 5:00	30,77	1	1	1			1	1	1	
	24/09/22 6:00	33,23	1	1	1			1	1	1	
	24/09/22 7:00	35,58	1	1	1			1	1	1	
	24/09/22 8:00	40,57	1	1	1	1	1	1	1	1	
	24/09/22 9:00	41,91	1	1	1	1	1	1	1	1	1
	24/09/22 10:00	43,58	1	1	1	1	1	1	1	1	3
	24/09/22 11:00	44,09	1	1	1	1	1	1	1	1	3
	24/09/22 12:00	45,31	1	1	1	1	1	1	1	1	5
	24/09/22 13:00	45,33	1	1	1	1	1	1	1	1	5
	24/09/22 14:00	45,11	1	1	1	1	1	1	1	1	5
	24/09/22 15:00	43,93	1	1	1	1	1	1	1	1	3
	24/09/22 16:00	43,92	1	1	1	1	1	1	1	1	3
	24/09/22 17:00	44,19	1	1	1	1	1	1	1	1	4
	24/09/22 18:00	44,98	1	1	1	1	1	1	1	1	4
	24/09/22 19:00	46,90	1	1	1	1	1	1	1	1	7
24/09/22 20:00	46,93	1	1	1	1	1	1	1	1	7	
24/09/22 21:00	43,21	1	1	1	1	1	1	1	1	2	
24/09/22 22:00	40,06	1	1	1	1	1	1	1	1		
24/09/22 23:00	38,32	1	1	1	1			1	1	1	

Παρατηρήσεις:

- 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή 25/9/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Κυριακή	25/09/22 0:00	35,80	1	1	1			1	1	1	
	25/09/22 1:00	33,49	1	1	1			1	1	1	
	25/09/22 2:00	31,89	1	1	1			1	1	1	
	25/09/22 3:00	30,93	1	1	1			1	1	1	
	25/09/22 4:00	30,55	1	1	1			1	1	1	
	25/09/22 5:00	31,07	1	1	1			1	1	1	
	25/09/22 6:00	33,33	1	1	1			1	1	1	
	25/09/22 7:00	35,67	1	1	1			1	1	1	
	25/09/22 8:00	40,70	1	1	1	1	1	1	1	1	
	25/09/22 9:00	42,43	1	1	1	1	1	1	1	1	1
	25/09/22 10:00	44,12	1	1	1	1	1	1	1	1	3
	25/09/22 11:00	44,84	1	1	1	1	1	1	1	1	4
	25/09/22 12:00	45,84	1	1	1	1	1	1	1	1	5
	25/09/22 13:00	46,24	1	1	1	1	1	1	1	1	6
	25/09/22 14:00	45,84	1	1	1	1	1	1	1	1	5
	25/09/22 15:00	44,90	1	1	1	1	1	1	1	1	4
	25/09/22 16:00	44,78	1	1	1	1	1	1	1	1	4
	25/09/22 17:00	44,97	1	1	1	1	1	1	1	1	4
	25/09/22 18:00	45,73	1	1	1	1	1	1	1	1	5
	25/09/22 19:00	47,22	1	1	1	1	1	1	1	1	7
25/09/22 20:00	47,17	1	1	1	1	1	1	1	1	7	
25/09/22 21:00	43,50	1	1	1	1	1	1	1	1	3	
25/09/22 22:00	40,36	1	1	1	1	1	1	1	1		
25/09/22 23:00	38,62	1	1	1	1			1	1	1	

Παρατηρήσεις:

- 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα 26/9/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	26/09/22 0:00	36,05	1	1	1	1		1	1	1	
	26/09/22 1:00	33,40	1	1	1			1	1	1	
	26/09/22 2:00	31,87	1	1	1			1	1	1	
	26/09/22 3:00	30,95	1	1	1			1	1	1	
	26/09/22 4:00	30,56	1	1	1			1	1	1	
	26/09/22 5:00	31,31	1	1	1			1	1	1	
	26/09/22 6:00	34,01	1	1	1			1	1	1	
	26/09/22 7:00	36,28	1	1	1		1	1	1	1	
	26/09/22 8:00	40,96	1	1	1	1	1	1	1	1	
	26/09/22 9:00	42,40	1	1	1	1	1	1	1	1	1
	26/09/22 10:00	44,02	1	1	1	1	1	1	1	1	3
	26/09/22 11:00	44,56	1	1	1	1	1	1	1	1	4
	26/09/22 12:00	45,71	1	1	1	1	1	1	1	1	5
	26/09/22 13:00	45,78	1	1	1	1	1	1	1	1	5
	26/09/22 14:00	45,39	1	1	1	1	1	1	1	1	5
	26/09/22 15:00	44,36	1	1	1	1	1	1	1	1	4
	26/09/22 16:00	44,39	1	1	1	1	1	1	1	1	4
	26/09/22 17:00	44,67	1	1	1	1	1	1	1	1	4
	26/09/22 18:00	45,47	1	1	1	1	1	1	1	1	5
	26/09/22 19:00	47,43	1	1	1	1	1	1	1	1	7
26/09/22 20:00	47,55	1	1	1	1	1	1	1	1	7	
26/09/22 21:00	43,83	1	1	1	1	1	1	1	1	3	
26/09/22 22:00	40,63	1	1	1	1	1	1	1	1		
26/09/22 23:00	38,75	1	1	1	1	1	1	1	1		

Παρατηρήσεις:

- 1 εκ των 16 Η/Ζ βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα 27/9/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	27/09/22 0:00	34,02	1	1	1			1	1	1	
	27/09/22 1:00	31,58	1	1	1			1	1	1	
	27/09/22 2:00	30,27	1	1	1			1	1	1	
	27/09/22 3:00	29,45	1	1	1			1	1	1	
	27/09/22 4:00	29,07	1	1	1			1	1	1	
	27/09/22 5:00	29,84	1	1	1			1	1	1	
	27/09/22 6:00	32,10	1	1	1			1	1	1	
	27/09/22 7:00	35,45	1	1	1			1	1	1	
	27/09/22 8:00	38,16	1	1	1		1	1	1	1	
	27/09/22 9:00	40,63	1	1	1	1	1	1	1	1	
	27/09/22 10:00	41,86	1	1	1	1	1	1	1	1	1
	27/09/22 11:00	42,63	1	1	1	1	1	1	1	1	2
	27/09/22 12:00	43,22	1	1	1	1	1	1	1	1	2
	27/09/22 13:00	42,84	1	1	1	1	1	1	1	1	2
	27/09/22 14:00	42,10	1	1	1	1	1	1	1	1	1
	27/09/22 15:00	41,56	1	1	1	1	1	1	1	1	1
27/09/22 16:00	41,71	1	1	1	1	1	1	1	1	1	
27/09/22 17:00	42,56	1	1	1	1	1	1	1	1	1	
27/09/22 18:00	44,07	1	1	1	1	1	1	1	1	3	
27/09/22 19:00	45,34	1	1	1	1	1	1	1	1	5	
27/09/22 20:00	45,61	1	1	1	1	1	1	1	1	5	
27/09/22 21:00	41,70	1	1	1	1	1	1	1	1	1	
27/09/22 22:00	39,17	1	1	1	1	1	1	1	1		
27/09/22 23:00	36,86	1	1	1	1			1	1	1	

Παρατηρήσεις:

- 1 εκ των 16 H/Z βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 28/9/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	28/09/22 0:00	33,19	1	1	1			1	1	1	
	28/09/22 1:00	30,90	1	1	1			1	1	1	
	28/09/22 2:00	29,69	1	1	1			1	1	1	
	28/09/22 3:00	28,98	1	1	1			1	1	1	
	28/09/22 4:00	28,46	1	1	1			1	1	1	
	28/09/22 5:00	28,71	1	1	1			1	1	1	
	28/09/22 6:00	30,72	1	1	1			1	1	1	
	28/09/22 7:00	34,54	1	1	1			1	1	1	
	28/09/22 8:00	37,24	1	1	1		1	1	1	1	
	28/09/22 9:00	40,02	1	1	1	1	1	1	1	1	
	28/09/22 10:00	41,08	1	1	1	1	1	1	1	1	
	28/09/22 11:00	41,30	1	1	1	1	1	1	1	1	
	28/09/22 12:00	41,45	1	1	1	1	1	1	1	1	
	28/09/22 13:00	41,85	1	1	1	1	1	1	1	1	
	28/09/22 14:00	41,16	1	1	1	1	1	1	1	1	
	28/09/22 15:00	40,25	1	1	1	1	1	1	1	1	
	28/09/22 16:00	40,41	1	1	1	1	1	1	1	1	
	28/09/22 17:00	41,30	1	1	1	1	1	1	1	1	
	28/09/22 18:00	42,79	1	1	1	1	1	1	1	1	2
	28/09/22 19:00	44,27	1	1	1	1	1	1	1	1	4
28/09/22 20:00	44,50	1	1	1	1	1	1	1	1	4	
28/09/22 21:00	41,05	1	1	1	1	1	1	1	1		
28/09/22 22:00	38,72	1	1	1	1	1	1	1	1		
28/09/22 23:00	35,99	1	1	1	1			1	1	1	
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη 29/9/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	29/09/22 0:00	34,01	1	1	1			1	1	1	
	29/09/22 1:00	31,61	1	1	1			1	1	1	
	29/09/22 2:00	30,25	1	1	1			1	1	1	
	29/09/22 3:00	29,40	1	1	1			1	1	1	
	29/09/22 4:00	28,84	1	1	1			1	1	1	
	29/09/22 5:00	29,10	1	1	1			1	1	1	
	29/09/22 6:00	30,98	1	1	1			1	1	1	
	29/09/22 7:00	34,75	1	1	1			1	1	1	
	29/09/22 8:00	38,64	1	1	1		1	1	1	1	
	29/09/22 9:00	40,73	1	1	1	1	1	1	1	1	
	29/09/22 10:00	42,29	1	1	1	1	1	1	1	1	1
	29/09/22 11:00	42,45	1	1	1	1	1	1	1	1	1
	29/09/22 12:00	42,49	1	1	1	1	1	1	1	1	1
	29/09/22 13:00	43,45	1	1	1	1	1	1	1	1	2
	29/09/22 14:00	43,23	1	1	1	1	1	1	1	1	2
	29/09/22 15:00	42,15	1	1	1	1	1	1	1	1	1
	29/09/22 16:00	42,05	1	1	1	1	1	1	1	1	1
	29/09/22 17:00	42,66	1	1	1	1	1	1	1	1	2
	29/09/22 18:00	44,04	1	1	1	1	1	1	1	1	3
	29/09/22 19:00	45,96	1	1	1	1	1	1	1	1	5
29/09/22 20:00	45,82	1	1	1	1	1	1	1	1	5	
29/09/22 21:00	42,26	1	1	1	1	1	1	1	1	1	
29/09/22 22:00	39,30	1	1	1	1	1	1	1	1		
29/09/22 23:00	36,99	1	1	1	1		1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή				30/9/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	30/09/22 0:00	34,92	1	1	1			1	1	1	
	30/09/22 1:00	32,44	1	1	1			1	1	1	
	30/09/22 2:00	31,22	1	1	1			1	1	1	
	30/09/22 3:00	30,29	1	1	1			1	1	1	
	30/09/22 4:00	29,71	1	1	1			1	1	1	
	30/09/22 5:00	30,27	1	1	1			1	1	1	
	30/09/22 6:00	31,79	1	1	1			1	1	1	
	30/09/22 7:00	34,97	1	1	1			1	1	1	
	30/09/22 8:00	39,66	1	1	1	1	1	1	1	1	
	30/09/22 9:00	42,74	1	1	1	1	1	1	1	1	2
	30/09/22 10:00	44,00	1	1	1	1	1	1	1	1	3
	30/09/22 11:00	44,79	1	1	1	1	1	1	1	1	4
	30/09/22 12:00	45,90	1	1	1	1	1	1	1	1	5
	30/09/22 13:00	46,45	1	1	1	1	1	1	1	1	6
	30/09/22 14:00	45,74	1	1	1	1	1	1	1	1	5
	30/09/22 15:00	44,82	1	1	1	1	1	1	1	1	4
	30/09/22 16:00	44,80	1	1	1	1	1	1	1	1	4
	30/09/22 17:00	45,32	1	1	1	1	1	1	1	1	5
	30/09/22 18:00	46,27	1	1	1	1	1	1	1	1	6
	30/09/22 19:00	47,94	1	1	1	1	1	1	1	1	8
30/09/22 20:00	47,40	1	1	1	1	1	1	1	1	7	
30/09/22 21:00	43,67	1	1	1	1	1	1	1	1	3	
30/09/22 22:00	40,62	1	1	1	1	1	1	1	1		
30/09/22 23:00	38,27	1	1	1		1	1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο 1/10/2022					
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	01/10/22 0:00	35,79	1	1	1			1	1	1	
	01/10/22 1:00	33,11	1	1	1			1	1	1	
	01/10/22 2:00	31,85	1	1	1			1	1	1	
	01/10/22 3:00	31,10	1	1	1			1	1	1	
	01/10/22 4:00	30,65	1	1	1			1	1	1	
	01/10/22 5:00	30,96	1	1	1			1	1	1	
	01/10/22 6:00	33,13	1	1	1			1	1	1	
	01/10/22 7:00	36,13	1	1	1	1		1	1	1	
	01/10/22 8:00	40,70	1	1	1	1	1	1	1	1	
	01/10/22 9:00	43,62	1	1	1	1	1	1	1	1	3
	01/10/22 10:00	44,94	1	1	1	1	1	1	1	1	4
	01/10/22 11:00	46,06	1	1	1	1	1	1	1	1	6
	01/10/22 12:00	46,75	1	1	1	1	1	1	1	1	6
	01/10/22 13:00	47,42	1	1	1	1	1	1	1	1	7
	01/10/22 14:00	46,79	1	1	1	1	1	1	1	1	6
	01/10/22 15:00	46,09	1	1	1	1	1	1	1	1	6
	01/10/22 16:00	45,84	1	1	1	1	1	1	1	1	6
	01/10/22 17:00	46,23	1	1	1	1	1	1	1	1	6
	01/10/22 18:00	47,12	1	1	1	1	1	1	1	1	7
	01/10/22 19:00	48,29	1	1	1	1	1	1	1	1	8
	01/10/22 20:00	47,80	1	1	1	1	1	1	1	1	8
	01/10/22 21:00	44,19	1	1	1	1	1	1	1	1	4
	01/10/22 22:00	40,81	1	1	1	1	1	1	1	1	1
01/10/22 23:00	38,82	1	1	1		1	1	1	1	1	
		Μη διαθεσιμότητα μονάδας λόγω συντήρησης.									
		Μη διαθεσιμότητα μονάδας λόγω βλάβης.									

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή 2/10/2022					
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Κυριακή	02/10/22 0:00	35,43	1	1	1			1	1	1	
	02/10/22 1:00	32,77	1	1	1			1	1	1	
	02/10/22 2:00	31,53	1	1	1			1	1	1	
	02/10/22 3:00	30,79	1	1	1			1	1	1	
	02/10/22 4:00	30,34	1	1	1			1	1	1	
	02/10/22 5:00	30,65	1	1	1			1	1	1	
	02/10/22 6:00	32,80	1	1	1			1	1	1	
	02/10/22 7:00	35,77	1	1	1			1	1	1	
	02/10/22 8:00	40,30	1	1	1	1	1	1	1	1	
	02/10/22 9:00	43,19	1	1	1	1	1	1	1	1	2
	02/10/22 10:00	44,49	1	1	1	1	1	1	1	1	4
	02/10/22 11:00	45,60	1	1	1	1	1	1	1	1	5
	02/10/22 12:00	46,28	1	1	1	1	1	1	1	1	6
	02/10/22 13:00	46,95	1	1	1	1	1	1	1	1	7
	02/10/22 14:00	46,33	1	1	1	1	1	1	1	1	6
	02/10/22 15:00	45,63	1	1	1	1	1	1	1	1	5
	02/10/22 16:00	45,38	1	1	1	1	1	1	1	1	5
	02/10/22 17:00	45,77	1	1	1	1	1	1	1	1	5
	02/10/22 18:00	46,65	1	1	1	1	1	1	1	1	6
	02/10/22 19:00	47,80	1	1	1	1	1	1	1	1	8
	02/10/22 20:00	47,32	1	1	1	1	1	1	1	1	7
	02/10/22 21:00	43,75	1	1	1	1	1	1	1	1	3
	02/10/22 22:00	40,40	1	1	1	1	1	1	1	1	
02/10/22 23:00	38,43	1	1	1		1	1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης. Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα 3/10/2022					
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	03/10/22 0:00	32,34	1	1	1			1	1	1	
	03/10/22 1:00	30,04	1	1	1			1	1	1	
	03/10/22 2:00	29,00	1	1	1			1	1	1	
	03/10/22 3:00	28,41	1	1	1			1	1	1	
	03/10/22 4:00	27,77	1	1	1			1	1	1	
	03/10/22 5:00	28,05	1	1	1			1	1	1	
	03/10/22 6:00	29,78	1	1	1			1	1	1	
	03/10/22 7:00	33,73	1	1	1			1	1	1	
	03/10/22 8:00	37,53	1	1	1	1	1	1	1	1	
	03/10/22 9:00	39,84	1	1	1	1	1	1	1	1	
	03/10/22 10:00	41,00	1	1	1	1	1	1	1	1	
	03/10/22 11:00	41,49	1	1	1	1	1	1	1	1	1
	03/10/22 12:00	41,07	1	1	1	1	1	1	1	1	1
	03/10/22 13:00	42,02	1	1	1	1	1	1	1	1	1
	03/10/22 14:00	41,47	1	1	1	1	1	1	1	1	
	03/10/22 15:00	40,71	1	1	1	1	1	1	1	1	
	03/10/22 16:00	40,54	1	1	1	1	1	1	1	1	
	03/10/22 17:00	40,88	1	1	1	1	1	1	1	1	
	03/10/22 18:00	42,60	1	1	1	1	1	1	1	1	2
	03/10/22 19:00	44,73	1	1	1	1	1	1	1	1	4
	03/10/22 20:00	44,62	1	1	1	1	1	1	1	1	4
	03/10/22 21:00	41,29	1	1	1	1	1	1	1	1	
	03/10/22 22:00	38,40	1	1	1	1	1	1	1	1	
03/10/22 23:00	35,80	1	1	1		1	1	1	1		
		Μη διαθεσιμότητα μονάδας λόγω συντήρησης.									
		Μη διαθεσιμότητα μονάδας λόγω βλάβης.									

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τρίτη 4/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τρίτη	04/10/22 0:00	33,72	1	1	1	1	1	1		1	1
	04/10/22 1:00	31,67	1	1	1	1	1	1		1	
	04/10/22 2:00	30,66	1	1	1	1	1	1		1	
	04/10/22 3:00	29,66	1	1	1	1	1	1		1	
	04/10/22 4:00	29,27	1	1	1	1	1	1		1	
	04/10/22 5:00	29,22	1	1	1	1	1	1		1	
	04/10/22 6:00	31,54	1	1	1	1	1	1		1	
	04/10/22 7:00	34,33	1	1	1	1	1	1		1	2
	04/10/22 8:00	39,32	1	1	1	1	1	1		1	8
	04/10/22 9:00	42,57	1	1	1	1	1	1		1	11
	04/10/22 10:00	43,75	1	1	1	1	1	1		1	13
	04/10/22 11:00	44,13	1	1	1	1	1	1		1	13
	04/10/22 12:00	44,39	1	1	1	1	1	1		1	13
	04/10/22 13:00	44,73	1	1	1	1	1	1		1	13
	04/10/22 14:00	45,35	1	1	1	1	1	1		1	14
	04/10/22 15:00	43,14	1	1	1	1	1	1		1	13
	04/10/22 16:00	42,82	1	1	1	1	1	1		1	13
	04/10/22 17:00	44,04	1	1	1	1	1	1		1	13
	04/10/22 18:00	44,37	1	1	1	1	1	1		1	14
	04/10/22 19:00	45,49	1	1	1	1	1	1		1	14
04/10/22 20:00	45,76	1	1	1	1	1	1		1	14	
04/10/22 21:00	43,07	1	1	1	1	1	1		1	13	
04/10/22 22:00	39,14	1	1	1	1	1	1		1	7	
04/10/22 23:00	36,89	1	1	1	1	1	1		1	5	
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 5/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	05/10/22 0:00	33,06	1	1	1	1	1	1		1	1
	05/10/22 1:00	31,04	1	1	1	1	1	1		1	
	05/10/22 2:00	29,76	1	1	1	1	1	1		1	
	05/10/22 3:00	29,06	1	1	1	1	1	1		1	
	05/10/22 4:00	28,40	1	1	1	1	1	1		1	
	05/10/22 5:00	28,47	1	1	1	1	1	1		1	
	05/10/22 6:00	30,39	1	1	1	1	1	1		1	
	05/10/22 7:00	34,37	1	1	1	1	1	1		1	2
	05/10/22 8:00	38,58	1	1	1	1	1	1		1	7
	05/10/22 9:00	40,87	1	1	1	1	1	1		1	10
	05/10/22 10:00	41,91	1	1	1	1	1	1		1	11
	05/10/22 11:00	42,31	1	1	1	1	1	1		1	11
	05/10/22 12:00	42,07	1	1	1	1	1	1		1	11
	05/10/22 13:00	43,10	1	1	1	1	1	1		1	12
	05/10/22 14:00	42,98	1	1	1	1	1	1		1	12
	05/10/22 15:00	41,49	1	1	1	1	1	1		1	10
	05/10/22 16:00	41,16	1	1	1	1	1	1		1	10
	05/10/22 17:00	42,08	1	1	1	1	1	1		1	11
	05/10/22 18:00	43,19	1	1	1	1	1	1		1	12
	05/10/22 19:00	44,94	1	1	1	1	1	1		1	14
05/10/22 20:00	45,06	1	1	1	1	1	1		1	14	
05/10/22 21:00	42,15	1	1	1	1	1	1		1	11	
05/10/22 22:00	38,94	1	1	1	1	1	1		1	7	
05/10/22 23:00	36,04	1	1	1	1	1	1		1	4	
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη 6/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	06/10/22 0:00	32,69	1	1	1			1	1	1	
	06/10/22 1:00	31,65	1	1	1			1	1	1	
	06/10/22 2:00	30,72	1	1	1			1	1	1	
	06/10/22 3:00	29,55	1	1	1			1	1	1	
	06/10/22 4:00	29,25	1	1	1			1	1	1	
	06/10/22 5:00	29,93	1	1	1			1	1	1	
	06/10/22 6:00	31,53	1	1	1			1	1	1	
	06/10/22 7:00	34,74	1	1	1			1	1	1	
	06/10/22 8:00	39,59	1	1	1	1	1	1	1	1	
	06/10/22 9:00	40,94	1	1	1	1	1	1	1	1	
	06/10/22 10:00	41,53	1	1	1	1	1	1	1	1	
	06/10/22 11:00	42,41	1	1	1	1	1	1	1	1	1
	06/10/22 12:00	42,78	1	1	1	1	1	1	1	1	2
	06/10/22 13:00	43,78	1	1	1	1	1	1	1	1	3
	06/10/22 14:00	43,39	1	1	1	1	1	1	1	1	2
	06/10/22 15:00	42,07	1	1	1	1	1	1	1	1	1
	06/10/22 16:00	41,65	1	1	1	1	1	1	1	1	1
	06/10/22 17:00	41,99	1	1	1	1	1	1	1	1	1
	06/10/22 18:00	44,07	1	1	1	1	1	1	1	1	3
	06/10/22 19:00	44,52	1	1	1	1	1	1	1	1	4
06/10/22 20:00	43,72	1	1	1	1	1	1	1	1	3	
06/10/22 21:00	40,92	1	1	1	1	1	1	1	1		
06/10/22 22:00	37,91	1	1	1		1	1	1	1		
06/10/22 23:00	35,10	1	1	1		1	1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή 7/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	07/10/22 0:00	33,04	1	1	1			1	1	1	
	07/10/22 1:00	31,68	1	1	1			1	1	1	
	07/10/22 2:00	30,62	1	1	1			1	1	1	
	07/10/22 3:00	29,53	1	1	1			1	1	1	
	07/10/22 4:00	29,28	1	1	1			1	1	1	
	07/10/22 5:00	29,77	1	1	1			1	1	1	
	07/10/22 6:00	31,53	1	1	1			1	1	1	
	07/10/22 7:00	35,39	1	1	1			1	1	1	
	07/10/22 8:00	38,55	1	1	1	1		1	1	1	
	07/10/22 9:00	40,21	1	1	1	1	1	1	1	1	
	07/10/22 10:00	41,14	1	1	1	1	1	1	1	1	
	07/10/22 11:00	42,50	1	1	1	1	1	1	1	1	1
	07/10/22 12:00	42,91	1	1	1	1	1	1	1	1	2
	07/10/22 13:00	43,68	1	1	1	1	1	1	1	1	3
	07/10/22 14:00	43,34	1	1	1	1	1	1	1	1	2
	07/10/22 15:00	42,07	1	1	1	1	1	1	1	1	1
	07/10/22 16:00	41,65	1	1	1	1	1	1	1	1	1
	07/10/22 17:00	42,08	1	1	1	1	1	1	1	1	1
	07/10/22 18:00	44,32	1	1	1	1	1	1	1	1	3
	07/10/22 19:00	45,28	1	1	1	1	1	1	1	1	4
07/10/22 20:00	44,37	1	1	1	1	1	1	1	1	3	
07/10/22 21:00	41,27	1	1	1	1	1	1	1	1		
07/10/22 22:00	38,55	1	1	1		1	1	1	1		
07/10/22 23:00	35,43	1	1	1		1	1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο 8/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	08/10/22 0:00	32,48	1	1	1			1	1	1	
	08/10/22 1:00	31,09	1	1	1			1	1	1	
	08/10/22 2:00	29,75	1	1	1			1	1	1	
	08/10/22 3:00	28,68	1	1	1			1	1	1	
	08/10/22 4:00	28,61	1	1	1			1	1	1	
	08/10/22 5:00	29,13	1	1	1			1	1	1	
	08/10/22 6:00	30,60	1	1	1			1	1	1	
	08/10/22 7:00	34,98	1	1	1			1	1	1	
	08/10/22 8:00	37,57	1	1	1	1		1	1	1	
	08/10/22 9:00	38,74	1	1	1	1		1	1	1	
	08/10/22 10:00	39,93	1	1	1	1	1	1	1	1	
	08/10/22 11:00	41,32	1	1	1	1	1	1	1	1	
	08/10/22 12:00	41,45	1	1	1	1	1	1	1	1	
	08/10/22 13:00	42,00	1	1	1	1	1	1	1	1	
	08/10/22 14:00	41,73	1	1	1	1	1	1	1	1	
	08/10/22 15:00	40,89	1	1	1	1	1	1	1	1	
	08/10/22 16:00	40,45	1	1	1	1	1	1	1	1	
	08/10/22 17:00	40,96	1	1	1	1	1	1	1	1	
	08/10/22 18:00	43,61	1	1	1	1	1	1	1	1	2
	08/10/22 19:00	45,00	1	1	1	1	1	1	1	1	4
08/10/22 20:00	44,06	1	1	1	1	1	1	1	1	3	
08/10/22 21:00	41,04	1	1	1	1	1	1	1	1		
08/10/22 22:00	38,69	1	1	1		1	1	1	1		
08/10/22 23:00	35,22	1	1	1			1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή 9/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Κυριακή	09/10/22 0:00	32,17	1	1	1			1	1	1	
	09/10/22 1:00	30,78	1	1	1			1	1	1	
	09/10/22 2:00	29,39	1	1	1			1	1	1	
	09/10/22 3:00	28,32	1	1	1			1	1	1	
	09/10/22 4:00	28,30	1	1	1			1	1	1	
	09/10/22 5:00	28,83	1	1	1			1	1	1	
	09/10/22 6:00	30,21	1	1	1			1	1	1	
	09/10/22 7:00	34,71	1	1	1			1	1	1	
	09/10/22 8:00	37,14	1	1	1	1		1	1	1	
	09/10/22 9:00	38,33	1	1	1	1		1	1	1	
	09/10/22 10:00	39,43	1	1	1	1	1	1	1	1	
	09/10/22 11:00	40,82	1	1	1	1	1	1	1	1	
	09/10/22 12:00	41,08	1	1	1	1	1	1	1	1	
	09/10/22 13:00	41,57	1	1	1	1	1	1	1	1	
	09/10/22 14:00	41,33	1	1	1	1	1	1	1	1	
	09/10/22 15:00	40,39	1	1	1	1	1	1	1	1	
	09/10/22 16:00	39,95	1	1	1	1	1	1	1	1	
	09/10/22 17:00	40,47	1	1	1	1	1	1	1	1	
	09/10/22 18:00	43,22	1	1	1	1	1	1	1	1	2
	09/10/22 19:00	44,71	1	1	1	1	1	1	1	1	4
09/10/22 20:00	43,33	1	1	1	1	1	1	1	1	2	
09/10/22 21:00	40,78	1	1	1	1	1	1	1	1		
09/10/22 22:00	38,53	1	1	1		1	1	1	1		
09/10/22 23:00	34,99	1	1	1			1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα				10/10/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	10/10/22 0:00	32,32	1	1	1			1	1	1	
	10/10/22 1:00	30,93	1	1	1			1	1	1	
	10/10/22 2:00	29,57	1	1	1			1	1	1	
	10/10/22 3:00	28,50	1	1	1			1	1	1	
	10/10/22 4:00	28,46	1	1	1			1	1	1	
	10/10/22 5:00	28,98	1	1	1			1	1	1	
	10/10/22 6:00	30,40	1	1	1			1	1	1	
	10/10/22 7:00	34,84	1	1	1			1	1	1	
	10/10/22 8:00	37,36	1	1	1	1		1	1	1	
	10/10/22 9:00	38,54	1	1	1	1		1	1	1	
	10/10/22 10:00	39,68	1	1	1	1	1	1	1	1	
	10/10/22 11:00	41,07	1	1	1	1	1	1	1	1	
	10/10/22 12:00	41,27	1	1	1	1	1	1	1	1	
	10/10/22 13:00	41,62	1	1	1	1	1	1	1	1	
	10/10/22 14:00	41,49	1	1	1	1	1	1	1	1	
	10/10/22 15:00	40,64	1	1	1	1	1	1	1	1	
	10/10/22 16:00	40,20	1	1	1	1	1	1	1	1	
	10/10/22 17:00	40,71	1	1	1	1	1	1	1	1	
	10/10/22 18:00	43,20	1	1	1	1	1	1	1	1	2
	10/10/22 19:00	44,86	1	1	1	1	1	1	1	1	4
10/10/22 20:00	43,70	1	1	1	1	1	1	1	1	3	
10/10/22 21:00	40,91	1	1	1	1	1	1	1	1		
10/10/22 22:00	38,61	1	1	1		1	1	1	1		
10/10/22 23:00	35,10	1	1	1		1	1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τρίτη 11/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τρίτη	11/10/22 0:00	31,75	1	1	1			1	1	1	
	11/10/22 1:00	30,35	1	1	1			1	1	1	
	11/10/22 2:00	28,91	1	1	1			1	1	1	
	11/10/22 3:00	28,02	1	1	1			1	1	1	
	11/10/22 4:00	27,59	1	1	1			1	1	1	
	11/10/22 5:00	28,17	1	1	1			1	1	1	
	11/10/22 6:00	29,58	1	1	1			1	1	1	
	11/10/22 7:00	33,78	1	1	1			1	1	1	
	11/10/22 8:00	37,93	1	1	1	1		1	1	1	
	11/10/22 9:00	39,44	1	1	1	1	1	1	1	1	
	11/10/22 10:00	40,23	1	1	1	1	1	1	1	1	
	11/10/22 11:00	40,39	1	1	1	1	1	1	1	1	
	11/10/22 12:00	40,54	1	1	1	1	1	1	1	1	
	11/10/22 13:00	41,58	1	1	1	1	1	1	1	1	
	11/10/22 14:00	41,13	1	1	1	1	1	1	1	1	
	11/10/22 15:00	40,48	1	1	1	1	1	1	1	1	
	11/10/22 16:00	39,93	1	1	1	1	1	1	1	1	
	11/10/22 17:00	40,25	1	1	1	1	1	1	1	1	
	11/10/22 18:00	42,85	1	1	1	1	1	1	1	1	2
	11/10/22 19:00	43,57	1	1	1	1	1	1	1	1	2
11/10/22 20:00	42,01	1	1	1	1	1	1	1	1	1	
11/10/22 21:00	39,66	1	1	1	1	1	1	1	1		
11/10/22 22:00	37,20	1	1	1		1	1	1	1		
11/10/22 23:00	34,20	1	1	1			1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 12/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	12/10/22 0:00	32,07	1	1	1			1	1	1	
	12/10/22 1:00	30,66	1	1	1			1	1	1	
	12/10/22 2:00	29,20	1	1	1			1	1	1	
	12/10/22 3:00	28,30	1	1	1			1	1	1	
	12/10/22 4:00	27,87	1	1	1			1	1	1	
	12/10/22 5:00	28,45	1	1	1			1	1	1	
	12/10/22 6:00	29,88	1	1	1			1	1	1	
	12/10/22 7:00	34,12	1	1	1			1	1	1	
	12/10/22 8:00	38,31	1	1	1	1		1	1	1	
	12/10/22 9:00	39,83	1	1	1	1	1	1	1	1	
	12/10/22 10:00	40,63	1	1	1	1	1	1	1	1	
	12/10/22 11:00	40,79	1	1	1	1	1	1	1	1	
	12/10/22 12:00	40,95	1	1	1	1	1	1	1	1	
	12/10/22 13:00	42,00	1	1	1	1	1	1	1	1	
	12/10/22 14:00	41,54	1	1	1	1	1	1	1	1	
	12/10/22 15:00	40,89	1	1	1	1	1	1	1	1	
	12/10/22 16:00	40,33	1	1	1	1	1	1	1	1	
	12/10/22 17:00	40,65	1	1	1	1	1	1	1	1	
	12/10/22 18:00	43,28	1	1	1	1	1	1	1	1	2
	12/10/22 19:00	43,96	1	1	1	1	1	1	1	1	3
12/10/22 20:00	42,43	1	1	1	1	1	1	1	1	1	
12/10/22 21:00	40,06	1	1	1	1	1	1	1	1		
12/10/22 22:00	37,57	1	1	1		1	1	1	1		
12/10/22 23:00	34,54	1	1	1			1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης. Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη 13/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	13/10/22 0:00	30,30	1	1				1	1	1	
	13/10/22 1:00	28,45	1	1				1	1	1	
	13/10/22 2:00	27,27	1	1				1	1	1	
	13/10/22 3:00	26,47	1	1				1	1	1	
	13/10/22 4:00	28,51	1	1				1	1	1	
	13/10/22 5:00	28,67	1	1				1	1	1	
	13/10/22 6:00	30,27	1	1				1	1	1	
	13/10/22 7:00	32,59	1	1				1	1	1	
	13/10/22 8:00	35,61	1	1	1			1	1	1	
	13/10/22 9:00	37,01	1	1	1		1	1	1	1	
	13/10/22 10:00	38,19	1	1	1		1	1	1	1	
	13/10/22 11:00	38,54	1	1	1		1	1	1	1	
	13/10/22 12:00	38,71	1	1	1		1	1	1	1	
	13/10/22 13:00	38,67	1	1	1		1	1	1	1	
	13/10/22 14:00	38,58	1	1	1		1	1	1	1	
	13/10/22 15:00	37,65	1	1	1		1	1	1	1	
	13/10/22 16:00	37,13	1	1	1		1	1	1	1	
	13/10/22 17:00	37,46	1	1	1		1	1	1	1	
	13/10/22 18:00	38,73	1	1	1		1	1	1	1	
	13/10/22 19:00	41,34	1	1	1	1	1	1	1	1	
13/10/22 20:00	40,92	1	1	1	1	1	1	1	1		
13/10/22 21:00	39,04	1	1	1	1	1	1	1	1		
13/10/22 22:00	35,94	1	1	1		1	1	1	1		
13/10/22 23:00	32,47	1	1				1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης. Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή 14/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	14/10/22 0:00	29,85	1	1				1	1	1	
	14/10/22 1:00	28,03	1	1				1	1	1	
	14/10/22 2:00	26,87	1	1				1	1	1	
	14/10/22 3:00	26,07	1	1				1	1	1	
	14/10/22 4:00	28,09	1	1				1	1	1	
	14/10/22 5:00	28,24	1	1				1	1	1	
	14/10/22 6:00	29,82	1	1				1	1	1	
	14/10/22 7:00	32,11	1	1				1	1	1	
	14/10/22 8:00	35,08	1	1	1			1	1	1	
	14/10/22 9:00	36,46	1	1	1		1	1	1	1	
	14/10/22 10:00	37,62	1	1	1		1	1	1	1	
	14/10/22 11:00	37,97	1	1	1		1	1	1	1	
	14/10/22 12:00	38,47	1	1	1		1	1	1	1	
	14/10/22 13:00	38,37	1	1	1		1	1	1	1	
	14/10/22 14:00	38,01	1	1	1		1	1	1	1	
	14/10/22 15:00	37,10	1	1	1		1	1	1	1	
	14/10/22 16:00	36,59	1	1	1		1	1	1	1	
	14/10/22 17:00	36,91	1	1	1		1	1	1	1	
	14/10/22 18:00	38,20	1	1	1		1	1	1	1	
	14/10/22 19:00	40,72	1	1	1	1	1	1	1	1	
14/10/22 20:00	40,31	1	1	1	1	1	1	1	1		
14/10/22 21:00	38,46	1	1	1		1	1	1	1		
14/10/22 22:00	35,41	1	1	1			1	1	1		
14/10/22 23:00	31,99	1	1				1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο 15/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	15/10/22 0:00	29,19	1	1				1	1	1	
	15/10/22 1:00	27,46	1	1				1	1	1	
	15/10/22 2:00	26,44	1	1				1	1	1	
	15/10/22 3:00	25,53	1	1				1	1	1	
	15/10/22 4:00	25,26	1	1				1	1	1	
	15/10/22 5:00	25,60	1	1				1	1	1	
	15/10/22 6:00	27,91	1	1				1	1	1	
	15/10/22 7:00	32,11	1	1				1	1	1	
	15/10/22 8:00	35,30	1	1	1			1	1	1	
	15/10/22 9:00	37,04	1	1	1		1	1	1	1	
	15/10/22 10:00	37,59	1	1	1		1	1	1	1	
	15/10/22 11:00	37,98	1	1	1		1	1	1	1	
	15/10/22 12:00	38,33	1	1	1		1	1	1	1	
	15/10/22 13:00	38,19	1	1	1		1	1	1	1	
	15/10/22 14:00	37,94	1	1	1		1	1	1	1	
	15/10/22 15:00	37,17	1	1	1		1	1	1	1	
	15/10/22 16:00	36,81	1	1	1		1	1	1	1	
	15/10/22 17:00	37,14	1	1	1		1	1	1	1	
	15/10/22 18:00	38,67	1	1	1		1	1	1	1	
	15/10/22 19:00	41,15	1	1	1	1	1	1	1	1	
15/10/22 20:00	40,52	1	1	1	1	1	1	1	1		
15/10/22 21:00	38,41	1	1	1		1	1	1	1		
15/10/22 22:00	35,39	1	1	1			1	1	1		
15/10/22 23:00	32,01	1	1	1			1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή 16/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Κυριακή	16/10/22 0:00	30,29	1	1				1	1	1	
	16/10/22 1:00	28,43	1	1				1	1	1	
	16/10/22 2:00	27,16	1	1				1	1	1	
	16/10/22 3:00	26,15	1	1				1	1	1	
	16/10/22 4:00	26,00	1	1				1	1	1	
	16/10/22 5:00	26,34	1	1				1	1	1	
	16/10/22 6:00	28,22	1	1				1	1	1	
	16/10/22 7:00	31,81	1	1				1	1	1	
	16/10/22 8:00	35,41	1	1	1			1	1	1	
	16/10/22 9:00	36,52	1	1	1		1	1	1	1	
	16/10/22 10:00	36,98	1	1	1		1	1	1	1	
	16/10/22 11:00	38,15	1	1	1		1	1	1	1	
	16/10/22 12:00	38,21	1	1	1		1	1	1	1	
	16/10/22 13:00	38,26	1	1	1		1	1	1	1	
	16/10/22 14:00	38,19	1	1	1		1	1	1	1	
	16/10/22 15:00	37,09	1	1	1		1	1	1	1	
	16/10/22 16:00	36,63	1	1	1		1	1	1	1	
	16/10/22 17:00	37,01	1	1	1		1	1	1	1	
	16/10/22 18:00	38,34	1	1	1		1	1	1	1	
	16/10/22 19:00	40,80	1	1	1	1	1	1	1	1	
16/10/22 20:00	40,52	1	1	1	1	1	1	1	1		
16/10/22 21:00	38,57	1	1	1		1	1	1	1		
16/10/22 22:00	35,44	1	1	1		1	1	1	1		
16/10/22 23:00	32,07	1	1				1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα		17/10/2022		
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	17/10/22 0:00	30,08	1	1				1	1	1	
	17/10/22 1:00	28,28	1	1				1	1	1	
	17/10/22 2:00	27,06	1	1				1	1	1	
	17/10/22 3:00	26,26	1	1				1	1	1	
	17/10/22 4:00	25,83	1	1				1	1	1	
	17/10/22 5:00	26,34	1	1				1	1	1	
	17/10/22 6:00	28,49	1	1				1	1	1	
	17/10/22 7:00	32,71	1	1				1	1	1	
	17/10/22 8:00	35,71	1	1			1	1	1	1	
	17/10/22 9:00	37,56	1	1	1		1	1	1	1	
	17/10/22 10:00	38,14	1	1	1		1	1	1	1	
	17/10/22 11:00	38,47	1	1	1		1	1	1	1	
	17/10/22 12:00	38,76	1	1	1		1	1	1	1	
	17/10/22 13:00	38,56	1	1	1		1	1	1	1	
	17/10/22 14:00	38,24	1	1	1		1	1	1	1	
	17/10/22 15:00	37,34	1	1	1		1	1	1	1	
	17/10/22 16:00	36,95	1	1	1		1	1	1	1	
	17/10/22 17:00	37,21	1	1	1		1	1	1	1	
	17/10/22 18:00	38,68	1	1	1		1	1	1	1	
	17/10/22 19:00	41,42	1	1	1	1	1	1	1	1	
17/10/22 20:00	40,72	1	1	1	1	1	1	1	1		
17/10/22 21:00	38,66	1	1	1		1	1	1	1		
17/10/22 22:00	35,53	1	1			1	1	1	1		
17/10/22 23:00	32,02	1	1				1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τρίτη				18/10/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τρίτη	18/10/22 0:00	29,17	1	1				1	1	1	
	18/10/22 1:00	27,44	1	1				1	1	1	
	18/10/22 2:00	26,30	1	1				1	1	1	
	18/10/22 3:00	25,50	1	1				1	1	1	
	18/10/22 4:00	26,41	1	1				1	1	1	
	18/10/22 5:00	26,63	1	1				1	1	1	
	18/10/22 6:00	28,54	1	1				1	1	1	
	18/10/22 7:00	31,64	1	1				1	1	1	
	18/10/22 8:00	34,20	1	1				1	1	1	
	18/10/22 9:00	37,16	1	1	1		1	1	1	1	
	18/10/22 10:00	38,32	1	1	1	1	1	1	1	1	
	18/10/22 11:00	38,44	1	1	1		1	1	1	1	
	18/10/22 12:00	38,61	1	1	1		1	1	1	1	
	18/10/22 13:00	38,84	1	1	1		1	1	1	1	
	18/10/22 14:00	38,34	1	1	1		1	1	1	1	
	18/10/22 15:00	37,52	1	1	1		1	1	1	1	
	18/10/22 16:00	37,04	1	1	1	1	1	1	1	1	
	18/10/22 17:00	37,05	1	1	1		1	1	1	1	
	18/10/22 18:00	38,37	1	1	1		1	1	1	1	
	18/10/22 19:00	40,87	1	1	1		1	1	1	1	
18/10/22 20:00	40,38	1	1	1		1	1	1	1		
18/10/22 21:00	38,32	1	1	1		1	1	1	1		
18/10/22 22:00	35,34	1	1			1	1	1	1		
18/10/22 23:00	31,95	1	1				1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 19/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	19/10/22 0:00	29,07	1	1				1	1	1	
	19/10/22 1:00	27,31	1	1				1	1	1	
	19/10/22 2:00	26,13	1	1				1	1	1	
	19/10/22 3:00	25,31	1	1				1	1	1	
	19/10/22 4:00	25,42	1	1				1	1	1	
	19/10/22 5:00	25,73	1	1				1	1	1	
	19/10/22 6:00	27,77	1	1				1	1	1	
	19/10/22 7:00	31,43	1	1				1	1	1	
	19/10/22 8:00	34,45	1	1	1			1	1	1	
	19/10/22 9:00	36,72	1	1	1	1		1	1	1	
	19/10/22 10:00	37,74	1	1	1	1		1	1	1	
	19/10/22 11:00	38,28	1	1	1	1		1	1	1	
	19/10/22 12:00	38,75	1	1	1	1		1	1	1	
	19/10/22 13:00	38,97	1	1	1	1		1	1	1	
	19/10/22 14:00	38,58	1	1	1	1		1	1	1	
	19/10/22 15:00	37,70	1	1	1	1		1	1	1	
	19/10/22 16:00	37,07	1	1	1	1		1	1	1	
	19/10/22 17:00	37,22	1	1	1	1		1	1	1	
	19/10/22 18:00	38,59	1	1	1	1		1	1	1	
	19/10/22 19:00	41,05	1	1	1	1	1	1	1	1	
19/10/22 20:00	40,50	1	1	1	1	1	1	1	1		
19/10/22 21:00	38,34	1	1	1	1		1	1	1		
19/10/22 22:00	35,35	1	1	1			1	1	1		
19/10/22 23:00	31,98	1	1				1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη 20/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	20/10/22 0:00	29,03	1	1				1	1	1	
	20/10/22 1:00	27,31	1	1				1	1	1	
	20/10/22 2:00	26,10	1	1				1	1	1	
	20/10/22 3:00	25,34	1	1				1	1	1	
	20/10/22 4:00	25,26	1	1				1	1	1	
	20/10/22 5:00	25,46	1	1				1	1	1	
	20/10/22 6:00	27,05	1	1				1	1	1	
	20/10/22 7:00	30,48	1	1				1	1	1	
	20/10/22 8:00	33,79	1	1	1			1	1	1	
	20/10/22 9:00	37,10	1	1	1	1		1	1	1	
	20/10/22 10:00	38,04	1	1	1	1		1	1	1	
	20/10/22 11:00	38,19	1	1	1	1		1	1	1	
	20/10/22 12:00	38,26	1	1	1	1		1	1	1	
	20/10/22 13:00	38,61	1	1	1	1		1	1	1	
	20/10/22 14:00	38,02	1	1	1	1		1	1	1	
	20/10/22 15:00	37,05	1	1	1	1		1	1	1	
	20/10/22 16:00	36,38	1	1	1	1		1	1	1	
	20/10/22 17:00	36,50	1	1	1	1		1	1	1	
	20/10/22 18:00	37,82	1	1	1	1		1	1	1	
	20/10/22 19:00	40,40	1	1	1	1	1	1	1	1	
20/10/22 20:00	40,01	1	1	1	1	1	1	1	1		
20/10/22 21:00	37,89	1	1	1	1		1	1	1		
20/10/22 22:00	34,84	1	1	1			1	1	1		
20/10/22 23:00	31,35	1	1				1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης. Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή				21/10/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	21/10/22 0:00	28,53	1	1				1	1	1	
	21/10/22 1:00	26,78	1	1				1	1	1	
	21/10/22 2:00	25,56	1	1				1	1	1	
	21/10/22 3:00	24,92	1	1				1	1	1	
	21/10/22 4:00	24,84	1	1				1	1	1	
	21/10/22 5:00	25,07	1	1				1	1	1	
	21/10/22 6:00	26,65	1	1				1	1	1	
	21/10/22 7:00	29,83	1	1				1	1	1	
	21/10/22 8:00	33,26	1	1				1	1	1	
	21/10/22 9:00	35,68	1	1	1			1	1	1	
	21/10/22 10:00	36,53	1	1	1	1		1	1	1	
	21/10/22 11:00	36,94	1	1	1	1		1	1	1	
	21/10/22 12:00	37,45	1	1	1	1		1	1	1	
	21/10/22 13:00	37,59	1	1	1	1		1	1	1	
	21/10/22 14:00	37,32	1	1	1	1		1	1	1	
	21/10/22 15:00	36,56	1	1	1	1		1	1	1	
	21/10/22 16:00	35,70	1	1	1	1		1	1	1	
	21/10/22 17:00	36,00	1	1	1	1		1	1	1	
	21/10/22 18:00	37,51	1	1	1	1		1	1	1	
	21/10/22 19:00	39,75	1	1	1	1		1	1	1	
21/10/22 20:00	39,18	1	1	1	1		1	1	1		
21/10/22 21:00	37,27	1	1	1	1		1	1	1		
21/10/22 22:00	34,25	1	1	1			1	1	1		
21/10/22 23:00	30,78	1	1				1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο				22/10/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	22/10/22 0:00	28,44	1	1				1	1	1	
	22/10/22 1:00	26,66	1	1				1	1	1	
	22/10/22 2:00	25,39	1	1				1	1	1	
	22/10/22 3:00	24,77	1	1				1	1	1	
	22/10/22 4:00	24,64	1	1				1	1	1	
	22/10/22 5:00	25,00	1	1				1	1	1	
	22/10/22 6:00	27,14	1	1				1	1	1	
	22/10/22 7:00	29,74	1	1				1	1	1	
	22/10/22 8:00	33,13	1	1				1	1	1	
	22/10/22 9:00	35,71	1	1	1			1	1	1	
	22/10/22 10:00	37,53	1	1	1	1		1	1	1	
	22/10/22 11:00	37,34	1	1	1	1		1	1	1	
	22/10/22 12:00	37,63	1	1	1	1		1	1	1	
	22/10/22 13:00	37,80	1	1	1	1		1	1	1	
	22/10/22 14:00	37,51	1	1	1	1		1	1	1	
	22/10/22 15:00	36,61	1	1	1	1		1	1	1	
	22/10/22 16:00	35,81	1	1	1	1		1	1	1	
	22/10/22 17:00	36,08	1	1	1	1		1	1	1	
	22/10/22 18:00	37,94	1	1	1	1		1	1	1	
	22/10/22 19:00	40,01	1	1	1	1		1	1	1	
22/10/22 20:00	39,14	1	1	1	1		1	1	1		
22/10/22 21:00	37,00	1	1	1			1	1	1		
22/10/22 22:00	33,80	1	1				1	1	1		
22/10/22 23:00	30,93	1	1				1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή 23/10/2022					
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1	
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)	
Κυριακή	23/10/22 0:00	28,13	1	1				1	1	1		
	23/10/22 1:00	26,37	1	1				1	1	1		
	23/10/22 2:00	25,14	1	1	1			1	1	1		
	23/10/22 3:00	24,59	1	1				1	1	1		
	23/10/22 4:00	24,38	1	1				1	1	1		
	23/10/22 5:00	24,77	1	1				1	1	1		
	23/10/22 6:00	26,91	1	1				1	1	1		
	23/10/22 7:00	29,32	1	1				1	1	1		
	23/10/22 8:00	32,70	1	1				1	1	1		
	23/10/22 9:00	35,25	1	1	1			1	1	1		
	23/10/22 10:00	37,08	1	1	1	1		1	1	1		
	23/10/22 11:00	36,54	1	1	1	1		1	1	1		
	23/10/22 12:00	36,70	1	1	1	1		1	1	1		
	23/10/22 13:00	36,80	1	1	1	1	1	1	1	1		
	23/10/22 14:00	36,56	1	1	1	1		1	1	1		
	23/10/22 15:00	35,72	1	1	1	1		1	1	1		
	23/10/22 16:00	34,90	1	1	1	1		1	1	1		
	23/10/22 17:00	35,36	1	1	1	1	1	1	1	1		
	23/10/22 18:00	37,40	1	1	1	1	1		1	1	1	
	23/10/22 19:00	39,43	1	1	1	1	1		1	1	1	
23/10/22 20:00	38,45	1	1	1	1	1		1	1	1		
23/10/22 21:00	36,39	1	1	1				1	1	1		
23/10/22 22:00	33,09	1	1					1	1	1		
23/10/22 23:00	30,30	1	1					1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.												
Μη διαθεσιμότητα μονάδας λόγω βλάβης.												

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα				24/10/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	24/10/22 0:00	29,04	1	1				1	1	1	
	24/10/22 1:00	27,26	1	1				1	1	1	
	24/10/22 2:00	26,05	1	1				1	1	1	
	24/10/22 3:00	25,26	1	1				1	1	1	
	24/10/22 4:00	25,16	1	1				1	1	1	
	24/10/22 5:00	25,50	1	1				1	1	1	
	24/10/22 6:00	27,60	1	1				1	1	1	
	24/10/22 7:00	31,18	1	1				1	1	1	
	24/10/22 8:00	34,20	1	1				1	1	1	
	24/10/22 9:00	36,57	1	1	1			1	1	1	
	24/10/22 10:00	37,74	1	1	1	1		1	1	1	
	24/10/22 11:00	38,22	1	1	1	1		1	1	1	
	24/10/22 12:00	38,71	1	1	1	1		1	1	1	
	24/10/22 13:00	38,92	1	1	1	1		1	1	1	
	24/10/22 14:00	38,57	1	1	1	1		1	1	1	
	24/10/22 15:00	37,67	1	1	1	1		1	1	1	
	24/10/22 16:00	36,97	1	1	1	1		1	1	1	
	24/10/22 17:00	37,17	1	1	1	1		1	1	1	
	24/10/22 18:00	38,66	1	1	1	1		1	1	1	
	24/10/22 19:00	41,04	1	1	1	1	1	1	1	1	
24/10/22 20:00	40,41	1	1	1	1	1	1	1	1		
24/10/22 21:00	38,22	1	1	1	1		1	1	1		
24/10/22 22:00	35,18	1	1	1			1	1	1		
24/10/22 23:00	31,90	1	1				1	1	1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τρίτη 25/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τρίτη	25/10/22 0:00	27,81	1	1		1		1		1	
	25/10/22 1:00	26,14	1	1		1		1		1	
	25/10/22 2:00	25,01	1	1		1		1		1	
	25/10/22 3:00	24,50	1	1		1		1		1	
	25/10/22 4:00	24,22	1	1		1		1		1	
	25/10/22 5:00	24,52	1	1		1		1		1	
	25/10/22 6:00	26,42	1	1		1		1		1	
	25/10/22 7:00	29,56	1	1		1	1	1		1	
	25/10/22 8:00	32,54	1	1	1	1	1	1		1	
	25/10/22 9:00	35,69	1	1	1	1	1	1		1	3
	25/10/22 10:00	36,45	1	1	1	1	1	1		1	3
	25/10/22 11:00	35,88	1	1	1	1	1	1		1	2
	25/10/22 12:00	35,76	1	1	1	1	1	1		1	2
	25/10/22 13:00	35,16	1	1	1	1	1	1		1	1
	25/10/22 14:00	35,13	1	1	1	1	1	1		1	1
	25/10/22 15:00	34,28	1	1	1	1	1	1		1	
	25/10/22 16:00	34,06	1	1	1	1	1	1		1	
	25/10/22 17:00	34,78	1	1	1	1	1	1		1	1
	25/10/22 18:00	37,08	1	1	1	1	1	1		1	3
	25/10/22 19:00	38,61	1	1	1	1	1	1		1	5
25/10/22 20:00	36,82	1	1	1	1	1	1		1	3	
25/10/22 21:00	34,94	1	1	1	1	1	1		1	1	
25/10/22 22:00	31,93	1	1	1	1	1	1		1		
25/10/22 23:00	29,73	1	1	1	1		1		1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 26/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	26/10/22 0:00	26,76	1	1	1			1		1	
	26/10/22 1:00	25,23	1	1	1			1		1	
	26/10/22 2:00	24,30	1	1	1			1		1	
	26/10/22 3:00	23,73	1	1	1			1		1	
	26/10/22 4:00	23,53	1	1	1			1		1	
	26/10/22 5:00	23,71	1	1	1			1		1	
	26/10/22 6:00	25,20	1	1	1			1		1	
	26/10/22 7:00	28,62	1	1	1	1		1		1	
	26/10/22 8:00	30,71	1	1	1	1		1		1	
	26/10/22 9:00	33,18	1	1	1	1	1	1		1	
	26/10/22 10:00	33,45	1	1	1	1	1	1		1	
	26/10/22 11:00	33,68	1	1	1	1	1	1		1	
	26/10/22 12:00	33,78	1	1	1	1	1	1		1	
	26/10/22 13:00	33,76	1	1	1	1	1	1		1	
	26/10/22 14:00	33,42	1	1	1	1	1	1		1	
	26/10/22 15:00	32,25	1	1	1	1	1	1		1	
	26/10/22 16:00	32,27	1	1	1	1	1	1		1	
	26/10/22 17:00	32,66	1	1	1	1	1	1		1	
	26/10/22 18:00	36,04	1	1	1	1	1	1		1	3
	26/10/22 19:00	36,82	1	1	1	1	1	1		1	4
26/10/22 20:00	34,66	1	1	1	1	1	1		1	3	
26/10/22 21:00	32,20	1	1	1	1	1	1		1		
26/10/22 22:00	30,55	1	1	1	1	1	1		1		
26/10/22 23:00	28,17	1	1	1	1		1		1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη 27/10/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	27/10/22 0:00	24,98	1	1	1			1		1	
	27/10/22 1:00	23,84	1	1	1			1		1	
	27/10/22 2:00	22,92	1	1	1			1		1	
	27/10/22 3:00	22,32	1	1	1			1		1	
	27/10/22 4:00	22,30	1	1	1			1		1	
	27/10/22 5:00	22,57	1	1	1			1		1	
	27/10/22 6:00	24,15	1	1	1			1		1	
	27/10/22 7:00	26,58	1	1	1			1		1	
	27/10/22 8:00	30,18	1	1	1	1		1		1	
	27/10/22 9:00	32,13	1	1	1	1	1	1		1	
	27/10/22 10:00	32,59	1	1	1	1	1	1		1	
	27/10/22 11:00	32,85	1	1	1	1	1	1		1	
	27/10/22 12:00	32,90	1	1	1	1	1	1		1	
	27/10/22 13:00	32,76	1	1	1	1	1	1		1	
	27/10/22 14:00	32,28	1	1	1	1	1	1		1	
	27/10/22 15:00	31,52	1	1	1	1	1	1		1	
	27/10/22 16:00	31,10	1	1	1	1	1	1		1	
	27/10/22 17:00	31,60	1	1	1	1	1	1		1	
	27/10/22 18:00	34,88	1	1	1	1	1	1		1	3
	27/10/22 19:00	35,39	1	1	1	1	1	1		1	3
27/10/22 20:00	34,19	1	1	1	1	1	1		1	2	
27/10/22 21:00	31,40	1	1	1	1	1	1		1		
27/10/22 22:00	29,93	1	1	1	1		1		1		
27/10/22 23:00	26,89	1	1	1			1		1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή				28/10/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	28/10/22 0:00	24,31	1	1	1			1		1	
	28/10/22 1:00	22,94	1	1	1			1		1	
	28/10/22 2:00	21,97	1	1	1			1		1	
	28/10/22 3:00	21,28	1	1	1			1		1	
	28/10/22 4:00	21,30	1	1	1			1		1	
	28/10/22 5:00	21,36	1	1	1			1		1	
	28/10/22 6:00	23,30	1	1	1			1		1	
	28/10/22 7:00	26,06	1	1	1			1		1	
	28/10/22 8:00	29,15	1	1	1	1		1		1	
	28/10/22 9:00	30,45	1	1	1	1		1		1	
	28/10/22 10:00	31,06	1	1	1	1	1	1		1	
	28/10/22 11:00	31,18	1	1	1	1	1	1		1	
	28/10/22 12:00	31,28	1	1	1	1	1	1		1	
	28/10/22 13:00	31,39	1	1	1	1	1	1		1	
	28/10/22 14:00	30,99	1	1	1	1	1	1		1	
	28/10/22 15:00	30,41	1	1	1	1		1		1	
	28/10/22 16:00	30,21	1	1	1	1		1		1	
	28/10/22 17:00	30,29	1	1	1	1		1		1	
	28/10/22 18:00	31,93	1	1	1	1	1	1		1	
	28/10/22 19:00	33,46	1	1	1	1	1	1		1	
28/10/22 20:00	31,94	1	1	1	1	1	1		1		
28/10/22 21:00	31,35	1	1	1	1	1	1		1		
28/10/22 22:00	28,50	1	1	1	1		1		1		
28/10/22 23:00	26,03	1	1	1			1		1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο				29/10/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	29/10/22 0:00	24,82	1	1	1			1		1	
	29/10/22 1:00	23,73	1	1	1			1		1	
	29/10/22 2:00	22,73	1	1	1			1		1	
	29/10/22 3:00	22,06	1	1	1			1		1	
	29/10/22 4:00	22,06	1	1	1			1		1	
	29/10/22 5:00	22,20	1	1	1			1		1	
	29/10/22 6:00	23,90	1	1	1			1		1	
	29/10/22 7:00	26,30	1	1	1			1		1	
	29/10/22 8:00	29,94	1	1	1	1		1		1	
	29/10/22 9:00	31,58	1	1	1	1	1	1		1	
	29/10/22 10:00	32,24	1	1	1	1	1	1		1	
	29/10/22 11:00	32,47	1	1	1	1	1	1		1	
	29/10/22 12:00	32,34	1	1	1	1	1	1		1	
	29/10/22 13:00	32,43	1	1	1	1	1	1		1	
	29/10/22 14:00	31,97	1	1	1	1	1	1		1	
	29/10/22 15:00	31,18	1	1	1	1	1	1		1	
	29/10/22 16:00	30,88	1	1	1	1	1	1		1	
	29/10/22 17:00	31,22	1	1	1	1	1	1		1	
	29/10/22 18:00	33,44	1	1	1	1	1	1	1	1	
	29/10/22 19:00	34,56	1	1	1	1	1	1	1		1
29/10/22 20:00	32,85	1	1	1	1	1	1	1		1	
29/10/22 21:00	32,00	1	1	1	1	1	1	1		1	
29/10/22 22:00	29,51	1	1	1	1		1		1		
29/10/22 23:00	26,79	1	1	1			1		1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή				30/10/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Κυριακή	30/10/22 0:00	24,32	1	1	1			1		1	
	30/10/22 1:00	23,26	1	1	1			1		1	
	30/10/22 2:00	22,28	1	1	1			1		1	
	30/10/22 3:00	21,62	1	1	1			1		1	
	30/10/22 4:00	21,62	1	1	1			1		1	
	30/10/22 5:00	21,76	1	1	1			1		1	
	30/10/22 6:00	23,43	1	1	1			1		1	
	30/10/22 7:00	25,78	1	1	1			1		1	
	30/10/22 8:00	29,35	1	1	1	1		1		1	
	30/10/22 9:00	30,96	1	1	1	1	1	1		1	
	30/10/22 10:00	31,60	1	1	1	1	1	1		1	
	30/10/22 11:00	31,83	1	1	1	1	1	1		1	
	30/10/22 12:00	31,69	1	1	1	1	1	1		1	
	30/10/22 13:00	31,79	1	1	1	1	1	1		1	
	30/10/22 14:00	31,34	1	1	1	1	1	1		1	
	30/10/22 15:00	30,56	1	1	1	1		1		1	
	30/10/22 16:00	30,27	1	1	1	1		1		1	
	30/10/22 17:00	30,60	1	1	1	1		1		1	
	30/10/22 18:00	32,78	1	1	1	1	1	1	1	1	
	30/10/22 19:00	33,87	1	1	1	1	1	1	1	1	1
30/10/22 20:00	32,20	1	1	1	1	1	1	1	1		
30/10/22 21:00	31,37	1	1	1	1	1	1	1	1		
30/10/22 22:00	28,93	1	1	1	1		1		1		
30/10/22 23:00	26,26	1	1	1			1		1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα			31/10/2022	
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	31/10/22 0:00	24,57	1	1	1			1		1	
	31/10/22 1:00	23,50	1	1	1			1		1	
	31/10/22 2:00	22,50	1	1	1			1		1	
	31/10/22 3:00	21,84	1	1	1			1		1	
	31/10/22 4:00	21,84	1	1	1			1		1	
	31/10/22 5:00	21,98	1	1	1			1		1	
	31/10/22 6:00	23,67	1	1	1			1		1	
	31/10/22 7:00	26,04	1	1	1			1		1	
	31/10/22 8:00	29,65	1	1	1	1		1		1	
	31/10/22 9:00	31,27	1	1	1	1	1	1		1	
	31/10/22 10:00	31,92	1	1	1	1	1	1		1	
	31/10/22 11:00	32,15	1	1	1	1	1	1		1	
	31/10/22 12:00	32,02	1	1	1	1	1	1		1	
	31/10/22 13:00	32,11	1	1	1	1	1	1		1	
	31/10/22 14:00	31,65	1	1	1	1	1	1		1	
	31/10/22 15:00	30,87	1	1	1	1	1	1		1	
	31/10/22 16:00	30,58	1	1	1	1	1	1		1	
	31/10/22 17:00	30,91	1	1	1	1	1	1		1	
	31/10/22 18:00	33,11	1	1	1	1	1	1		1	
	31/10/22 19:00	34,21	1	1	1	1	1	1		1	1
31/10/22 20:00	32,52	1	1	1	1	1	1		1		
31/10/22 21:00	31,68	1	1	1	1	1	1		1		
31/10/22 22:00	29,22	1	1	1	1		1		1		
31/10/22 23:00	26,52	1	1	1			1		1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα				1/11/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	01/11/22 0:00	24,32	1	1	1			1		1	
	01/11/22 1:00	23,26	1	1	1			1		1	
	01/11/22 2:00	22,28	1	1	1			1		1	
	01/11/22 3:00	21,62	1	1	1			1		1	
	01/11/22 4:00	21,62	1	1	1			1		1	
	01/11/22 5:00	21,76	1	1	1			1		1	
	01/11/22 6:00	23,43	1	1	1			1		1	
	01/11/22 7:00	25,78	1	1	1			1		1	
	01/11/22 8:00	29,35	1	1	1	1		1		1	
	01/11/22 9:00	30,96	1	1	1	1	1	1		1	
	01/11/22 10:00	31,60	1	1	1	1	1	1		1	
	01/11/22 11:00	31,83	1	1	1	1	1	1		1	
	01/11/22 12:00	31,69	1	1	1	1	1	1		1	
	01/11/22 13:00	31,79	1	1	1	1	1	1		1	
	01/11/22 14:00	31,34	1	1	1	1	1	1		1	
	01/11/22 15:00	30,56	1	1	1	1	1	1		1	
	01/11/22 16:00	30,27	1	1	1	1	1	1		1	
	01/11/22 17:00	30,60	1	1	1	1	1	1		1	
	01/11/22 18:00	32,78	1	1	1	1	1	1		1	
	01/11/22 19:00	33,84	1	1	1	1	1	1		1	
01/11/22 20:00	32,20	1	1	1	1	1	1		1		
01/11/22 21:00	31,37	1	1	1	1	1	1		1		
01/11/22 22:00	28,93	1	1	1	1		1		1		
01/11/22 23:00	26,26	1	1	1			1		1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 2/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	02/11/22 0:00	21,57	1	1				1		1	
	02/11/22 1:00	20,32	1	1				1		1	
	02/11/22 2:00	19,49	1	1				1		1	
	02/11/22 3:00	19,07	1	1				1		1	
	02/11/22 4:00	19,04	1	1				1		1	
	02/11/22 5:00	19,45	1	1				1		1	
	02/11/22 6:00	20,54	1	1				1		1	
	02/11/22 7:00	23,08	1	1				1		1	
	02/11/22 8:00	24,73	1	1		1		1		1	
	02/11/22 9:00	26,22	1	1		1		1		1	
	02/11/22 10:00	26,83	1	1	1	1		1		1	
	02/11/22 11:00	27,01	1	1	1	1		1		1	
	02/11/22 12:00	26,98	1	1	1	1		1		1	
	02/11/22 13:00	27,02	1	1	1	1		1		1	
	02/11/22 14:00	26,36	1	1	1	1		1		1	
	02/11/22 15:00	25,85	1	1	1	1		1		1	
	02/11/22 16:00	25,72	1	1	1	1		1		1	
	02/11/22 17:00	26,99	1	1	1	1		1		1	
	02/11/22 18:00	28,45	1	1	1	1		1		1	
	02/11/22 19:00	28,08	1	1	1	1		1		1	
02/11/22 20:00	26,89	1	1	1	1		1		1		
02/11/22 21:00	25,26	1	1	1			1		1		
02/11/22 22:00	23,01	1	1				1		1		
02/11/22 23:00	21,09	1	1				1		1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης. Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη				3/11/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	03/11/22 0:00	20,76	1	1				1		1	
	03/11/22 1:00	19,52	1	1				1		1	
	03/11/22 2:00	18,80	1	1				1		1	
	03/11/22 3:00	18,48	1	1				1		1	
	03/11/22 4:00	18,43	1	1				1		1	
	03/11/22 5:00	18,88	1	1				1		1	
	03/11/22 6:00	19,99	1	1				1		1	
	03/11/22 7:00	22,51	1	1				1		1	
	03/11/22 8:00	24,27	1	1				1		1	
	03/11/22 9:00	25,59	1	1	1			1		1	
	03/11/22 10:00	26,18	1	1	1			1		1	
	03/11/22 11:00	26,32	1	1	1			1		1	
	03/11/22 12:00	26,33	1	1	1			1		1	
	03/11/22 13:00	26,31	1	1	1			1		1	
	03/11/22 14:00	25,75	1	1	1			1		1	
	03/11/22 15:00	25,17	1	1	1			1		1	
	03/11/22 16:00	25,03	1	1	1			1		1	
	03/11/22 17:00	26,32	1	1	1			1		1	
	03/11/22 18:00	27,38	1	1	1			1		1	
	03/11/22 19:00	27,08	1	1	1			1		1	
03/11/22 20:00	26,20	1	1	1			1		1		
03/11/22 21:00	24,72	1	1	1			1		1		
03/11/22 22:00	22,37	1	1				1		1		
03/11/22 23:00	20,55	1	1				1		1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή 4/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	04/11/22 0:00	18,08	1	1				1		1	
	04/11/22 1:00	16,97	1	1				1		1	
	04/11/22 2:00	16,42	1	1				1		1	
	04/11/22 3:00	16,14	1	1				1		1	
	04/11/22 4:00	16,18	1	1				1		1	
	04/11/22 5:00	16,59	1	1				1		1	
	04/11/22 6:00	17,63	1	1				1		1	
	04/11/22 7:00	20,14	1	1				1		1	
	04/11/22 8:00	22,41	1	1				1		1	
	04/11/22 9:00	23,26	1	1				1		1	
	04/11/22 10:00	23,68	1	1				1		1	
	04/11/22 11:00	23,83	1	1				1		1	
	04/11/22 12:00	23,71	1	1				1		1	
	04/11/22 13:00	23,59	1	1				1		1	
	04/11/22 14:00	23,43	1	1				1		1	
	04/11/22 15:00	22,82	1	1				1		1	
	04/11/22 16:00	22,69	1	1				1		1	
	04/11/22 17:00	23,72	1	1				1		1	
	04/11/22 18:00	24,25	1	1				1		1	
	04/11/22 19:00	24,55	1	1				1		1	
04/11/22 20:00	23,62	1	1				1		1		
04/11/22 21:00	22,05	1	1				1		1		
04/11/22 22:00	20,05	1	1				1		1		
04/11/22 23:00	18,58	1	1				1		1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο 5/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	05/11/22 0:00	17,59	1	1				1		1	
	05/11/22 1:00	16,51	1	1				1		1	
	05/11/22 2:00	15,98	1	1				1		1	
	05/11/22 3:00	15,75	1	1				1		1	
	05/11/22 4:00	15,74	1	1				1		1	
	05/11/22 5:00	16,10	1	1				1		1	
	05/11/22 6:00	17,12	1	1				1		1	
	05/11/22 7:00	19,41	1	1				1		1	
	05/11/22 8:00	21,61	1	1				1		1	
	05/11/22 9:00	22,44	1	1				1		1	
	05/11/22 10:00	23,00	1	1				1		1	
	05/11/22 11:00	23,12	1	1				1		1	
	05/11/22 12:00	23,02	1	1				1		1	
	05/11/22 13:00	22,93	1	1				1		1	
	05/11/22 14:00	22,79	1	1				1		1	
	05/11/22 15:00	22,23	1	1				1		1	
	05/11/22 16:00	21,99	1	1				1		1	
	05/11/22 17:00	23,02	1	1				1		1	
	05/11/22 18:00	23,70	1	1				1		1	
	05/11/22 19:00	24,05	1	1				1		1	
05/11/22 20:00	22,96	1	1				1		1		
05/11/22 21:00	21,47	1	1				1		1		
05/11/22 22:00	19,62	1	1				1		1		
05/11/22 23:00	18,10	1	1				1		1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή 6/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Κυριακή	06/11/22 0:00	17,33	1	1				1		1	
	06/11/22 1:00	16,26	1	1				1		1	
	06/11/22 2:00	15,74	1	1				1		1	
	06/11/22 3:00	15,51	1	1				1		1	
	06/11/22 4:00	15,51	1	1				1		1	
	06/11/22 5:00	15,86	1	1				1		1	
	06/11/22 6:00	16,86	1	1				1		1	
	06/11/22 7:00	19,12	1	1				1		1	
	06/11/22 8:00	21,29	1	1				1		1	
	06/11/22 9:00	22,10	1	1				1		1	
	06/11/22 10:00	22,65	1	1				1		1	
	06/11/22 11:00	22,78	1	1				1		1	
	06/11/22 12:00	22,68	1	1				1		1	
	06/11/22 13:00	22,59	1	1				1		1	
	06/11/22 14:00	22,45	1	1				1		1	
	06/11/22 15:00	21,90	1	1				1		1	
	06/11/22 16:00	21,66	1	1				1		1	
	06/11/22 17:00	22,67	1	1				1		1	
	06/11/22 18:00	23,35	1	1				1		1	
	06/11/22 19:00	23,69	1	1				1		1	
06/11/22 20:00	22,62	1	1				1		1		
06/11/22 21:00	21,15	1	1				1		1		
06/11/22 22:00	19,33	1	1				1		1		
06/11/22 23:00	17,83	1	1				1		1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης. Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα 7/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	07/11/22 0:00	17,44	1	1				1		1	
	07/11/22 1:00	16,39	1	1				1		1	
	07/11/22 2:00	15,82	1	1				1		1	
	07/11/22 3:00	15,51	1	1				1		1	
	07/11/22 4:00	15,55	1	1				1		1	
	07/11/22 5:00	15,85	1	1				1		1	
	07/11/22 6:00	16,82	1	1				1		1	
	07/11/22 7:00	19,12	1	1				1		1	
	07/11/22 8:00	21,37	1	1				1		1	
	07/11/22 9:00	22,21	1	1				1		1	
	07/11/22 10:00	22,73	1	1				1		1	
	07/11/22 11:00	22,90	1	1				1		1	
	07/11/22 12:00	22,71	1	1				1		1	
	07/11/22 13:00	22,65	1	1				1		1	
	07/11/22 14:00	22,54	1	1				1		1	
	07/11/22 15:00	22,06	1	1				1		1	
	07/11/22 16:00	21,82	1	1				1		1	
	07/11/22 17:00	22,74	1	1				1		1	
	07/11/22 18:00	23,27	1	1				1		1	
	07/11/22 19:00	23,75	1	1				1		1	
07/11/22 20:00	22,71	1	1				1		1		
07/11/22 21:00	21,27	1	1				1		1		
07/11/22 22:00	19,41	1	1				1		1		
07/11/22 23:00	17,92	1	1				1		1		
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα 8/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	08/11/22 0:00	15,54	1	1				1			
	08/11/22 1:00	14,74	1	1				1			
	08/11/22 2:00	14,27	1	1				1			
	08/11/22 3:00	14,01	1	1				1			
	08/11/22 4:00	13,96	1	1				1			
	08/11/22 5:00	14,06	1	1				1			
	08/11/22 6:00	14,63	1	1				1			
	08/11/22 7:00	16,45	1	1				1			1
	08/11/22 8:00	17,91							1	1	1
	08/11/22 9:00	19,24							1	1	3
	08/11/22 10:00	19,58							1	1	3
	08/11/22 11:00	20,45							1	1	4
	08/11/22 12:00	20,63							1	1	4
	08/11/22 13:00	20,66							1	1	4
	08/11/22 14:00	20,34							1	1	4
	08/11/22 15:00	19,69	1	1		1	1	1			
	08/11/22 16:00	19,40	1	1		1	1	1			
	08/11/22 17:00	20,26	1	1		1	1	1			
	08/11/22 18:00	21,36	1	1	1	1	1	1			
	08/11/22 19:00	21,02	1	1		1	1	1			
08/11/22 20:00	20,23	1	1		1	1	1				
08/11/22 21:00	19,07	1	1		1	1	1				
08/11/22 22:00	17,58	1	1		1		1				
08/11/22 23:00	16,29	1	1		1		1				

Παρατηρήσεις:

1) Η ένταξη των μονάδων κατά τις ώρες 08:30-13:30 οφείλεται σε απαίτηση του θερμικού παραγωγού για δοκιμές και τεχνικές εργασίες στον ΑΣΠ.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης.
	Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 9/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	09/11/22 0:00	14,31		1	1	1		1			
	09/11/22 1:00	13,65		1	1	1		1			
	09/11/22 2:00	13,23		1	1	1		1			
	09/11/22 3:00	12,79		1	1	1		1			
	09/11/22 4:00	12,76		1	1	1		1			
	09/11/22 5:00	13,31		1	1	1		1			
	09/11/22 6:00	14,23		1	1	1		1			
	09/11/22 7:00	16,02		1	1	1		1			
	09/11/22 8:00	17,38		1	1	1	1	1			
	09/11/22 9:00	18,39		1	1	1	1	1			
	09/11/22 10:00	19,02		1	1	1	1	1			
	09/11/22 11:00	18,97		1	1	1	1	1			
	09/11/22 12:00	19,04		1	1	1	1	1			
	09/11/22 13:00	18,84		1	1	1	1	1			
	09/11/22 14:00	18,68		1	1	1	1	1			
	09/11/22 15:00	18,51		1	1	1	1	1			
	09/11/22 16:00	18,35		1	1	1	1	1			
	09/11/22 17:00	19,34		1	1	1	1	1			
	09/11/22 18:00	20,27		1	1	1	1	1			
	09/11/22 19:00	20,00		1	1	1	1	1			
09/11/22 20:00	19,41		1	1	1	1	1				
09/11/22 21:00	18,19		1	1	1	1	1				
09/11/22 22:00	16,77		1	1	1		1				
09/11/22 23:00	15,25		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη				10/11/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	10/11/22 0:00	14,30		1	1	1		1			
	10/11/22 1:00	13,64		1	1	1		1			
	10/11/22 2:00	13,08		1	1			1			
	10/11/22 3:00	12,85		1	1			1			
	10/11/22 4:00	12,91		1	1			1			
	10/11/22 5:00	13,16		1	1			1			
	10/11/22 6:00	14,25		1	1			1	1		
	10/11/22 7:00	16,02		1	1			1	1		
	10/11/22 8:00	17,14		1	1			1	1		
	10/11/22 9:00	18,27		1	1			1	1		
	10/11/22 10:00	18,70		1	1			1	1		
	10/11/22 11:00	18,10		1	1			1	1		
	10/11/22 12:00	18,88		1	1			1	1		
	10/11/22 13:00	19,06		1	1			1	1		
	10/11/22 14:00	18,71		1	1			1	1		
	10/11/22 15:00	18,47		1	1			1	1		
	10/11/22 16:00	18,44		1	1			1	1		
	10/11/22 17:00	19,30		1	1			1	1		
	10/11/22 18:00	20,34		1	1			1	1		
	10/11/22 19:00	20,11		1	1			1	1		
10/11/22 20:00	19,54		1	1			1	1			
10/11/22 21:00	18,38		1	1			1	1			
10/11/22 22:00	16,87		1	1			1	1			
10/11/22 23:00	15,55		1	1			1	1			
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή 11/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	11/11/22 0:00	14,32		1	1	1		1			
	11/11/22 1:00	13,60		1	1	1		1			
	11/11/22 2:00	13,12		1	1	1		1			
	11/11/22 3:00	12,91		1	1	1		1			
	11/11/22 4:00	12,91		1	1	1		1			
	11/11/22 5:00	13,23		1	1	1		1			
	11/11/22 6:00	14,01		1	1	1		1			
	11/11/22 7:00	15,33		1	1	1		1			
	11/11/22 8:00	16,94		1	1	1	1	1			
	11/11/22 9:00	17,94		1	1	1	1	1			
	11/11/22 10:00	18,32		1	1	1	1	1			
	11/11/22 11:00	17,96		1	1	1	1	1			
	11/11/22 12:00	18,50		1	1	1	1	1			
	11/11/22 13:00	18,73		1	1	1	1	1			
	11/11/22 14:00	18,49		1	1	1	1	1			
	11/11/22 15:00	18,19		1	1	1	1	1			
	11/11/22 16:00	18,27		1	1	1	1	1			
	11/11/22 17:00	19,51		1	1	1	1	1			1
	11/11/22 18:00	20,32		1	1	1	1	1	1		2
	11/11/22 19:00	19,81		1	1	1	1	1	1		1
11/11/22 20:00	18,99		1	1	1	1	1	1			
11/11/22 21:00	18,21		1	1	1	1	1	1			
11/11/22 22:00	16,75		1	1	1	1	1	1			
11/11/22 23:00	15,41		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο 12/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	12/11/22 0:00	14,76		1	1	1		1			
	12/11/22 1:00	14,00		1	1	1		1			
	12/11/22 2:00	13,52		1	1	1		1			
	12/11/22 3:00	13,28		1	1	1		1			
	12/11/22 4:00	13,36		1	1	1		1			
	12/11/22 5:00	13,54		1	1	1		1			
	12/11/22 6:00	14,10		1	1	1		1			
	12/11/22 7:00	15,66		1	1	1		1			
	12/11/22 8:00	17,18		1	1	1	1	1			
	12/11/22 9:00	18,29		1	1	1	1	1			
	12/11/22 10:00	18,82		1	1	1	1	1			
	12/11/22 11:00	18,51		1	1	1	1	1			
	12/11/22 12:00	19,05		1	1	1	1	1			
	12/11/22 13:00	19,18		1	1	1	1	1			
	12/11/22 14:00	19,06		1	1	1	1	1			
	12/11/22 15:00	18,64		1	1	1	1	1			
	12/11/22 16:00	18,74		1	1	1	1	1			
	12/11/22 17:00	20,00		1	1	1	1	1			1
	12/11/22 18:00	20,91		1	1	1	1	1	1		2
	12/11/22 19:00	20,13		1	1	1	1	1	1		1
12/11/22 20:00	19,86		1	1	1	1	1	1		1	
12/11/22 21:00	18,65		1	1	1	1	1	1			
12/11/22 22:00	17,12		1	1	1	1	1	1			
12/11/22 23:00	15,88		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή 13/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Κυριακή	13/11/22 0:00	14,35		1	1	1		1			
	13/11/22 1:00	13,65		1	1	1		1			
	13/11/22 2:00	13,16		1	1	1		1			
	13/11/22 3:00	12,99		1	1	1		1			
	13/11/22 4:00	12,99		1	1	1		1			
	13/11/22 5:00	13,15		1	1	1		1			
	13/11/22 6:00	13,88		1	1	1		1			
	13/11/22 7:00	15,13		1	1	1		1			
	13/11/22 8:00	16,76		1	1	1	1	1			
	13/11/22 9:00	17,76		1	1	1	1	1			
	13/11/22 10:00	17,89		1	1	1	1	1			
	13/11/22 11:00	18,21		1	1	1	1	1			
	13/11/22 12:00	18,71		1	1	1	1	1			
	13/11/22 13:00	19,01		1	1	1	1	1			
	13/11/22 14:00	18,65		1	1	1	1	1			
	13/11/22 15:00	18,05		1	1	1	1	1			
	13/11/22 16:00	18,06		1	1	1	1	1			
	13/11/22 17:00	19,42		1	1	1	1	1			1
	13/11/22 18:00	20,21		1	1	1	1	1	1		2
	13/11/22 19:00	19,60		1	1	1	1	1	1		1
13/11/22 20:00	19,25		1	1	1	1	1	1		1	
13/11/22 21:00	18,08		1	1	1	1	1	1			
13/11/22 22:00	16,65		1	1	1	1	1				
13/11/22 23:00	15,42		1	1	1	1	1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα		14/11/2022		
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	14/11/22 0:00	14,48		1	1	1		1			
	14/11/22 1:00	13,75		1	1	1		1			
	14/11/22 2:00	13,29		1	1	1		1			
	14/11/22 3:00	13,01		1	1	1		1			
	14/11/22 4:00	13,07		1	1	1		1			
	14/11/22 5:00	13,32		1	1	1		1			
	14/11/22 6:00	13,95		1	1	1		1			
	14/11/22 7:00	15,54		1	1	1		1			
	14/11/22 8:00	17,00		1	1	1	1	1			
	14/11/22 9:00	18,08		1	1	1	1	1			
	14/11/22 10:00	18,63		1	1	1	1	1			
	14/11/22 11:00	18,37		1	1	1	1	1			
	14/11/22 12:00	18,81		1	1	1	1	1			
	14/11/22 13:00	19,02		1	1	1	1	1			
	14/11/22 14:00	18,74		1	1	1	1	1			
	14/11/22 15:00	18,38		1	1	1	1	1			
	14/11/22 16:00	18,43		1	1	1	1	1			
	14/11/22 17:00	19,77		1	1	1	1	1			1
	14/11/22 18:00	20,51		1	1	1	1	1	1		2
	14/11/22 19:00	19,94		1	1	1	1	1	1		1
14/11/22 20:00	19,52		1	1	1	1	1	1		1	
14/11/22 21:00	18,32		1	1	1	1	1	1			
14/11/22 22:00	16,83		1	1	1	1	1				
14/11/22 23:00	15,55		1	1	1	1	1				
		Μη διαθεσιμότητα μονάδας λόγω συντήρησης.									
		Μη διαθεσιμότητα μονάδας λόγω βλάβης.									

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα		15/11/2022		
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	15/11/22 0:00	13,87		1	1	1		1			
	15/11/22 1:00	13,11		1	1			1			
	15/11/22 2:00	12,68		1	1			1			
	15/11/22 3:00	12,43		1	1			1			
	15/11/22 4:00	12,46		1	1			1			
	15/11/22 5:00	12,71		1	1			1			
	15/11/22 6:00	14,06		1	1	1		1			
	15/11/22 7:00	15,11		1	1	1		1			
	15/11/22 8:00	15,97		1	1	1		1			
	15/11/22 9:00	16,91		1	1	1	1	1			
	15/11/22 10:00	17,51		1	1	1	1	1			
	15/11/22 11:00	17,34		1	1	1	1	1			
	15/11/22 12:00	17,78		1	1	1	1	1			
	15/11/22 13:00	17,85		1	1	1	1	1			
	15/11/22 14:00	17,60		1	1	1	1	1			
	15/11/22 15:00	17,39		1	1	1	1	1			
	15/11/22 16:00	17,56		1	1	1	1	1			
	15/11/22 17:00	18,80		1	1	1	1	1			
	15/11/22 18:00	19,60		1	1	1	1	1			1
	15/11/22 19:00	18,94		1	1	1	1	1			
15/11/22 20:00	18,64		1	1	1	1	1				
15/11/22 21:00	17,79		1	1	1	1	1				
15/11/22 22:00	15,86		1	1	1		1				
15/11/22 23:00	14,86		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 16/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	16/11/22 0:00	13,56		1	1	1		1			
	16/11/22 1:00	12,63		1	1			1			
	16/11/22 2:00	12,26		1	1			1			
	16/11/22 3:00	11,97		1	1			1			
	16/11/22 4:00	11,99		1	1			1			
	16/11/22 5:00	12,26		1	1			1			
	16/11/22 6:00	13,18		1	1			1			
	16/11/22 7:00	14,93		1	1	1		1			
	16/11/22 8:00	15,65		1	1	1		1			
	16/11/22 9:00	16,31		1	1	1	1	1			
	16/11/22 10:00	16,99		1	1	1	1	1			
	16/11/22 11:00	17,08		1	1	1	1	1			
	16/11/22 12:00	17,32		1	1	1	1	1			
	16/11/22 13:00	17,25		1	1	1	1	1			
	16/11/22 14:00	17,00		1	1	1	1	1			
	16/11/22 15:00	16,91		1	1	1	1	1			
	16/11/22 16:00	17,09		1	1	1	1	1			
	16/11/22 17:00	18,29		1	1	1	1	1			
	16/11/22 18:00	19,17		1	1	1	1	1			
	16/11/22 19:00	18,68		1	1	1	1	1			
16/11/22 20:00	18,22		1	1	1	1	1				
16/11/22 21:00	17,50		1	1	1	1	1				
16/11/22 22:00	15,65		1	1	1		1				
16/11/22 23:00	14,43		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης. Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη 17/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	17/11/22 0:00	13,73		1	1	1		1			
	17/11/22 1:00	12,84		1	1			1			
	17/11/22 2:00	12,35		1	1			1			
	17/11/22 3:00	12,19		1	1			1			
	17/11/22 4:00	12,15		1	1			1			
	17/11/22 5:00	12,48		1	1			1			
	17/11/22 6:00	13,36		1	1			1			
	17/11/22 7:00	14,86		1	1	1		1			
	17/11/22 8:00	16,11		1	1	1		1			
	17/11/22 9:00	17,17		1	1	1	1	1			
	17/11/22 10:00	17,57		1	1	1	1	1			
	17/11/22 11:00	17,44		1	1	1	1	1			
	17/11/22 12:00	17,74		1	1	1	1	1			
	17/11/22 13:00	17,89		1	1	1	1	1			
	17/11/22 14:00	17,64		1	1	1	1	1			
	17/11/22 15:00	17,44		1	1	1	1	1			
	17/11/22 16:00	17,63		1	1	1	1	1			
	17/11/22 17:00	18,80		1	1	1	1	1			
	17/11/22 18:00	19,91		1	1	1	1	1			1
	17/11/22 19:00	19,10		1	1	1	1	1			
17/11/22 20:00	18,58		1	1	1	1	1				
17/11/22 21:00	17,70		1	1	1	1	1				
17/11/22 22:00	16,21		1	1	1		1				
17/11/22 23:00	14,29		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή		18/11/2022		
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	18/11/22 0:00	12,86		1	1			1			
	18/11/22 1:00	12,06		1	1			1			
	18/11/22 2:00	11,68		1	1			1			
	18/11/22 3:00	11,44		1	1			1			
	18/11/22 4:00	11,47		1	1			1			
	18/11/22 5:00	11,69		1	1			1			
	18/11/22 6:00	12,72		1	1			1			
	18/11/22 7:00	14,04		1	1	1		1			
	18/11/22 8:00	14,94		1	1	1		1			
	18/11/22 9:00	15,67		1	1	1		1			
	18/11/22 10:00	16,42		1	1	1	1	1			
	18/11/22 11:00	16,40		1	1	1	1	1			
	18/11/22 12:00	16,51		1	1	1	1	1			
	18/11/22 13:00	16,47		1	1	1	1	1			
	18/11/22 14:00	16,55		1	1	1	1	1			
	18/11/22 15:00	16,47		1	1	1	1	1			
	18/11/22 16:00	16,71		1	1	1	1	1			
	18/11/22 17:00	17,78		1	1	1	1	1			
	18/11/22 18:00	18,77		1	1	1	1	1			
	18/11/22 19:00	18,15		1	1	1	1	1			
18/11/22 20:00	17,67		1	1	1	1	1				
18/11/22 21:00	17,08		1	1	1	1	1				
18/11/22 22:00	15,44		1	1	1		1				
18/11/22 23:00	13,58		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο		19/11/2022		
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	19/11/22 0:00	12,53		1	1			1			
	19/11/22 1:00	11,79		1	1			1			
	19/11/22 2:00	11,45		1	1			1			
	19/11/22 3:00	11,33		1	1			1			
	19/11/22 4:00	11,55		1	1			1			
	19/11/22 5:00	12,06		1	1			1			
	19/11/22 6:00	12,97		1	1			1			
	19/11/22 7:00	14,13		1	1	1		1			
	19/11/22 8:00	15,39		1	1	1		1			
	19/11/22 9:00	15,99		1	1	1		1			
	19/11/22 10:00	16,02		1	1	1		1			
	19/11/22 11:00	16,09		1	1	1		1			
	19/11/22 12:00	16,24		1	1	1	1	1			
	19/11/22 13:00	16,32		1	1	1	1	1			
	19/11/22 14:00	16,90		1	1	1	1	1			
	19/11/22 15:00	16,91		1	1	1	1	1			
	19/11/22 16:00	17,28		1	1	1	1	1			
	19/11/22 17:00	18,68		1	1	1	1	1			
	19/11/22 18:00	18,79		1	1	1	1	1			
	19/11/22 19:00	18,31		1	1	1	1	1			
19/11/22 20:00	18,01		1	1	1	1	1				
19/11/22 21:00	16,94		1	1	1	1	1				
19/11/22 22:00	14,84		1	1	1		1				
19/11/22 23:00	13,15		1	1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή				20/11/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Κυριακή	20/11/22 0:00	12,06		1	1			1			
	20/11/22 1:00	11,31		1	1			1			
	20/11/22 2:00	10,87		1	1			1			
	20/11/22 3:00	10,75		1	1			1			
	20/11/22 4:00	10,84		1	1			1			
	20/11/22 5:00	10,97		1	1			1			
	20/11/22 6:00	11,89		1	1			1			
	20/11/22 7:00	13,30		1	1			1			
	20/11/22 8:00	14,17		1	1	1		1			
	20/11/22 9:00	14,97		1	1	1		1			
	20/11/22 10:00	15,39		1	1	1		1			
	20/11/22 11:00	15,34		1	1	1		1			
	20/11/22 12:00	15,43		1	1	1		1			
	20/11/22 13:00	15,51		1	1	1		1			
	20/11/22 14:00	16,00		1	1	1		1			
	20/11/22 15:00	15,88		1	1	1		1			
	20/11/22 16:00	16,17		1	1	1		1			
	20/11/22 17:00	17,19		1	1	1	1	1			
	20/11/22 18:00	18,07		1	1	1	1	1			
	20/11/22 19:00	17,56		1	1	1	1	1			
20/11/22 20:00	17,04		1	1	1	1	1				
20/11/22 21:00	16,45		1	1	1	1	1				
20/11/22 22:00	15,05		1	1	1		1				
20/11/22 23:00	12,55		1	1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα		21/11/2022		
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	21/11/22 0:00	12,24		1	1			1			
	21/11/22 1:00	11,48		1	1			1			
	21/11/22 2:00	11,04		1	1			1			
	21/11/22 3:00	10,91		1	1			1			
	21/11/22 4:00	11,00		1	1			1			
	21/11/22 5:00	11,14		1	1			1			
	21/11/22 6:00	12,07		1	1			1			
	21/11/22 7:00	13,50		1	1	1		1			
	21/11/22 8:00	14,39		1	1	1		1			
	21/11/22 9:00	15,20		1	1	1		1			
	21/11/22 10:00	15,63		1	1	1		1			
	21/11/22 11:00	15,57		1	1	1		1			
	21/11/22 12:00	15,66		1	1	1		1			
	21/11/22 13:00	15,75		1	1	1		1			
	21/11/22 14:00	15,91		1	1	1		1			
	21/11/22 15:00	16,13		1	1	1		1			
	21/11/22 16:00	16,42		1	1	1	1	1			
	21/11/22 17:00	17,45		1	1	1	1	1			
	21/11/22 18:00	18,54		1	1	1	1	1			
	21/11/22 19:00	17,83		1	1	1	1	1			
21/11/22 20:00	17,30		1	1	1	1	1				
21/11/22 21:00	16,70		1	1	1	1	1				
21/11/22 22:00	15,28		1	1	1		1				
21/11/22 23:00	12,74		1	1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα			22/11/2022	
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	22/11/22 0:00	11,65		1	1			1			
	22/11/22 1:00	10,86		1	1			1			
	22/11/22 2:00	10,56		1	1			1			
	22/11/22 3:00	10,42		1	1			1			
	22/11/22 4:00	10,50		1	1			1			
	22/11/22 5:00	10,54		1	1			1			
	22/11/22 6:00	11,17		1	1			1			
	22/11/22 7:00	12,40		1	1			1			
	22/11/22 8:00	13,75		1	1	1		1			
	22/11/22 9:00	14,34		1	1	1		1			
	22/11/22 10:00	14,83		1	1	1		1			
	22/11/22 11:00	14,92		1	1	1		1			
	22/11/22 12:00	15,07		1	1	1		1			
	22/11/22 13:00	15,13		1	1	1		1			
	22/11/22 14:00	15,43		1	1	1		1			
	22/11/22 15:00	15,27		1	1	1		1			
	22/11/22 16:00	15,44		1	1	1		1			
	22/11/22 17:00	16,29		1	1	1		1			
	22/11/22 18:00	16,90		1	1	1	1	1			
	22/11/22 19:00	16,61		1	1	1	1	1			
22/11/22 20:00	16,26		1	1	1		1				
22/11/22 21:00	15,46		1	1	1		1				
22/11/22 22:00	14,28		1	1	1		1				
22/11/22 23:00	12,58		1	1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 23/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	23/11/22 0:00	11,76		1	1			1			
	23/11/22 1:00	10,98		1	1			1			
	23/11/22 2:00	10,64		1	1			1			
	23/11/22 3:00	10,50		1	1			1			
	23/11/22 4:00	10,58		1	1			1			
	23/11/22 5:00	10,68		1	1			1			
	23/11/22 6:00	11,35		1	1			1			
	23/11/22 7:00	12,50		1	1			1			
	23/11/22 8:00	13,56		1	1	1		1			
	23/11/22 9:00	14,21		1	1	1		1			
	23/11/22 10:00	14,69		1	1	1		1			
	23/11/22 11:00	15,33		1	1	1		1			
	23/11/22 12:00	15,53		1	1	1		1			
	23/11/22 13:00	15,52		1	1	1		1			
	23/11/22 14:00	15,75		1	1	1		1			
	23/11/22 15:00	15,85		1	1	1		1			
	23/11/22 16:00	16,02		1	1	1		1			
	23/11/22 17:00	16,74		1	1	1	1	1			
	23/11/22 18:00	17,27		1	1	1	1	1			
	23/11/22 19:00	16,97		1	1	1	1	1			
23/11/22 20:00	16,10		1	1	1		1				
23/11/22 21:00	15,65		1	1	1		1				
23/11/22 22:00	14,20		1	1	1		1				
23/11/22 23:00	12,78		1	1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη 24/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	24/11/22 0:00	11,65		1	1			1			
	24/11/22 1:00	10,93		1	1			1			
	24/11/22 2:00	10,31		1	1			1			
	24/11/22 3:00	10,46		1	1			1			
	24/11/22 4:00	10,45		1	1			1			
	24/11/22 5:00	10,63		1	1			1			
	24/11/22 6:00	11,42		1	1			1			
	24/11/22 7:00	12,93		1	1			1			
	24/11/22 8:00	13,02		1	1			1			
	24/11/22 9:00	14,05		1	1	1		1			
	24/11/22 10:00	14,05		1	1	1		1			
	24/11/22 11:00	15,16		1	1	1		1			
	24/11/22 12:00	15,84		1	1	1		1			
	24/11/22 13:00	15,66		1	1	1		1			
	24/11/22 14:00	15,56		1	1	1		1			
	24/11/22 15:00	15,15		1	1	1		1			
	24/11/22 16:00	15,39		1	1	1		1			
	24/11/22 17:00	16,44		1	1	1	1	1			
	24/11/22 18:00	17,03		1	1	1	1	1			
	24/11/22 19:00	16,95		1	1	1	1	1			
24/11/22 20:00	16,17		1	1	1		1				
24/11/22 21:00	15,53		1	1	1		1				
24/11/22 22:00	14,04		1	1	1		1				
24/11/22 23:00	12,82		1	1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή 25/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	25/11/22 0:00	11,60		1	1			1			
	25/11/22 1:00	10,95		1	1			1			
	25/11/22 2:00	10,50		1	1			1			
	25/11/22 3:00	10,30		1	1			1			
	25/11/22 4:00	10,36		1	1			1			
	25/11/22 5:00	10,75		1	1			1			
	25/11/22 6:00	11,27		1	1			1			
	25/11/22 7:00	12,52		1	1			1			
	25/11/22 8:00	13,07		1	1			1			
	25/11/22 9:00	13,94		1	1	1		1			
	25/11/22 10:00	15,28		1	1	1		1			
	25/11/22 11:00	16,72		1	1	1	1	1			
	25/11/22 12:00	16,95		1	1	1	1	1			
	25/11/22 13:00	16,89		1	1	1	1	1			
	25/11/22 14:00	16,79		1	1	1	1	1			
	25/11/22 15:00	16,29		1	1	1	1	1			
	25/11/22 16:00	16,83		1	1	1	1	1			
	25/11/22 17:00	17,96		1	1	1	1	1			
	25/11/22 18:00	17,76		1	1	1	1	1			
	25/11/22 19:00	17,54		1	1	1	1	1			
25/11/22 20:00	15,83		1	1	1		1				
25/11/22 21:00	15,44		1	1	1		1				
25/11/22 22:00	13,14		1	1			1				
25/11/22 23:00	12,93		1	1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο		26/11/2022		
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	26/11/22 0:00	12,09		1	1			1			
	26/11/22 1:00	11,31		1	1			1			
	26/11/22 2:00	10,95		1	1			1			
	26/11/22 3:00	10,76		1	1			1			
	26/11/22 4:00	10,78		1	1			1			
	26/11/22 5:00	11,06		1	1			1			
	26/11/22 6:00	11,72		1	1			1			
	26/11/22 7:00	12,90		1	1			1			
	26/11/22 8:00	13,85		1	1	1		1			
	26/11/22 9:00	14,55		1	1	1		1			
	26/11/22 10:00	15,61		1	1	1		1			
	26/11/22 11:00	16,52		1	1	1	1	1			
	26/11/22 12:00	16,76		1	1	1	1	1			
	26/11/22 13:00	16,75		1	1	1	1	1			
	26/11/22 14:00	16,51		1	1	1	1	1			
	26/11/22 15:00	16,19		1	1	1	1	1			
	26/11/22 16:00	16,56		1	1	1	1	1			
	26/11/22 17:00	17,56		1	1	1	1	1			
	26/11/22 18:00	17,77		1	1	1	1	1			
	26/11/22 19:00	17,55		1	1	1	1	1			
26/11/22 20:00	16,16		1	1	1		1				
26/11/22 21:00	15,32		1	1	1		1				
26/11/22 22:00	13,83		1	1	1		1				
26/11/22 23:00	13,29		1	1			1				

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή 27/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Κυριακή	27/11/22 0:00	11,82		1	1			1			
	27/11/22 1:00	11,10		1	1			1			
	27/11/22 2:00	10,60		1	1			1			
	27/11/22 3:00	10,52		1	1			1			
	27/11/22 4:00	10,55		1	1			1			
	27/11/22 5:00	10,79		1	1			1			
	27/11/22 6:00	11,32		1	1			1			
	27/11/22 7:00	12,64		1	1			1			
	27/11/22 8:00	13,31		1	1			1			
	27/11/22 9:00	14,17		1	1	1		1			
	27/11/22 10:00	14,94		1	1	1		1			
	27/11/22 11:00	15,58		1	1	1		1			
	27/11/22 12:00	16,03		1	1	1		1			
	27/11/22 13:00	16,00		1	1	1		1			
	27/11/22 14:00	15,84		1	1	1		1			
	27/11/22 15:00	15,44		1	1	1		1			
	27/11/22 16:00	15,80		1	1	1		1			
	27/11/22 17:00	16,77		1	1	1	1	1			
	27/11/22 18:00	17,05		1	1	1	1	1			
	27/11/22 19:00	16,99		1	1	1	1	1			
27/11/22 20:00	15,89		1	1	1		1				
27/11/22 21:00	15,06		1	1	1		1				
27/11/22 22:00	13,80		1	1	1		1				
27/11/22 23:00	12,88		1	1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα 28/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	28/11/22 0:00	11,90		1	1			1			
	28/11/22 1:00	11,15		1	1			1			
	28/11/22 2:00	10,79		1	1			1			
	28/11/22 3:00	10,53		1	1			1			
	28/11/22 4:00	10,59		1	1			1			
	28/11/22 5:00	10,98		1	1			1			
	28/11/22 6:00	11,48		1	1			1			
	28/11/22 7:00	12,90		1	1			1			
	28/11/22 8:00	13,98		1	1	1		1			
	28/11/22 9:00	14,67		1	1	1		1			
	28/11/22 10:00	16,16		1	1	1		1			
	28/11/22 11:00	16,40		1	1	1	1	1			
	28/11/22 12:00	16,58		1	1	1	1	1			
	28/11/22 13:00	16,70		1	1	1	1	1			
	28/11/22 14:00	16,55		1	1	1	1	1			
	28/11/22 15:00	16,15		1	1	1	1	1			
	28/11/22 16:00	16,81		1	1	1	1	1			
	28/11/22 17:00	17,66		1	1	1	1	1			
	28/11/22 18:00	17,73		1	1	1	1	1			
	28/11/22 19:00	17,57		1	1	1	1	1			
28/11/22 20:00	15,97		1	1	1		1				
28/11/22 21:00	14,80		1	1	1		1				
28/11/22 22:00	13,61		1	1	1		1				
28/11/22 23:00	13,06		1	1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα 29/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	29/11/22 0:00	12,59		1	1			1			
	29/11/22 1:00	11,74		1	1			1			
	29/11/22 2:00	11,24		1	1			1			
	29/11/22 3:00	11,04		1	1			1			
	29/11/22 4:00	10,99		1	1			1			
	29/11/22 5:00	11,25		1	1			1			
	29/11/22 6:00	11,88		1	1			1			
	29/11/22 7:00	12,79		1	1			1			
	29/11/22 8:00	13,59		1	1	1		1			
	29/11/22 9:00	14,65		1	1	1		1			
	29/11/22 10:00	15,44		1	1	1		1			
	29/11/22 11:00	15,92		1	1	1		1			
	29/11/22 12:00	16,10		1	1	1		1			
	29/11/22 13:00	16,37		1	1	1		1			
	29/11/22 14:00	16,39		1	1	1	1	1			
	29/11/22 15:00	16,47		1	1	1	1	1			
	29/11/22 16:00	17,44		1	1	1	1	1			
	29/11/22 17:00	18,42		1	1	1	1	1			
	29/11/22 18:00	18,68		1	1	1	1	1			
	29/11/22 19:00	17,65		1	1	1	1	1			
29/11/22 20:00	17,16		1	1	1	1	1				
29/11/22 21:00	16,37		1	1	1		1				
29/11/22 22:00	15,20		1	1	1		1				
29/11/22 23:00	13,99		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης. Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 30/11/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	30/11/22 0:00	13,42		1	1			1			
	30/11/22 1:00	12,70		1	1			1			
	30/11/22 2:00	12,25		1	1			1			
	30/11/22 3:00	11,91		1	1			1			
	30/11/22 4:00	11,92		1	1			1			
	30/11/22 5:00	12,35		1	1			1			
	30/11/22 6:00	13,30		1	1			1			
	30/11/22 7:00	14,81		1	1	1		1			
	30/11/22 8:00	15,93		1	1	1		1			
	30/11/22 9:00	16,91		1	1	1	1	1			
	30/11/22 10:00	17,53		1	1	1	1	1			
	30/11/22 11:00	17,62		1	1	1	1	1			
	30/11/22 12:00	17,93		1	1	1	1	1			
	30/11/22 13:00	17,89		1	1	1	1	1			
	30/11/22 14:00	17,84		1	1	1	1	1			
	30/11/22 15:00	18,29		1	1	1	1	1			
	30/11/22 16:00	18,83		1	1	1	1	1			
	30/11/22 17:00	19,23		1	1	1	1	1			
	30/11/22 18:00	19,77		1	1	1	1	1	1		1
	30/11/22 19:00	19,59		1	1	1	1	1	1		1
30/11/22 20:00	19,11		1	1	1	1	1	1			
30/11/22 21:00	17,44		1	1	1	1	1	1			
30/11/22 22:00	16,34		1	1	1		1				
30/11/22 23:00	14,86		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη 1/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	01/12/22 0:00	12,88		1	1			1			
	01/12/22 1:00	12,10		1	1			1			
	01/12/22 2:00	11,60		1	1			1			
	01/12/22 3:00	11,27		1	1			1			
	01/12/22 4:00	11,31		1	1			1			
	01/12/22 5:00	11,67		1	1			1			
	01/12/22 6:00	12,66		1	1			1			
	01/12/22 7:00	13,87		1	1	1		1			
	01/12/22 8:00	14,78		1	1	1		1			
	01/12/22 9:00	15,70		1	1	1		1			
	01/12/22 10:00	16,25		1	1	1		1			
	01/12/22 11:00	16,50		1	1	1	1	1			
	01/12/22 12:00	16,76		1	1	1	1	1			
	01/12/22 13:00	16,66		1	1	1	1	1			
	01/12/22 14:00	16,69		1	1	1	1	1			
	01/12/22 15:00	17,23		1	1	1	1	1			
	01/12/22 16:00	17,95		1	1	1	1	1			
	01/12/22 17:00	19,12		1	1	1	1	1			
	01/12/22 18:00	19,20		1	1	1	1	1			
	01/12/22 19:00	18,92		1	1	1	1	1			
01/12/22 20:00	18,03		1	1	1	1	1				
01/12/22 21:00	16,77		1	1	1	1	1				
01/12/22 22:00	15,80		1	1	1		1				
01/12/22 23:00	14,37		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή 2/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	02/12/22 0:00	12,61		1	1			1			
	02/12/22 1:00	11,80		1	1			1			
	02/12/22 2:00	11,24		1	1			1			
	02/12/22 3:00	10,90		1	1			1			
	02/12/22 4:00	10,92		1	1			1			
	02/12/22 5:00	11,23		1	1			1			
	02/12/22 6:00	12,22		1	1			1			
	02/12/22 7:00	13,36		1	1			1			
	02/12/22 8:00	14,31		1	1	1		1			
	02/12/22 9:00	15,23		1	1	1		1			
	02/12/22 10:00	15,69		1	1	1		1			
	02/12/22 11:00	15,93		1	1	1		1			
	02/12/22 12:00	16,11		1	1	1		1			
	02/12/22 13:00	16,16		1	1	1		1			
	02/12/22 14:00	16,43		1	1	1	1	1			
	02/12/22 15:00	16,98		1	1	1	1	1			
	02/12/22 16:00	17,61		1	1	1	1	1			
	02/12/22 17:00	18,88		1	1	1	1	1			
	02/12/22 18:00	18,80		1	1	1	1	1	1		
	02/12/22 19:00	18,58		1	1	1	1	1	1		
02/12/22 20:00	17,60		1	1	1	1	1	1			
02/12/22 21:00	16,58		1	1	1	1	1	1			
02/12/22 22:00	15,46		1	1	1		1				
02/12/22 23:00	14,11		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης. Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο 3/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	03/12/22 0:00	12,35		1	1			1			
	03/12/22 1:00	11,55		1	1			1			
	03/12/22 2:00	11,04		1	1			1			
	03/12/22 3:00	10,74		1	1			1			
	03/12/22 4:00	10,73		1	1			1			
	03/12/22 5:00	11,06		1	1			1			
	03/12/22 6:00	11,87		1	1			1			
	03/12/22 7:00	12,87		1	1			1			
	03/12/22 8:00	13,55		1	1	1		1			
	03/12/22 9:00	14,34		1	1	1		1			
	03/12/22 10:00	15,09		1	1	1		1			
	03/12/22 11:00	15,32		1	1	1		1			
	03/12/22 12:00	15,49		1	1	1		1			
	03/12/22 13:00	15,64		1	1	1		1			
	03/12/22 14:00	15,81		1	1	1		1			
	03/12/22 15:00	16,11		1	1	1		1			
	03/12/22 16:00	16,79		1	1	1	1	1			
	03/12/22 17:00	17,95		1	1	1	1	1			
	03/12/22 18:00	17,74		1	1	1	1	1			
	03/12/22 19:00	17,66		1	1	1	1	1			
03/12/22 20:00	16,82		1	1	1	1	1				
03/12/22 21:00	16,00		1	1	1	1	1				
03/12/22 22:00	14,92		1	1	1		1				
03/12/22 23:00	13,69		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή 4/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Κυριακή	04/12/22 0:00	12,37		1	1			1			
	04/12/22 1:00	11,53		1	1			1			
	04/12/22 2:00	11,06		1	1			1			
	04/12/22 3:00	10,75		1	1			1			
	04/12/22 4:00	10,70		1	1			1			
	04/12/22 5:00	11,10		1	1			1			
	04/12/22 6:00	11,84		1	1			1			
	04/12/22 7:00	12,86		1	1			1			
	04/12/22 8:00	12,84		1	1			1			
	04/12/22 9:00	13,45		1	1			1			
	04/12/22 10:00	14,86		1	1	1		1			
	04/12/22 11:00	15,13		1	1	1		1			
	04/12/22 12:00	15,13		1	1	1		1			
	04/12/22 13:00	15,20		1	1	1		1			
	04/12/22 14:00	15,21		1	1	1		1			
	04/12/22 15:00	15,20		1	1	1		1			
	04/12/22 16:00	15,74		1	1	1		1			
	04/12/22 17:00	16,94		1	1	1	1	1			
	04/12/22 18:00	17,21		1	1	1	1	1			
	04/12/22 19:00	17,33		1	1	1	1	1			
04/12/22 20:00	16,69		1	1	1	1	1				
04/12/22 21:00	15,78		1	1	1		1				
04/12/22 22:00	14,73		1	1	1		1				
04/12/22 23:00	13,59		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα 5/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	05/12/22 0:00	12,39		1	1			1			
	05/12/22 1:00	11,58		1	1			1			
	05/12/22 2:00	11,06		1	1			1			
	05/12/22 3:00	10,73		1	1			1			
	05/12/22 4:00	10,72		1	1			1			
	05/12/22 5:00	11,07		1	1			1			
	05/12/22 6:00	11,96		1	1			1			
	05/12/22 7:00	13,07		1	1			1			
	05/12/22 8:00	13,59		1	1	1		1			
	05/12/22 9:00	14,38		1	1	1		1			
	05/12/22 10:00	15,23		1	1	1		1			
	05/12/22 11:00	15,48		1	1	1		1			
	05/12/22 12:00	15,58		1	1	1		1			
	05/12/22 13:00	15,61		1	1	1		1			
	05/12/22 14:00	15,77		1	1	1		1			
	05/12/22 15:00	16,10		1	1	1		1			
	05/12/22 16:00	16,66		1	1	1	1	1			
	05/12/22 17:00	17,91		1	1	1	1	1			
	05/12/22 18:00	18,04		1	1	1	1	1			
	05/12/22 19:00	17,95		1	1	1	1	1			
05/12/22 20:00	17,12		1	1	1	1	1				
05/12/22 21:00	16,12		1	1	1		1				
05/12/22 22:00	15,04		1	1	1		1				
05/12/22 23:00	13,78		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα 6/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	06/12/22 0:00	11,92		1	1			1			
	06/12/22 1:00	11,10		1	1			1			
	06/12/22 2:00	10,70		1	1			1			
	06/12/22 3:00	10,52		1	1			1			
	06/12/22 4:00	10,47		1	1			1			
	06/12/22 5:00	10,74		1	1			1			
	06/12/22 6:00	11,52		1	1			1			
	06/12/22 7:00	12,46		1	1			1			
	06/12/22 8:00	12,82		1	1			1			
	06/12/22 9:00	13,07		1	1			1			
	06/12/22 10:00	14,16		1	1	1		1			
	06/12/22 11:00	14,92		1	1	1		1			
	06/12/22 12:00	14,74		1	1	1		1			
	06/12/22 13:00	14,36		1	1	1		1			
	06/12/22 14:00	14,56		1	1	1		1			
	06/12/22 15:00	14,59		1	1	1		1			
	06/12/22 16:00	14,95		1	1	1		1			
	06/12/22 17:00	16,18		1	1	1		1			
	06/12/22 18:00	16,37		1	1	1		1			
	06/12/22 19:00	16,49		1	1	1		1			
06/12/22 20:00	16,31		1	1	1		1				
06/12/22 21:00	15,47		1	1	1		1				
06/12/22 22:00	14,39		1	1	1		1				
06/12/22 23:00	13,45		1	1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 7/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	07/12/22 0:00	12,37		1	1			1			
	07/12/22 1:00	11,50		1	1			1			
	07/12/22 2:00	10,94		1	1			1			
	07/12/22 3:00	10,67		1	1			1			
	07/12/22 4:00	10,64		1	1			1			
	07/12/22 5:00	10,96		1	1			1			
	07/12/22 6:00	11,73		1	1			1			
	07/12/22 7:00	12,95		1	1			1			
	07/12/22 8:00	13,40		1	1			1			
	07/12/22 9:00	14,13		1	1	1		1			
	07/12/22 10:00	14,98		1	1	1		1			
	07/12/22 11:00	15,33		1	1	1		1			
	07/12/22 12:00	15,37		1	1	1		1			
	07/12/22 13:00	15,37		1	1	1		1			
	07/12/22 14:00	15,55		1	1	1		1			
	07/12/22 15:00	15,80		1	1	1		1			
	07/12/22 16:00	16,36		1	1	1		1			
	07/12/22 17:00	17,38		1	1	1	1	1			
	07/12/22 18:00	17,56		1	1	1	1	1			
	07/12/22 19:00	17,60		1	1	1	1	1			
07/12/22 20:00	16,89		1	1	1	1	1				
07/12/22 21:00	15,73		1	1	1		1				
07/12/22 22:00	14,44		1	1	1		1				
07/12/22 23:00	13,62		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη 8/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	08/12/22 0:00	12,26		1	1			1			
	08/12/22 1:00	11,38		1	1			1			
	08/12/22 2:00	10,84		1	1			1			
	08/12/22 3:00	10,60		1	1			1			
	08/12/22 4:00	10,55		1	1			1			
	08/12/22 5:00	10,79		1	1			1			
	08/12/22 6:00	11,58		1	1			1			
	08/12/22 7:00	12,84		1	1			1			
	08/12/22 8:00	13,18		1	1			1			
	08/12/22 9:00	13,96		1	1	1		1			
	08/12/22 10:00	14,62		1	1	1		1			
	08/12/22 11:00	14,96		1	1	1		1			
	08/12/22 12:00	15,01		1	1	1		1			
	08/12/22 13:00	15,05		1	1	1		1			
	08/12/22 14:00	15,13		1	1	1		1			
	08/12/22 15:00	15,42		1	1	1		1			
	08/12/22 16:00	16,04		1	1	1		1			
	08/12/22 17:00	17,35		1	1	1	1	1			
	08/12/22 18:00	17,56		1	1	1	1	1			
	08/12/22 19:00	17,60		1	1	1	1	1			
08/12/22 20:00	16,70		1	1	1	1	1				
08/12/22 21:00	15,71		1	1	1		1				
08/12/22 22:00	14,38		1	1	1		1				
08/12/22 23:00	13,53		1	1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή 9/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	09/12/22 0:00	12,15		1	1			1			
	09/12/22 1:00	11,25		1	1			1			
	09/12/22 2:00	10,73		1	1			1			
	09/12/22 3:00	10,58		1	1			1			
	09/12/22 4:00	10,55		1	1			1			
	09/12/22 5:00	10,66		1	1			1			
	09/12/22 6:00	11,54		1	1			1			
	09/12/22 7:00	12,84		1	1			1			
	09/12/22 8:00	13,22		1	1			1			
	09/12/22 9:00	13,87		1	1	1		1			
	09/12/22 10:00	13,98		1	1	1		1			
	09/12/22 11:00	14,33		1	1	1		1			
	09/12/22 12:00	14,66		1	1	1		1			
	09/12/22 13:00	14,62		1	1	1		1			
	09/12/22 14:00	14,62		1	1	1		1			
	09/12/22 15:00	15,04		1	1	1		1			
	09/12/22 16:00	15,80		1	1	1		1			
	09/12/22 17:00	17,66		1	1	1	1	1			
	09/12/22 18:00	17,77		1	1	1	1	1			
	09/12/22 19:00	17,65		1	1	1	1	1			
09/12/22 20:00	16,43		1	1	1	1	1				
09/12/22 21:00	15,69		1	1	1		1				
09/12/22 22:00	14,21		1	1	1		1				
09/12/22 23:00	13,36		1	1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο 10/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	10/12/22 0:00	11,83	1		1			1			
	10/12/22 1:00	11,03	1		1			1			
	10/12/22 2:00	10,64	1		1			1			
	10/12/22 3:00	10,52	1		1			1			
	10/12/22 4:00	10,45	1		1			1			
	10/12/22 5:00	10,52	1		1			1			
	10/12/22 6:00	11,48	1		1			1			
	10/12/22 7:00	12,44	1		1			1			
	10/12/22 8:00	13,10	1		1	1		1			
	10/12/22 9:00	13,76	1		1	1		1			
	10/12/22 10:00	14,15	1		1	1		1			
	10/12/22 11:00	14,52	1		1	1		1			
	10/12/22 12:00	14,65	1		1	1		1			
	10/12/22 13:00	14,02	1		1	1		1			
	10/12/22 14:00	14,58	1		1	1		1			
	10/12/22 15:00	14,08	1		1	1		1			
	10/12/22 16:00	15,40	1		1	1		1			
	10/12/22 17:00	16,97	1		1	1	1	1			
	10/12/22 18:00	17,18	1		1	1	1	1			
	10/12/22 19:00	17,02	1		1	1	1	1			
10/12/22 20:00	16,25	1		1	1	1	1				
10/12/22 21:00	15,81	1		1	1	1	1				
10/12/22 22:00	14,42	1		1	1		1				
10/12/22 23:00	13,35	1		1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή 11/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Κυριακή	11/12/22 0:00	12,23	1		1			1			
	11/12/22 1:00	11,22	1		1			1			
	11/12/22 2:00	10,70	1		1			1			
	11/12/22 3:00	10,59	1		1			1			
	11/12/22 4:00	10,67	1		1			1			
	11/12/22 5:00	10,69	1		1			1			
	11/12/22 6:00	11,06	1		1			1			
	11/12/22 7:00	12,13	1		1			1			
	11/12/22 8:00	12,89	1		1			1			
	11/12/22 9:00	13,35	1		1	1		1			
	11/12/22 10:00	13,56	1		1	1		1			
	11/12/22 11:00	13,70	1		1	1		1			
	11/12/22 12:00	14,22	1		1	1		1			
	11/12/22 13:00	13,85	1		1	1		1			
	11/12/22 14:00	14,16	1		1	1		1			
	11/12/22 15:00	14,35	1		1	1		1			
	11/12/22 16:00	14,83	1		1	1		1			
	11/12/22 17:00	16,82	1		1	1	1	1			
	11/12/22 18:00	16,83	1		1	1	1	1			
	11/12/22 19:00	16,24	1		1	1	1	1			
11/12/22 20:00	15,47	1		1	1		1				
11/12/22 21:00	15,19	1		1	1		1				
11/12/22 22:00	13,95	1		1	1		1				
11/12/22 23:00	13,13	1		1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα		12/12/2022		
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	12/12/22 0:00	12,13	1		1			1			
	12/12/22 1:00	11,26	1		1			1			
	12/12/22 2:00	10,79	1		1			1			
	12/12/22 3:00	10,62	1		1			1			
	12/12/22 4:00	10,55	1		1			1			
	12/12/22 5:00	10,61	1		1			1			
	12/12/22 6:00	11,56	1		1			1			
	12/12/22 7:00	12,86	1		1			1			
	12/12/22 8:00	13,02	1		1	1		1			
	12/12/22 9:00	13,61	1		1	1		1			
	12/12/22 10:00	13,72	1		1	1		1			
	12/12/22 11:00	13,88	1		1	1		1			
	12/12/22 12:00	14,28	1		1	1		1			
	12/12/22 13:00	14,41	1		1	1		1			
	12/12/22 14:00	14,40	1		1	1		1			
	12/12/22 15:00	14,75	1		1	1		1			
	12/12/22 16:00	15,36	1		1	1		1			
	12/12/22 17:00	17,59	1		1	1	1	1			
	12/12/22 18:00	17,77	1		1	1	1	1	1		
	12/12/22 19:00	17,69	1		1	1	1	1	1		
12/12/22 20:00	16,45	1		1	1	1	1	1			
12/12/22 21:00	16,12	1		1	1	1	1	1			
12/12/22 22:00	14,56	1		1	1		1				
12/12/22 23:00	13,36	1		1	1		1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τρίτη 13/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τρίτη	13/12/22 0:00	11,95	1		1			1			
	13/12/22 1:00	11,08	1		1			1			
	13/12/22 2:00	10,44	1		1			1			
	13/12/22 3:00	10,27	1		1			1			
	13/12/22 4:00	10,33	1		1			1			
	13/12/22 5:00	10,45	1		1			1			
	13/12/22 6:00	11,28	1		1			1			
	13/12/22 7:00	12,25	1		1			1			
	13/12/22 8:00	12,81	1		1			1			
	13/12/22 9:00	13,70	1		1	1		1			
	13/12/22 10:00	14,17	1		1	1		1			
	13/12/22 11:00	14,73	1		1	1		1			
	13/12/22 12:00	15,06	1		1	1		1			
	13/12/22 13:00	14,96	1		1	1		1			
	13/12/22 14:00	15,05	1		1	1		1			
	13/12/22 15:00	15,20	1		1	1		1			
	13/12/22 16:00	15,58	1		1	1		1			
	13/12/22 17:00	16,95	1		1	1	1	1			
	13/12/22 18:00	17,05	1		1	1	1	1			
	13/12/22 19:00	17,17	1		1	1	1	1			
	13/12/22 20:00	16,42	1		1	1	1	1			
	13/12/22 21:00	15,70	1		1	1		1			
	13/12/22 22:00	14,25	1		1	1		1			
13/12/22 23:00	13,02	1		1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 14/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	14/12/22 0:00	11,87	1		1			1			
	14/12/22 1:00	10,86	1		1			1			
	14/12/22 2:00	10,27	1		1			1			
	14/12/22 3:00	10,19	1		1			1			
	14/12/22 4:00	10,14	1		1			1			
	14/12/22 5:00	10,22	1		1			1			
	14/12/22 6:00	11,01	1		1			1			
	14/12/22 7:00	11,97	1		1			1			
	14/12/22 8:00	12,36	1		1			1			
	14/12/22 9:00	13,03	1		1			1			
	14/12/22 10:00	13,87	1		1	1		1			
	14/12/22 11:00	14,53	1		1	1		1			
	14/12/22 12:00	14,69	1		1	1		1			
	14/12/22 13:00	14,74	1		1	1		1			
	14/12/22 14:00	14,80	1		1	1		1			
	14/12/22 15:00	14,84	1		1	1		1			
	14/12/22 16:00	15,56	1		1	1		1			
	14/12/22 17:00	16,64	1		1	1	1	1			
	14/12/22 18:00	16,78	1		1	1	1	1			
	14/12/22 19:00	16,83	1		1	1	1	1			
14/12/22 20:00	16,39	1		1	1	1	1				
14/12/22 21:00	15,40	1		1	1		1				
14/12/22 22:00	14,02	1		1	1		1				
14/12/22 23:00	12,90	1		1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη 15/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	15/12/22 0:00	12,07	1		1			1			
	15/12/22 1:00	11,20	1		1			1			
	15/12/22 2:00	10,72	1		1			1			
	15/12/22 3:00	10,51	1		1			1			
	15/12/22 4:00	10,49	1		1			1			
	15/12/22 5:00	10,70	1		1			1			
	15/12/22 6:00	11,68	1		1			1			
	15/12/22 7:00	12,99	1		1			1			
	15/12/22 8:00	13,56	1		1	1		1			
	15/12/22 9:00	14,30	1		1	1		1			
	15/12/22 10:00	14,55	1		1	1		1			
	15/12/22 11:00	14,72	1		1	1		1			
	15/12/22 12:00	14,94	1		1	1		1			
	15/12/22 13:00	15,10	1		1	1		1			
	15/12/22 14:00	15,30	1		1	1		1			
	15/12/22 15:00	15,64	1		1	1		1			
	15/12/22 16:00	16,24	1		1	1		1			
	15/12/22 17:00	17,59	1		1	1	1	1			
	15/12/22 18:00	17,76	1		1	1	1	1			
	15/12/22 19:00	17,67	1		1	1	1	1			
15/12/22 20:00	17,09	1		1	1	1	1				
15/12/22 21:00	16,39	1		1	1	1	1				
15/12/22 22:00	14,84	1		1	1		1				
15/12/22 23:00	13,52	1		1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης. Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή 16/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	16/12/22 0:00	11,34							1	1	
	16/12/22 1:00	10,40							1	1	
	16/12/22 2:00	10,00							1	1	
	16/12/22 3:00	9,88							1	1	
	16/12/22 4:00	9,89							1	1	
	16/12/22 5:00	10,16							1	1	
	16/12/22 6:00	11,04							1	1	
	16/12/22 7:00	12,33							1	1	
	16/12/22 8:00	12,94							1	1	
	16/12/22 9:00	13,79							1	1	
	16/12/22 10:00	14,04							1	1	
	16/12/22 11:00	14,20							1	1	
	16/12/22 12:00	14,31							1	1	
	16/12/22 13:00	14,29							1	1	
	16/12/22 14:00	14,35							1	1	
	16/12/22 15:00	14,59							1	1	
	16/12/22 16:00	15,31							1	1	
	16/12/22 17:00	16,55							1	1	
	16/12/22 18:00	16,83							1	1	
	16/12/22 19:00	16,65							1	1	
16/12/22 20:00	16,39							1	1		
16/12/22 21:00	15,40							1	1		
16/12/22 22:00	13,88							1	1		
16/12/22 23:00	12,73							1	1		

Παρατηρήσεις:

1) Η ένταξη των μονάδων οφείλεται σε προγραμματισμένες δοκιμές και τεχνικές εργασίες στον ΑΣΠ.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης.
	Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο		17/12/2022		
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	17/12/22 0:00	11,54	1		1			1			
	17/12/22 1:00	10,56	1		1			1			
	17/12/22 2:00	10,10	1		1			1			
	17/12/22 3:00	9,95	1		1			1			
	17/12/22 4:00	9,95	1		1			1			
	17/12/22 5:00	10,15	1		1			1			
	17/12/22 6:00	11,00	1		1			1			
	17/12/22 7:00	12,03	1		1			1			
	17/12/22 8:00	12,60	1		1			1			
	17/12/22 9:00	13,48	1		1	1		1			
	17/12/22 10:00	13,91	1		1	1		1			
	17/12/22 11:00	14,30	1		1	1		1			
	17/12/22 12:00	14,42	1		1	1		1			
	17/12/22 13:00	14,43	1		1	1		1			
	17/12/22 14:00	14,48	1		1	1		1			
	17/12/22 15:00	14,54	1		1	1		1			
	17/12/22 16:00	15,03	1		1	1		1			
	17/12/22 17:00	16,21	1		1	1	1	1			
	17/12/22 18:00	16,56	1		1	1	1	1			
	17/12/22 19:00	16,40	1		1	1	1	1			
17/12/22 20:00	16,04	1		1	1		1				
17/12/22 21:00	15,17	1		1	1		1				
17/12/22 22:00	13,78	1		1	1		1				
17/12/22 23:00	12,67	1		1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή 18/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Κυριακή	18/12/22 0:00	11,35	1		1			1			
	18/12/22 1:00	10,45	1		1			1			
	18/12/22 2:00	9,86	1		1			1			
	18/12/22 3:00	9,73	1		1			1			
	18/12/22 4:00	9,84	1		1			1			
	18/12/22 5:00	10,04	1		1			1			
	18/12/22 6:00	10,87	1		1			1			
	18/12/22 7:00	11,91	1		1			1			
	18/12/22 8:00	12,58	1		1			1			
	18/12/22 9:00	13,51	1		1	1		1			
	18/12/22 10:00	13,86	1		1	1		1			
	18/12/22 11:00	14,24	1		1	1		1			
	18/12/22 12:00	14,51	1		1	1		1			
	18/12/22 13:00	14,34	1		1	1		1			
	18/12/22 14:00	14,32	1		1	1		1			
	18/12/22 15:00	14,37	1		1	1		1			
	18/12/22 16:00	14,75	1		1	1		1			
	18/12/22 17:00	15,89	1		1	1		1			
	18/12/22 18:00	16,41	1		1	1	1	1	1		
	18/12/22 19:00	16,12	1		1	1	1	1	1		
18/12/22 20:00	15,86	1		1	1		1				
18/12/22 21:00	14,98	1		1	1		1				
18/12/22 22:00	13,58	1		1	1		1				
18/12/22 23:00	12,54	1		1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα 19/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	19/12/22 0:00	11,60	1		1			1			
	19/12/22 1:00	10,63	1		1			1			
	19/12/22 2:00	10,20	1		1			1			
	19/12/22 3:00	10,07	1		1			1			
	19/12/22 4:00	10,07	1		1			1			
	19/12/22 5:00	10,32	1		1			1			
	19/12/22 6:00	11,26	1		1			1			
	19/12/22 7:00	12,50	1		1			1			
	19/12/22 8:00	13,12	1		1			1			
	19/12/22 9:00	13,93	1		1	1		1			
	19/12/22 10:00	14,12	1		1	1		1			
	19/12/22 11:00	14,30	1		1	1		1			
	19/12/22 12:00	14,40	1		1	1		1			
	19/12/22 13:00	14,43	1		1	1		1			
	19/12/22 14:00	14,46	1		1	1		1			
	19/12/22 15:00	14,61	1		1	1		1			
	19/12/22 16:00	15,18	1		1	1		1			
	19/12/22 17:00	16,42	1		1	1	1	1			
	19/12/22 18:00	16,85	1		1	1	1	1			
	19/12/22 19:00	16,62	1		1	1	1	1			
19/12/22 20:00	16,40	1		1	1	1	1				
19/12/22 21:00	15,43	1		1	1		1				
19/12/22 22:00	14,00	1		1	1		1				
19/12/22 23:00	12,85	1		1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τρίτη 20/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τρίτη	20/12/22 0:00	11,45	1		1			1			
	20/12/22 1:00	10,52	1		1			1			
	20/12/22 2:00	10,10	1		1			1			
	20/12/22 3:00	10,04	1		1			1			
	20/12/22 4:00	9,98	1		1			1			
	20/12/22 5:00	10,12	1		1			1			
	20/12/22 6:00	11,37	1		1			1			
	20/12/22 7:00	12,45	1		1			1			
	20/12/22 8:00	12,85	1		1			1			
	20/12/22 9:00	13,56	1		1	1		1			
	20/12/22 10:00	13,66	1		1	1		1			
	20/12/22 11:00	13,82	1		1	1		1			
	20/12/22 12:00	13,97	1		1	1		1			
	20/12/22 13:00	13,99	1		1	1		1			
	20/12/22 14:00	13,84	1		1	1		1			
	20/12/22 15:00	13,78	1		1	1		1			
	20/12/22 16:00	14,39	1		1	1		1			
	20/12/22 17:00	15,53	1		1	1		1			
	20/12/22 18:00	15,85	1		1	1		1			
	20/12/22 19:00	15,65	1		1	1		1			
20/12/22 20:00	15,50	1		1	1		1				
20/12/22 21:00	14,64	1		1	1		1				
20/12/22 22:00	13,36	1		1			1				
20/12/22 23:00	12,50	1		1			1				
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 21/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	21/12/22 0:00	11,15	1		1			1			
	21/12/22 1:00	10,29	1		1			1			
	21/12/22 2:00	9,97	1		1			1			
	21/12/22 3:00	9,78	1		1			1			
	21/12/22 4:00	9,77	1		1			1			
	21/12/22 5:00	10,11	1		1			1			
	21/12/22 6:00	11,29	1		1			1			
	21/12/22 7:00	12,45	1		1			1			
	21/12/22 8:00	12,93	1		1			1			
	21/12/22 9:00	13,73	1		1	1		1			
	21/12/22 10:00	14,00	1		1	1		1			
	21/12/22 11:00	14,20	1		1	1		1			
	21/12/22 12:00	14,60	1		1	1		1			
	21/12/22 13:00	14,63	1		1	1		1			
	21/12/22 14:00	14,68	1		1	1		1			
	21/12/22 15:00	14,78	1		1	1		1			
	21/12/22 16:00	15,16	1		1	1		1			
	21/12/22 17:00	16,38	1		1	1	1	1			
	21/12/22 18:00	16,67	1		1	1	1	1			
	21/12/22 19:00	16,42	1		1	1	1	1			
21/12/22 20:00	16,08	1		1	1		1				
21/12/22 21:00	15,08	1		1	1		1				
21/12/22 22:00	13,81	1		1	1		1				
21/12/22 23:00	12,75	1		1			1				

Παρατηρήσεις:

1) 1 εκ των 16 H/Z βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.
Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη 22/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	22/12/22 0:00	11,75	1		1			1			
	22/12/22 1:00	10,90	1		1			1			
	22/12/22 2:00	10,41	1		1			1			
	22/12/22 3:00	10,27	1		1			1			
	22/12/22 4:00	10,29	1		1			1			
	22/12/22 5:00	10,52	1		1			1			
	22/12/22 6:00	11,47	1		1			1			
	22/12/22 7:00	12,71	1		1			1			
	22/12/22 8:00	13,57	1		1	1		1			
	22/12/22 9:00	14,20	1		1	1		1			
	22/12/22 10:00	14,48	1		1	1		1			
	22/12/22 11:00	14,74	1		1	1		1			
	22/12/22 12:00	14,86	1		1	1		1			
	22/12/22 13:00	14,94	1		1	1		1			
	22/12/22 14:00	15,13	1		1	1		1			
	22/12/22 15:00	15,38	1		1	1		1			
	22/12/22 16:00	16,06	1		1	1		1			
	22/12/22 17:00	17,17	1		1	1	1	1			
	22/12/22 18:00	17,42	1		1	1	1	1	1		
	22/12/22 19:00	17,23	1		1	1	1	1	1		
22/12/22 20:00	17,00	1		1	1	1	1	1			
22/12/22 21:00	16,12	1		1	1		1				
22/12/22 22:00	14,67	1		1	1		1				
22/12/22 23:00	13,34	1		1			1				

Παρατηρήσεις:

1) 1 εκ των 16 H/Z βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.
Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή 23/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	23/12/22 0:00	11,86	1		1			1			
	23/12/22 1:00	11,06	1		1			1			
	23/12/22 2:00	10,57	1		1			1			
	23/12/22 3:00	10,45	1		1			1			
	23/12/22 4:00	10,45	1		1			1			
	23/12/22 5:00	10,69	1		1			1			
	23/12/22 6:00	11,50	1		1			1			
	23/12/22 7:00	12,55	1		1			1			
	23/12/22 8:00	13,71	1		1	1		1			
	23/12/22 9:00	14,72	1		1	1		1			
	23/12/22 10:00	14,90	1		1	1		1			
	23/12/22 11:00	15,13	1		1	1		1			
	23/12/22 12:00	15,14	1		1	1		1			
	23/12/22 13:00	15,03	1		1	1		1			
	23/12/22 14:00	15,21	1		1	1		1			
	23/12/22 15:00	15,43	1		1	1		1			
	23/12/22 16:00	15,91	1		1	1		1			
	23/12/22 17:00	17,50	1		1	1	1	1			
	23/12/22 18:00	17,77	1		1	1	1	1	1		
	23/12/22 19:00	17,44	1		1	1	1	1	1		
23/12/22 20:00	16,74	1		1	1	1	1	1			
23/12/22 21:00	15,89	1		1	1		1				
23/12/22 22:00	14,58	1		1	1		1				
23/12/22 23:00	13,36	1		1			1				

Παρατηρήσεις:

1) 1 εκ των 16 H/Z βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.
Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο 24/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	24/12/22 0:00	12,42	1		1			1			
	24/12/22 1:00	11,48	1		1			1			
	24/12/22 2:00	10,92	1		1			1			
	24/12/22 3:00	10,80	1		1			1			
	24/12/22 4:00	10,73	1		1			1			
	24/12/22 5:00	10,98	1		1			1			
	24/12/22 6:00	11,88	1		1			1			
	24/12/22 7:00	12,77	1		1			1			
	24/12/22 8:00	14,04	1		1	1		1			
	24/12/22 9:00	14,98	1		1	1		1			
	24/12/22 10:00	15,29	1		1	1		1			
	24/12/22 11:00	15,49	1		1	1		1			
	24/12/22 12:00	15,50	1		1	1		1			
	24/12/22 13:00	15,18	1		1	1		1			
	24/12/22 14:00	15,22	1		1	1		1			
	24/12/22 15:00	15,27	1		1	1		1			
	24/12/22 16:00	15,82	1		1	1		1			
	24/12/22 17:00	17,93	1		1	1	1	1			
	24/12/22 18:00	17,86	1		1	1	1	1	1		
	24/12/22 19:00	17,58	1		1	1	1	1	1		
24/12/22 20:00	16,90	1		1	1	1	1	1			
24/12/22 21:00	16,15	1		1	1		1				
24/12/22 22:00	14,98	1		1	1		1				
24/12/22 23:00	13,79	1		1	1		1				
Παρατηρήσεις:											
1) 1 εκ των 16 H/Z βρίσκεται σε συντήρηση.											
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή 25/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Κυριακή	25/12/22 0:00	12,54	1		1			1			
	25/12/22 1:00	11,59	1		1			1			
	25/12/22 2:00	11,03	1		1			1			
	25/12/22 3:00	10,91	1		1			1			
	25/12/22 4:00	10,83	1		1			1			
	25/12/22 5:00	11,09	1		1			1			
	25/12/22 6:00	11,99	1		1			1			
	25/12/22 7:00	12,90	1		1			1			
	25/12/22 8:00	14,18	1		1	1		1			
	25/12/22 9:00	15,13	1		1	1		1			
	25/12/22 10:00	15,44	1		1	1		1			
	25/12/22 11:00	15,64	1		1	1		1			
	25/12/22 12:00	15,65	1		1	1		1			
	25/12/22 13:00	15,33	1		1	1		1			
	25/12/22 14:00	15,37	1		1	1		1			
	25/12/22 15:00	15,42	1		1	1		1			
	25/12/22 16:00	15,98	1		1	1		1			
	25/12/22 17:00	18,11	1		1	1	1	1			
	25/12/22 18:00	18,04	1		1	1	1	1	1		
	25/12/22 19:00	17,75	1		1	1	1	1	1		
25/12/22 20:00	17,07	1		1	1	1	1	1			
25/12/22 21:00	16,39	1		1	1	1	1	1			
25/12/22 22:00	15,13	1		1	1		1				
25/12/22 23:00	13,93	1		1	1	1	1				

Παρατηρήσεις:

1) 1 εκ των 16 H/Z βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.
Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα 26/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Δευτέρα	26/12/22 0:00	12,13	1		1			1			
	26/12/22 1:00	11,22	1		1			1			
	26/12/22 2:00	10,69	1		1			1			
	26/12/22 3:00	10,57	1		1			1			
	26/12/22 4:00	10,51	1		1			1			
	26/12/22 5:00	10,76	1		1			1			
	26/12/22 6:00	11,63	1		1			1			
	26/12/22 7:00	12,54	1		1			1			
	26/12/22 8:00	13,77	1		1	1		1			
	26/12/22 9:00	14,71	1		1	1		1			
	26/12/22 10:00	14,99	1		1	1		1			
	26/12/22 11:00	15,19	1		1	1		1			
	26/12/22 12:00	15,20	1		1	1		1			
	26/12/22 13:00	14,92	1		1	1		1			
	26/12/22 14:00	14,99	1		1	1		1			
	26/12/22 15:00	15,07	1		1	1		1			
	26/12/22 16:00	15,61	1		1	1		1			
	26/12/22 17:00	17,58	1		1	1	1	1			
	26/12/22 18:00	17,58	1		1	1	1	1			
	26/12/22 19:00	17,29	1		1	1	1	1			
26/12/22 20:00	16,62	1		1	1	1	1				
26/12/22 21:00	15,86	1		1	1		1				
26/12/22 22:00	14,68	1		1	1		1				
26/12/22 23:00	13,57	1		1	1		1				

Παρατηρήσεις:

1) 1 εκ των 16 H/Z βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.
Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τρίτη 27/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τρίτη	27/12/22 0:00	12,27	1		1			1			
	27/12/22 1:00	11,35	1		1			1			
	27/12/22 2:00	10,81	1		1			1			
	27/12/22 3:00	10,69	1		1			1			
	27/12/22 4:00	10,62	1		1			1			
	27/12/22 5:00	10,87	1		1			1			
	27/12/22 6:00	11,75	1		1			1			
	27/12/22 7:00	12,65	1		1			1			
	27/12/22 8:00	13,91	1		1	1		1			
	27/12/22 9:00	14,85	1		1	1		1			
	27/12/22 10:00	15,14	1		1	1		1			
	27/12/22 11:00	15,34	1		1	1		1			
	27/12/22 12:00	15,35	1		1	1		1			
	27/12/22 13:00	15,05	1		1	1		1			
	27/12/22 14:00	15,10	1		1	1		1			
	27/12/22 15:00	15,17	1		1	1		1			
	27/12/22 16:00	15,72	1		1	1		1			
	27/12/22 17:00	17,76	1		1	1	1	1			
	27/12/22 18:00	17,72	1		1	1	1	1	1		
	27/12/22 19:00	17,44	1		1	1	1	1	1		
27/12/22 20:00	16,76	1		1	1	1	1	1			
27/12/22 21:00	16,01	1		1	1		1				
27/12/22 22:00	14,83	1		1	1		1				
27/12/22 23:00	13,68	1		1	1		1				
Παρατηρήσεις:											
1) 1 εκ των 16 H/Z βρίσκεται σε συντήρηση.											
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη 28/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Τετάρτη	28/12/22 0:00	11,90	1		1			1			
	28/12/22 1:00	10,98	1		1			1			
	28/12/22 2:00	10,49	1		1			1			
	28/12/22 3:00	10,36	1		1			1			
	28/12/22 4:00	10,27	1		1			1			
	28/12/22 5:00	10,44	1		1			1			
	28/12/22 6:00	11,19	1		1			1			
	28/12/22 7:00	11,85	1		1			1			
	28/12/22 8:00	12,86	1		1			1			
	28/12/22 9:00	13,59	1		1	1		1			
	28/12/22 10:00	13,68	1		1	1		1			
	28/12/22 11:00	13,83	1		1	1		1			
	28/12/22 12:00	13,90	1		1	1		1			
	28/12/22 13:00	13,76	1		1	1		1			
	28/12/22 14:00	13,77	1		1	1		1			
	28/12/22 15:00	13,91	1		1	1		1			
	28/12/22 16:00	14,55	1		1	1		1			
	28/12/22 17:00	16,19	1		1	1	1	1			
	28/12/22 18:00	16,49	1		1	1	1	1	1		
	28/12/22 19:00	16,27	1		1	1	1	1	1		
28/12/22 20:00	15,64	1		1	1		1				
28/12/22 21:00	14,76	1		1	1		1				
28/12/22 22:00	13,93	1		1	1		1				
28/12/22 23:00	12,99	1		1			1				
Παρατηρήσεις:											
1) 1 εκ των 16 H/Z βρίσκεται σε συντήρηση.											
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη 29/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Πέμπτη	29/12/22 0:00	11,71	1			1		1			
	29/12/22 1:00	10,82	1			1		1			
	29/12/22 2:00	10,44	1			1		1			
	29/12/22 3:00	10,26	1			1		1			
	29/12/22 4:00	10,16	1			1		1			
	29/12/22 5:00	10,25	1			1		1			
	29/12/22 6:00	10,90	1			1		1			
	29/12/22 7:00	11,27	1			1		1			
	29/12/22 8:00	12,10	1			1		1			
	29/12/22 9:00	12,62	1			1		1			
	29/12/22 10:00	12,67	1			1		1			
	29/12/22 11:00	12,67	1			1		1			
	29/12/22 12:00	12,58	1			1		1			
	29/12/22 13:00	12,84	1			1		1			
	29/12/22 14:00	12,73	1			1		1			
	29/12/22 15:00	12,86	1			1		1			
	29/12/22 16:00	13,45	1		1	1		1			
	29/12/22 17:00	14,87	1		1	1		1			
	29/12/22 18:00	15,51	1		1	1		1			
	29/12/22 19:00	15,40	1		1	1		1			
29/12/22 20:00	14,79	1		1	1		1				
29/12/22 21:00	13,56	1		1	1		1				
29/12/22 22:00	13,17	1			1		1				
29/12/22 23:00	12,72	1			1		1				

Παρατηρήσεις:

1) 1 εκ των 16 H/Z βρίσκεται σε συντήρηση.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή				30/12/2022
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Παρασκευή	30/12/22 0:00	11,65	1			1		1			
	30/12/22 1:00	10,76	1			1		1			
	30/12/22 2:00	10,39	1			1		1			
	30/12/22 3:00	10,14	1			1		1			
	30/12/22 4:00	10,06	1			1		1			
	30/12/22 5:00	10,22	1			1		1			
	30/12/22 6:00	10,90	1			1		1			
	30/12/22 7:00	11,30	1			1		1			
	30/12/22 8:00	12,26	1			1		1			
	30/12/22 9:00	12,77	1			1		1			
	30/12/22 10:00	12,85	1			1		1			
	30/12/22 11:00	12,81	1			1		1			
	30/12/22 12:00	12,76	1			1		1			
	30/12/22 13:00	13,07	1			1		1			
	30/12/22 14:00	13,01	1			1		1			
	30/12/22 15:00	13,08	1			1		1			
	30/12/22 16:00	13,63	1		1	1		1			
	30/12/22 17:00	15,25	1		1	1		1			
	30/12/22 18:00	15,50	1		1	1		1			
	30/12/22 19:00	15,31	1		1	1		1			
30/12/22 20:00	14,99	1		1	1		1				
30/12/22 21:00	13,53	1		1	1		1				
30/12/22 22:00	13,24	1			1		1				
30/12/22 23:00	12,52	1			1		1				
Παρατηρήσεις:											
1) 1 εκ των 16 H/Z βρίσκεται σε συντήρηση.											
		Μη διαθεσιμότητα μονάδας λόγω συντήρησης.									
		Μη διαθεσιμότητα μονάδας λόγω βλάβης.									

ΗΣ ΘΗΡΑΣ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο 31/12/2022				
Αποδιδόμενη Ισχύς (MW)			7,3	7,3	3,5	3,5	3,5	5,8	12	10,65	1,1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x16)
Σάββατο	31/12/22 0:00	12,54	1		1			1			
	31/12/22 1:00	11,62	1		1			1			
	31/12/22 2:00	11,12	1		1			1			
	31/12/22 3:00	10,92	1		1			1			
	31/12/22 4:00	10,88	1		1			1			
	31/12/22 5:00	11,12	1		1			1			
	31/12/22 6:00	12,01	1		1			1			
	31/12/22 7:00	12,99	1		1			1			
	31/12/22 8:00	13,90	1		1	1		1			
	31/12/22 9:00	14,66	1		1	1		1			
	31/12/22 10:00	14,90	1		1	1		1			
	31/12/22 11:00	15,13	1		1	1		1			
	31/12/22 12:00	15,33	1		1	1		1			
	31/12/22 13:00	15,31	1		1	1		1			
	31/12/22 14:00	15,38	1		1	1		1			
	31/12/22 15:00	15,61	1		1	1		1			
	31/12/22 16:00	16,04	1		1	1		1			
	31/12/22 17:00	17,88	1		1	1	1	1			
	31/12/22 18:00	18,00	1		1	1	1	1	1		
	31/12/22 19:00	17,82	1		1	1	1	1	1		
31/12/22 20:00	17,24	1		1	1	1	1	1			
31/12/22 21:00	16,41	1		1	1	1	1	1			
31/12/22 22:00	15,05	1		1	1		1				
31/12/22 23:00	13,90	1		1	1	1	1				
Παρατηρήσεις:											
1) 1 εκ των 16 H/Z βρίσκεται σε συντήρηση.											
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											