

[illegible]

[illegible]

[illegible]

Δευτέρα, 1 Ιανουάριος 2024		Προτεινόμενος ΗΕΠ Μεγίστης																								
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		0,383	0,362	0,351	0,357	0,346	0,367	0,397	0,380	0,414	0,378	0,350	0,370	0,428	0,396	0,382	0,383	0,395	0,479	0,484	0,461	0,479	0,467	0,430	0,415	9,65
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (VOLVO PENTA TAD 1645GE)	0,4	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (VOLVO PENTA TAD 1645GE)	0,4																									
G3 (CUMMINS VTA 28G5)	0,4																									
G4 (VOLVO PENTA TAD 1345GE)	0,25																									
G5 (HYUNDAI KD8AX)	0,2																									
G6 (DOOSAN P158LE-2)	0,22	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
G7 (DOOSAN P158LE-2)	0,22																									
G8 (SCANIA S550E5)	0,4																									

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Δευτέρα, 15 Ιανουάριος 2024		Προτεινόμενος ΗΕΠ Μεγίστης																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		0,318	0,314	0,316	0,356	0,394	0,389	0,371	0,388	0,410	0,446	0,427	0,457	0,471	0,442	0,399	0,401	0,434	0,502	0,536	0,529	0,512	0,459	0,425	0,414	10,11	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (VOLVO PENTA TAD 1645GE)	0,4	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (VOLVO PENTA TAD 1645GE)	0,4																										
G3 (CUMMINS VTA 28G5)	0,4																										
G4 (VOLVO PENTA TAD 1345GE)	0,25																										
G5 (HYUNDAI KD8AX)	0,2																		1	1	1	1					
G6 (DOOSAN P158LE-2)	0,22	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		
G7 (DOOSAN P158LE-2)	0,22																										
G8 (SCANIA S550E5)	0,4																										

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Παρασκευή, 12 Ιούλιος 2024		Προτεινόμενος ΗΕΠ Μεγίστης																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		0,776	0,740	0,710	0,676	0,635	0,618	0,637	0,747	0,823	0,898	0,865	0,853	0,877	0,985	1,051	1,052	1,006	1,005	1,047	1,073	1,013	1,004	0,975	0,929	20,99	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (VOLVO PENTA TAD 1645GE)	0,32	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (VOLVO PENTA TAD 1645GE)	0,32										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		
G3 (CUMMINS VTA 28G5)	0,4	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		
G4 (VOLVO PENTA TAD 1345GE)	0,25																										
G5 (HYUNDAI KD8AX)	0,18																										
G6 (DOOSAN P158LE-2)	0,22	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		
G7 (DOOSAN P158LE-2)	0,22																										
G8 (SCANIA S550E5)	0,4																										

[illegible]

Κυριακή, 14 Ιούλιος 2024		Προτεινόμενος ΗΕΠ Μεγίστης																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		0,933	0,890	0,851	0,824	0,797	0,767	0,762	0,830	0,899	0,988	1,036	1,064	1,084	1,119	1,120	1,109	1,097	1,105	1,124	1,116	1,110	1,091	1,050	0,985	23,75	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (VOLVO PENTA TAD 1645GE)	0,32	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (VOLVO PENTA TAD 1645GE)	0,32	1	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		
G3 (CUMMINS VTA 28G5)	0,4	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		
G4 (VOLVO PENTA TAD 1345GE)	0,25																										
G5 (HYUNDAI KD8AX)	0,18																										
G6 (DOOSAN P158LE-2)	0,22																										
G7 (DOOSAN P158LE-2)	0,22	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		
G8 (SCANIA S550E5)	0,4																										

[illegible]

Τρίτη, 16 Ιούλιος 2024		Προτεινόμενος ΗΕΠ Μεγίστης																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		1,003	0,940	0,897	0,861	0,839	0,828	0,684	0,900	0,974	1,019	1,069	1,120	1,123	1,164	1,158	1,185	1,177	1,153	1,080	1,076	1,116	1,149	1,095	1,053	24,66	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (VOLVO PENTA TAD 1645GE)	0,32	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (VOLVO PENTA TAD 1645GE)	0,32	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		
G3 (CUMMINS VTA 28G5)	0,4	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		
G4 (VOLVO PENTA TAD 1345GE)	0,25																										
G5 (HYUNDAI KD8AX)	0,18																										
G6 (DOOSAN P158LE-2)	0,22	1													1	1	1	1	1	1	1	1	1	1	1		
G7 (DOOSAN P158LE-2)	0,22									1	1	1	1	1	1	1	1	1									
G8 (SCANIA S550E5)	0,4																										

[illegible]

Πέμπτη, 18 Ιούλιος 2024		Προτεινόμενος ΗΕΠ Μεγίστης																										
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)		
Εκτίμηση ζήτησης (MWh)		1,065	1,023	0,986	0,937	0,911	0,903	0,869	0,948	1,026	1,087	1,130	1,177	1,124	1,207	1,190	1,183	1,147	1,162	1,181	1,154	1,143	1,105	1,058	1,011	25,72		
Μονάδα	Αποδιδόμενη Ισχύς (MW)																											
G1 (VOLVO PENTA TAD 1645GE)	0,32	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη		
G2 (VOLVO PENTA TAD 1645GE)	0,32	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη		
G3 (CUMMINS VTA 28G5)	0,4	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη		
G4 (VOLVO PENTA TAD 1345GE)	0,25																									Διαθέσιμη		
G5 (HYUNDAI KD8AX)	0,18																									Διαθέσιμη		
G6 (DOOSAN P158LE-2)	0,22	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1				Διαθέσιμη		
G7 (DOOSAN P158LE-2)	0,22												1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη		
G8 (SCANIA S550E5)	0,4																									Διαθέσιμη		

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Παρασκευή, 13 Σεπτέμβριος 2024		Προτεινόμενος ΗΕΠ Μεγίστης																								
Ώρες Κατανόμης		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		0,802	0,770	0,740	0,702	0,678	0,682	0,668	0,711	0,788	0,831	0,887	0,896	0,888	0,976	1,029	1,022	0,989	0,999	1,004	0,975	0,972	0,941	0,897	0,862	20,71
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (VOLVO PENTA TAD 1645GE)	0,32	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (VOLVO PENTA TAD 1645GE)	0,32	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (CUMMINS VTA 28G5)	0,4																									Διαθέσιμη
G4 (VOLVO PENTA TAD 1345GE)	0,25																									Διαθέσιμη
G5 (HYUNDAI KD8AX)	0,18	1	1	1											1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G6 (DOOSAN P158LE-2)	0,22	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (DOOSAN P158LE-2)	0,22									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (SCANIA S550E5)	0,4																									Διαθέσιμη

[illegible]

[illegible]

[illegible]

Τρίτη, 17 Σεπτέμβριος 2024		Προτεινόμενος ΗΕΠ Μεγίστης																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		0,772	0,740	0,708	0,682	0,664	0,662	0,667	0,705	0,747	0,826	0,917	0,935	1,011	1,002	0,990	0,959	0,936	0,890	0,851	0,874	0,885	0,870	0,862	0,813	19,97	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (VOLVO PENTA TAD 1645GE)	0,32	1	1	1	1	1	1	1	1	1																Διαθέσιμη	
G2 (VOLVO PENTA TAD 1645GE)	0,32										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (CUMMINS VTA 28G5)	0,4	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (VOLVO PENTA TAD 1345GE)	0,25										1	1	1	1	1	1	1	1									Διαθέσιμη
G5 (HYUNDAI KD8AX)	0,18																		1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (DOOSAN P158LE-2)	0,22	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (DOOSAN P158LE-2)	0,22																										Διαθέσιμη
G8 (SCANIA S550E5)	0,4																										Διαθέσιμη

[illegible]

[illegible]

[illegible]

Σάββατο, 28 Σεπτέμβριος 2024		Προτεινόμενος ΗΕΠ Μεγίστης																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		0,538	0,508	0,481	0,453	0,442	0,440	0,434	0,478	0,517	0,599	0,629	0,647	0,659	0,672	0,685	0,665	0,634	0,604	0,619	0,679	0,665	0,621	0,552	0,483	13,70	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (VOLVO PENTA TAD 1645GE)	0,4																									Διαθέσιμη	
G2 (VOLVO PENTA TAD 1645GE)	0,4	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (CUMMINS VTA 28G5)	0,4																										Διαθέσιμη
G4 (VOLVO PENTA TAD 1345GE)	0,25	1																									Διαθέσιμη
G5 (HYUNDAI KD8AX)	0,2																										Διαθέσιμη
G6 (DOOSAN P158LE-2)	0,22										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (DOOSAN P158LE-2)	0,22	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (SCANIA S550E5)	0,4																										Διαθέσιμη

Κυριακή, 29 Σεπτέμβριος 2024		Προτεινόμενος ΗΕΠ Μεγίστης																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		0,445	0,415	0,397	0,388	0,385	0,355	0,347	0,374	0,435	0,568	0,552	0,581	0,588	0,614	0,608	0,588	0,556	0,535	0,555	0,581	0,584	0,565	0,527	0,480	12,02	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (VOLVO PENTA TAD 1645GE)	0,4										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (VOLVO PENTA TAD 1645GE)	0,4	1	1	1	1	1	1	1	1	1																Διαθέσιμη	
G3 (CUMMINS VTA 28G5)	0,4																									Διαθέσιμη	
G4 (VOLVO PENTA TAD 1345GE)	0,25																									Διαθέσιμη	
G5 (HYUNDAI KD8AX)	0,2										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (DOOSAN P158LE-2)	0,22																									Διαθέσιμη	
G7 (DOOSAN P158LE-2)	0,22	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G8 (SCANIA S550E5)	0,4																									Διαθέσιμη	

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 6 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Παρασκευή, 6 Δεκεμβρίου 2024	00:00	0,358	1				1			
	01:00	0,339	1							
	02:00	0,326	1							
	03:00	0,320	1							
	04:00	0,320	1							
	05:00	0,327	1							
	06:00	0,338	1							
	07:00	0,356	1				1			
	08:00	0,384	1				1			
	09:00	0,407	1				1			
	10:00	0,410	1				1			
	11:00	0,403	1				1			
	12:00	0,405	1				1			
	13:00	0,418	1				1			
	14:00	0,427	1				1			
	15:00	0,428	1				1			
	16:00	0,430	1				1			
	17:00	0,448	1				1			
	18:00	0,473	1				1			
	19:00	0,490	1				1			
	20:00	0,489	1				1			
	21:00	0,468	1				1			
	22:00	0,430	1				1			
	23:00	0,384	1				1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Σάββατο, 7 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Σάββατο, 7 Δεκεμβρίου 2024	00:00	0,363	1				1			
	01:00	0,343	1				1			
	02:00	0,328	1							
	03:00	0,320	1							
	04:00	0,317	1							
	05:00	0,321	1							
	06:00	0,330	1							
	07:00	0,348	1				1			
	08:00	0,376	1				1			
	09:00	0,403	1				1			
	10:00	0,411	1				1			
	11:00	0,406	1				1			
	12:00	0,406	1				1			
	13:00	0,417	1				1			
	14:00	0,427	1				1			
	15:00	0,423	1				1			
	16:00	0,428	1				1			
	17:00	0,446	1				1			
	18:00	0,471	1				1			
	19:00	0,488	1				1			
	20:00	0,487	1				1			
	21:00	0,466	1				1			
	22:00	0,431	1				1			
	23:00	0,385	1				1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 8 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Κυριακή, 8 Δεκεμβρίου 2024	00:00	0,366	1				1			
	01:00	0,345	1				1			
	02:00	0,330	1							
	03:00	0,320	1							
	04:00	0,317	1							
	05:00	0,319	1							
	06:00	0,326	1							
	07:00	0,342	1				1			
	08:00	0,370	1				1			
	09:00	0,399	1				1			
	10:00	0,409	1				1			
	11:00	0,403	1				1			
	12:00	0,402	1				1			
	13:00	0,411	1				1			
	14:00	0,420	1				1			
	15:00	0,424	1				1			
	16:00	0,431	1				1			
	17:00	0,448	1				1			
	18:00	0,470	1				1			
	19:00	0,484	1				1			
	20:00	0,482	1				1			
	21:00	0,462	1				1			
	22:00	0,427	1				1			
	23:00	0,382	1				1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 9 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Δευτέρα, 9 Δεκεμβρίου 2024	00:00	0,357	1				1			
	01:00	0,334	1							
	02:00	0,319	1							
	03:00	0,311	1							
	04:00	0,312	1							
	05:00	0,323	1							
	06:00	0,339	1							
	07:00	0,362	1				1			
	08:00	0,384	1				1			
	09:00	0,388	1				1			
	10:00	0,375	1				1			
	11:00	0,374	1				1			
	12:00	0,395	1				1			
	13:00	0,417	1				1			
	14:00	0,424	1				1			
	15:00	0,418	1				1			
	16:00	0,418	1				1			
	17:00	0,435	1				1			
	18:00	0,463	1				1			
	19:00	0,483	1				1			
	20:00	0,484	1				1			
	21:00	0,461	1				1			
	22:00	0,419	1				1			
	23:00	0,365	1				1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 10 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Π Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Τρίτη, 10 Δεκεμβρίου 2024	00:00	0,352	1				1			
	01:00	0,331	1							
	02:00	0,317	1							
	03:00	0,311	1							
	04:00	0,314	1							
	05:00	0,324	1							
	06:00	0,339	1							
	07:00	0,360	1				1			
	08:00	0,383	1				1			
	09:00	0,395	1				1			
	10:00	0,388	1				1			
	11:00	0,383	1				1			
	12:00	0,398	1				1			
	13:00	0,419	1				1			
	14:00	0,424	1				1			
	15:00	0,418	1				1			
	16:00	0,415	1				1			
	17:00	0,429	1				1			
	18:00	0,455	1				1			
	19:00	0,475	1				1			
	20:00	0,475	1				1			
	21:00	0,451	1				1			
	22:00	0,409	1				1			
	23:00	0,353	1				1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 11 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Π Α Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Τετάρτη, 11 Δεκεμβρίου 2024	00:00	0,350	1				1			
	01:00	0,330	1							
	02:00	0,317	1							
	03:00	0,311	1							
	04:00	0,313	1							
	05:00	0,322	1							
	06:00	0,335	1							
	07:00	0,355	1				1			
	08:00	0,381	1				1			
	09:00	0,399	1				1			
	10:00	0,396	1				1			
	11:00	0,391	1				1			
	12:00	0,402	1				1			
	13:00	0,420	1				1			
	14:00	0,426	1				1			
	15:00	0,421	1				1			
	16:00	0,417	1				1			
	17:00	0,428	1				1			
	18:00	0,452	1				1			
	19:00	0,471	1				1			
	20:00	0,471	1				1			
	21:00	0,449	1				1			
	22:00	0,409	1				1			
	23:00	0,357	1				1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 12 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Πέμπτη, 12 Δεκεμβρίου 2024	00:00	0,351	1				1			
	01:00	0,331	1							
	02:00	0,317	1							
	03:00	0,310	1							
	04:00	0,311	1							
	05:00	0,318	1							
	06:00	0,329	1							
	07:00	0,349	1				1			
	08:00	0,378	1				1			
	09:00	0,401	1				1			
	10:00	0,403	1				1			
	11:00	0,399	1				1			
	12:00	0,407	1				1			
	13:00	0,423	1				1			
	14:00	0,429	1				1			
	15:00	0,423	1				1			
	16:00	0,419	1				1			
	17:00	0,431	1				1			
	18:00	0,455	1				1			
	19:00	0,474	1				1			
	20:00	0,475	1				1			
	21:00	0,454	1				1			
	22:00	0,416	1				1			
	23:00	0,367	1				1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 13 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Παρασκευή, 13 Δεκεμβρίου 2024	00:00	0,341	1				1			
	01:00	0,323	1							
	02:00	0,311	1							
	03:00	0,307	1							
	04:00	0,311	1							
	05:00	0,321	1							
	06:00	0,333	1							
	07:00	0,350	1				1			
	08:00	0,373	1				1			
	09:00	0,392	1				1			
	10:00	0,391	1				1			
	11:00	0,379	1				1			
	12:00	0,381	1				1			
	13:00	0,395	1				1			
	14:00	0,407	1				1			
	15:00	0,412	1				1			
	16:00	0,419	1				1			
	17:00	0,440	1				1			
	18:00	0,468	1				1			
	19:00	0,488	1				1			
	20:00	0,488	1				1			
	21:00	0,465	1				1			
	22:00	0,425	1				1			
	23:00	0,374	1				1			



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Σάββατο, 14 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Σάββατο, 14 Δεκεμβρίου 2024	00:00	0,341	1				1			
	01:00	0,323	1							
	02:00	0,310	1							
	03:00	0,305	1							
	04:00	0,307	1							
	05:00	0,315	1							
	06:00	0,326	1							
	07:00	0,342	1				1			
	08:00	0,366	1				1			
	09:00	0,387	1				1			
	10:00	0,389	1				1			
	11:00	0,377	1				1			
	12:00	0,373	1				1			
	13:00	0,383	1				1			
	14:00	0,396	1				1			
	15:00	0,420	1				1			
	16:00	0,430	1				1			
	17:00	0,450	1				1			
	18:00	0,476	1				1			
	19:00	0,493	1				1			
	20:00	0,492	1				1			
	21:00	0,470	1				1			
	22:00	0,432	1				1			
	23:00	0,384	1				1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 15 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Κυριακή, 15 Δεκεμβρίου 2024	00:00	0,356	1				1			
	01:00	0,336	1				1			
	02:00	0,320	1							
	03:00	0,311	1							
	04:00	0,308	1							
	05:00	0,310	1							
	06:00	0,316	1							
	07:00	0,330	1							
	08:00	0,358	1				1			
	09:00	0,388	1				1			
	10:00	0,401	1				1			
	11:00	0,397	1				1			
	12:00	0,397	1				1			
	13:00	0,406	1				1			
	14:00	0,416	1				1			
	15:00	0,424	1				1			
	16:00	0,435	1				1			
	17:00	0,453	1				1			
	18:00	0,476	1				1			
	19:00	0,491	1				1			
	20:00	0,488	1				1			
	21:00	0,464	1				1			
	22:00	0,426	1				1			
	23:00	0,378	1				1			



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 16 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Δευτέρα, 16 Δεκεμβρίου 2024	00:00	0,350	1				1			
	01:00	0,327	1							
	02:00	0,312	1							
	03:00	0,305	1							
	04:00	0,306	1							
	05:00	0,316	1							
	06:00	0,333	1							
	07:00	0,356	1				1			
	08:00	0,380	1				1			
	09:00	0,385	1				1			
	10:00	0,373	1				1			
	11:00	0,373	1				1			
	12:00	0,395	1				1			
	13:00	0,414	1				1			
	14:00	0,418	1				1			
	15:00	0,413	1				1			
	16:00	0,414	1				1			
	17:00	0,431	1				1			
	18:00	0,456	1				1			
	19:00	0,474	1				1			
	20:00	0,473	1				1			
	21:00	0,451	1				1			
	22:00	0,411	1				1			
	23:00	0,358	1				1			



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 17 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Τρίτη, 17 Δεκεμβρίου 2024	00:00	0,346	1				1			
	01:00	0,325	1							
	02:00	0,310	1							
	03:00	0,304	1							
	04:00	0,308	1							
	05:00	0,318	1							
	06:00	0,334	1				1			
	07:00	0,355	1				1			
	08:00	0,379	1				1			
	09:00	0,391	1				1			
	10:00	0,384	1				1			
	11:00	0,380	1				1			
	12:00	0,394	1				1			
	13:00	0,415	1				1			
	14:00	0,423	1				1			
	15:00	0,421	1				1			
	16:00	0,421	1				1			
	17:00	0,435	1				1			
	18:00	0,458	1				1			
	19:00	0,477	1				1			
	20:00	0,476	1				1			
	21:00	0,453	1				1			
	22:00	0,410	1				1			
	23:00	0,355	1				1			



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 18 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Τετάρτη, 18 Δεκεμβρίου 2024	00:00	0,344	1				1			
	01:00	0,324	1							
	02:00	0,311	1							
	03:00	0,306	1							
	04:00	0,310	1							
	05:00	0,321	1							
	06:00	0,336	1				1			
	07:00	0,357	1				1			
	08:00	0,382	1				1			
	09:00	0,395	1				1			
	10:00	0,388	1				1			
	11:00	0,379	1				1			
	12:00	0,388	1				1			
	13:00	0,407	1				1			
	14:00	0,417	1				1			
	15:00	0,419	1				1			
	16:00	0,425	1				1			
	17:00	0,443	1				1			
	18:00	0,470	1				1			
	19:00	0,488	1				1			
	20:00	0,485	1				1			
	21:00	0,460	1				1			
	22:00	0,416	1				1			
	23:00	0,361	1				1			



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 19 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Πέμπτη, 19 Δεκεμβρίου 2024	00:00	0,341	1				1			
	01:00	0,323	1							
	02:00	0,311	1							
	03:00	0,307	1							
	04:00	0,312	1							
	05:00	0,324	1							
	06:00	0,338	1				1			
	07:00	0,357	1				1			
	08:00	0,381	1				1			
	09:00	0,397	1				1			
	10:00	0,393	1				1			
	11:00	0,383	1				1			
	12:00	0,388	1				1			
	13:00	0,405	1				1			
	14:00	0,418	1				1			
	15:00	0,423	1				1			
	16:00	0,431	1				1			
	17:00	0,450	1				1			
	18:00	0,476	1				1			
	19:00	0,494	1				1			
	20:00	0,491	1				1			
	21:00	0,467	1				1			
	22:00	0,426	1				1			
	23:00	0,374	1				1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Παρασκευή, 20 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Παρασκευή, 20 Δεκεμβρίου 2024	00:00	0,406	1					1		
	01:00	0,388	1					1		
	02:00	0,376	1					1		
	03:00	0,369	1					1		
	04:00	0,367	1					1		
	05:00	0,378	1					1		
	06:00	0,392	1					1		
	07:00	0,404	1					1		
	08:00	0,430	1					1		
	09:00	0,453	1					1		
	10:00	0,449	1					1		
	11:00	0,444	1					1		
	12:00	0,424	1					1		
	13:00	0,436	1					1		
	14:00	0,465	1					1		
	15:00	0,481	1					1		
	16:00	0,487	1					1		
	17:00	0,524	1					1	1	
	18:00	0,545	1					1	1	
	19:00	0,547	1					1	1	
	20:00	0,542	1					1	1	
	21:00	0,520	1					1	1	
	22:00	0,482	1					1		
	23:00	0,435	1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Σάββατο, 21 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Σάββατο, 21 Δεκεμβρίου 2024	00:00	0,411	1					1		
	01:00	0,390	1					1		
	02:00	0,376	1					1		
	03:00	0,369	1					1		
	04:00	0,365	1					1		
	05:00	0,369	1					1		
	06:00	0,381	1					1		
	07:00	0,394	1					1		
	08:00	0,422	1					1		
	09:00	0,451	1					1		
	10:00	0,459	1					1		
	11:00	0,458	1					1		
	12:00	0,455	1					1		
	13:00	0,465	1					1		
	14:00	0,473	1					1		
	15:00	0,483	1					1		
	16:00	0,489	1					1		
	17:00	0,517	1					1	1	
	18:00	0,539	1					1	1	
	19:00	0,545	1					1	1	
	20:00	0,541	1					1	1	
	21:00	0,523	1					1	1	
	22:00	0,477	1					1		
	23:00	0,435	1					1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Κυριακή, 22 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Κυριακή, 22 Δεκεμβρίου 2024	00:00	0,414	1					1		
	01:00	0,393	1					1		
	02:00	0,378	1					1		
	03:00	0,368	1					1		
	04:00	0,366	1					1		
	05:00	0,368	1					1		
	06:00	0,379	1					1		
	07:00	0,391	1					1		
	08:00	0,418	1					1		
	09:00	0,445	1					1		
	10:00	0,453	1					1		
	11:00	0,441	1					1		
	12:00	0,434	1					1		
	13:00	0,450	1					1		
	14:00	0,467	1					1		
	15:00	0,476	1					1		
	16:00	0,493	1					1	1	
	17:00	0,518	1					1	1	
	18:00	0,536	1					1	1	
	19:00	0,545	1					1	1	
	20:00	0,541	1					1	1	
	21:00	0,521	1					1	1	
	22:00	0,481	1					1		
	23:00	0,436	1					1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 23 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ρ Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερησίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Δευτέρα, 23 Δεκεμβρίου 2024	00:00	0,403	1					1		
	01:00	0,381	1					1		
	02:00	0,369	1					1		
	03:00	0,362	1					1		
	04:00	0,363	1					1		
	05:00	0,372	1					1		
	06:00	0,390	1					1		
	07:00	0,408	1					1		
	08:00	0,425	1					1		
	09:00	0,422	1					1		
	10:00	0,391	1					1		
	11:00	0,397	1					1		
	12:00	0,435	1					1		
	13:00	0,459	1					1		
	14:00	0,467	1					1		
	15:00	0,468	1					1		
	16:00	0,478	1					1		
	17:00	0,502	1					1	1	
	18:00	0,528	1					1	1	
	19:00	0,543	1					1	1	
	20:00	0,540	1					1	1	
	21:00	0,515	1					1	1	
	22:00	0,471	1					1		
	23:00	0,418	1					1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Τρίτη, 24 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Τρίτη, 24 Δεκεμβρίου 2024	00:00	0,399	1					1		
	01:00	0,380	1					1		
	02:00	0,364	1					1		
	03:00	0,355	1					1		
	04:00	0,353	1					1		
	05:00	0,355	1					1		
	06:00	0,366	1					1		
	07:00	0,388	1					1		
	08:00	0,418	1					1		
	09:00	0,435	1					1		
	10:00	0,435	1					1		
	11:00	0,443	1					1		
	12:00	0,444	1					1		
	13:00	0,453	1					1		
	14:00	0,449	1					1		
	15:00	0,445	1					1		
	16:00	0,443	1					1		
	17:00	0,471	1					1		
	18:00	0,495	1					1	1	
	19:00	0,511	1					1	1	
	20:00	0,518	1					1	1	
	21:00	0,490	1					1		
	22:00	0,458	1					1		
	23:00	0,417	1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 25 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ρ Α Ρ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Τετάρτη, 25 Δεκεμβρίου 2024	00:00	0,396	1					1		
	01:00	0,376	1					1		
	02:00	0,360	1					1		
	03:00	0,347	1					1		
	04:00	0,345	1					1		
	05:00	0,348	1					1		
	06:00	0,359	1					1		
	07:00	0,381	1					1		
	08:00	0,412	1					1		
	09:00	0,433	1					1		
	10:00	0,420	1					1		
	11:00	0,390	1					1		
	12:00	0,410	1					1		
	13:00	0,432	1					1		
	14:00	0,439	1					1		
	15:00	0,440	1					1		
	16:00	0,443	1					1		
	17:00	0,473	1					1		
	18:00	0,503	1					1	1	
	19:00	0,520	1					1	1	
	20:00	0,526	1					1	1	
	21:00	0,515	1					1	1	
	22:00	0,479	1					1		
	23:00	0,432	1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Πέμπτη, 26 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)			0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400
Η Ε Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Πέμπτη, 26 Δεκεμβρίου 2024	00:00	0,389	1					1		
	01:00	0,371	1					1		
	02:00	0,357	1					1		
	03:00	0,345	1					1		
	04:00	0,340	1					1		
	05:00	0,342	1					1		
	06:00	0,351	1					1		
	07:00	0,372	1					1		
	08:00	0,403	1					1		
	09:00	0,425	1					1		
	10:00	0,428	1					1		
	11:00	0,425	1					1		
	12:00	0,425	1					1		
	13:00	0,435	1					1		
	14:00	0,442	1					1		
	15:00	0,440	1					1		
	16:00	0,445	1					1		
	17:00	0,471	1					1		
	18:00	0,500	1					1	1	
	19:00	0,520	1					1	1	
	20:00	0,527	1					1	1	
	21:00	0,518	1					1	1	
	22:00	0,484	1					1		
	23:00	0,441	1					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης