

Τρίτη, 21 Ιούλιος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		22,02	19,62	18,47	17,85	17,38	17,58	17,88	19,50	21,40	23,07	23,51	23,38	24,23	24,60	24,19	22,36	24,09	24,78	25,45	26,47	26,91	27,57	26,06	24,27	542,67	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	5,89	5,54	5,11	4,64	4,84	5,14	5,85	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	144,97	
Ελάχιστη θερμική παραγωγή (MWh)		15,67	13,74	12,93	12,74	12,74	12,74	12,74	13,65	15,05	16,72	17,16	17,03	17,88	18,25	17,84	16,01	17,74	18,43	19,10	20,12	20,56	21,22	19,71	17,92	397,70	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	0	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

[illegible]

[illegible]

Παρασκευή, 24 Ιούλιος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		24,67	22,76	21,16	20,49	20,05	19,72	19,27	21,07	23,61	25,77	26,53	26,94	27,02	27,60	27,05	26,30	26,24	27,38	28,50	28,47	28,69	28,62	27,64	26,58	602,11	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		5,90	5,90	5,90	5,90	5,90	5,90	5,78	5,90	5,90	5,90	5,90	5,90	5,90	5,90	5,90	5,90	5,90	5,90	5,90	5,90	5,90	5,90	5,90	5,90	141,48	
Ελάχιστη θερμική παραγωγή (MWh)		18,77	16,86	15,26	14,59	14,15	13,82	13,49	15,17	17,71	19,87	20,63	21,04	21,12	21,70	21,15	20,40	20,34	21,48	22,60	22,57	22,79	22,72	21,74	20,68	460,63	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	0	0	0	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

[illegible]

[illegible]

Δευτέρα, 27 Ιούλιος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		24,60	23,04	21,35	20,54	20,23	20,32	19,96	22,20	24,94	30,27	28,29	29,02	29,79	30,36	30,46	30,46	30,69	31,46	32,58	32,36	32,44	32,70	31,26	30,87	660,21	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	6,35	6,35	6,16	6,07	6,10	5,99	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	151,32	
Ελάχιστη θερμική παραγωγή (MWh)		18,25	16,69	15,00	14,38	14,16	14,22	13,97	15,85	18,59	23,92	21,94	22,67	23,44	24,01	24,11	24,11	24,34	25,11	26,23	26,01	26,09	26,35	24,91	24,52	508,89	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

[illegible]

[illegible]

Πέμπτη, 30 Ιούλιος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		26,60	24,73	23,49	22,30	21,59	21,02	20,92	22,95	24,52	26,80	27,38	27,76	29,06	30,42	30,50	30,25	30,10	30,27	31,68	31,63	31,55	32,01	30,49	30,19	658,22	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	5,85	6,35	6,35	5,93	5,36	5,26	6,35	5,64	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	148,68	
Ελάχιστη θερμική παραγωγή (MWh)		20,25	18,88	17,14	15,95	15,66	15,66	15,66	16,60	18,88	20,45	21,03	21,41	22,71	24,07	24,15	23,90	23,75	23,92	25,33	25,28	25,20	25,66	24,14	23,84	509,54	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	1	1	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Παρασκευή, 31 Ιούλιος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		28,70	26,40	24,49	23,64	22,91	22,28	22,56	23,84	25,97	28,91	30,17	30,33	31,85	33,78	33,85	33,67	32,94	33,64	33,83	33,82	33,87	35,64	35,15	34,59	716,84	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	152,40	
Ελάχιστη θερμική παραγωγή (MWh)		22,35	20,05	18,14	17,29	16,56	15,93	16,21	17,49	19,62	22,56	23,82	23,98	25,50	27,43	27,50	27,32	26,59	27,29	27,48	27,47	27,52	29,29	28,80	28,24	564,44	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	1	1	1	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Σάββατο, 1 Αύγουστος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		30,57	27,72	25,80	24,25	23,36	22,81	21,52	22,91	24,68	26,43	27,52	28,27	29,32	30,23	29,96	29,56	29,44	30,10	31,13	31,32	31,72	32,51	31,52	30,38	673,04	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	6,35	6,35	6,35	6,35	6,35	5,85	6,35	5,80	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	151,36	
Ελάχιστη θερμική παραγωγή (MWh)		24,22	21,37	19,45	17,90	17,01	16,46	15,66	16,56	18,88	20,08	21,17	21,92	22,97	23,88	23,61	23,21	23,09	23,75	24,78	24,97	25,37	26,16	25,17	24,03	521,69	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	1	1	1	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Κυριακή, 2 Αύγουστος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		28,54	26,87	24,61	23,33	22,79	22,20	21,16	21,86	22,38	22,68	23,53	24,16	24,98	25,02	24,20	24,11	24,22	25,33	27,26	27,86	28,83	31,11	30,85	30,98	608,83	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	6,35	5,73	6,35	6,35	6,35	5,49	6,20	6,35	6,35	4,65	5,28	6,10	6,15	5,32	5,23	5,34	6,35	6,35	6,35	6,35	6,35	6,35	6,35	144,39	
Ελάχιστη θερμική παραγωγή (MWh)		22,19	20,52	18,88	16,98	16,44	15,85	15,66	15,66	16,03	16,33	18,88	18,88	18,88	18,88	18,88	18,88	18,88	18,98	20,91	21,51	22,48	24,76	24,50	24,63	464,44	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	1	1	1	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Δευτέρα, 3 Αύγουστος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		29,78	27,40	25,42	24,53	23,78	23,12	23,42	24,74	26,95	30,00	31,30	31,48	33,05	35,06	35,12	34,94	34,18	34,91	35,11	35,10	35,15	36,98	36,48	35,89	743,89	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	6,35	6,35	6,35	6,35	6,35	6,35	5,86	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	151,91	
Ελάχιστη θερμική παραγωγή (MWh)		23,43	21,05	19,07	18,18	17,43	16,77	17,07	18,88	20,60	23,65	24,95	25,13	26,70	28,71	28,77	28,59	27,83	28,56	28,76	28,75	28,80	30,63	30,13	29,54	591,98	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	1	1	1	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	1	1	1	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Τετάρτη, 2 Σεπτέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																							Αιολικό δυναμικό: Χαμηλό		
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		23,82	21,94	21,32	20,61	20,05	19,85	19,57	20,56	23,35	26,06	27,70	28,73	30,74	32,85	33,25	32,68	32,41	32,23	33,07	33,37	35,89	35,44	34,18	32,82	672,50	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	5,64	5,02	4,31	6,01	5,96	5,87	6,17	6,35	6,08	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	146,66	
Ελάχιστη θερμική παραγωγή (MWh)		17,47	16,30	16,30	16,30	14,03	13,90	13,70	14,39	17,00	19,98	21,35	22,38	24,39	26,50	26,90	26,33	26,06	25,88	26,72	27,02	29,54	29,09	27,83	26,47	525,84	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	0	0	0	0	0	0	0	0	0	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	1	1	1	1	1	1	1	1	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	Διαθέσιμη

Πέμπτη, 3 Σεπτέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Χαμηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		29,46	26,69	25,31	23,98	22,61	22,28	21,34	22,35	24,67	26,76	27,91	28,45	29,26	30,45	30,04	29,38	28,85	29,47	30,34	31,17	31,71	30,34	28,10	26,72	657,65	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	6,35	6,35	5,10	6,30	5,97	5,03	6,04	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	149,10	
Ελάχιστη θερμική παραγωγή (MWh)		23,11	20,34	18,96	18,88	16,31	16,31	16,31	16,31	18,32	20,41	21,56	22,10	22,91	24,10	23,69	23,03	22,50	23,12	23,99	24,82	25,36	23,99	21,75	20,37	508,55	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	1	1	1	1	0	0	0	0	0	1	1	1	1	1	1	1	1	1	0	0	0	0	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	0	0	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Παρασκευή, 4 Σεπτέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Χαμηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		24,16	22,29	21,18	20,35	19,67	19,64	19,36	20,87	23,77	26,70	27,87	28,66	29,78	30,76	31,05	29,96	29,17	29,10	29,21	29,03	31,69	30,58	28,72	27,69	631,26	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		5,28	3,41	5,51	4,68	5,90	5,89	5,81	5,20	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	143,29	
Ελάχιστη θερμική παραγωγή (MWh)		18,88	18,88	15,67	15,67	13,77	13,75	13,55	15,67	17,42	20,35	21,52	22,31	23,43	24,41	24,70	23,61	22,82	22,75	22,86	22,68	25,34	24,23	22,37	21,34	487,97	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	1	1	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	3,5	0	0	1	1	0	0	0	1	1	0	0	0	1	1	1	1	1	1	1	1	1	1	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

[illegible]

Κυριακή, 6 Σεπτέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		24,67	22,58	21,16	20,55	19,86	19,64	18,93	19,23	19,86	21,17	22,15	23,51	24,68	24,90	24,65	24,23	24,53	25,42	25,82	26,18	28,58	28,04	27,17	26,62	564,14	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		5,79	6,35	5,49	4,88	4,19	3,97	3,27	3,57	4,19	5,50	6,35	6,35	5,80	6,02	5,77	5,35	5,65	6,35	6,35	6,35	6,35	6,35	6,35	6,35	132,94	
Ελάχιστη θερμική παραγωγή (MWh)		18,88	16,23	15,67	15,67	15,67	15,67	15,67	15,67	15,67	15,67	15,80	17,16	18,88	18,88	18,88	18,88	18,88	19,07	19,47	19,83	22,23	21,69	20,82	20,27	431,20	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	1	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	1	1	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Δευτέρα, 7 Σεπτέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		24,86	22,63	21,33	20,71	20,26	20,11	19,84	21,11	23,59	26,14	27,18	28,31	29,89	30,82	30,39	29,74	29,14	29,49	30,17	30,18	32,36	30,36	28,74	27,68	635,03	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		5,98	6,35	5,66	5,04	4,59	4,44	4,18	5,44	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	143,29	
Ελάχιστη θερμική παραγωγή (MWh)		18,88	16,28	15,67	15,67	15,67	15,67	15,67	15,67	17,24	19,79	20,83	21,96	23,54	24,47	24,04	23,39	22,79	23,14	23,82	23,83	26,01	24,01	22,39	21,33	491,74	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	1	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Τρίτη, 8 Σεπτέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		24,42	22,33	21,08	20,40	20,03	19,97	19,74	20,97	23,63	26,66	27,82	28,65	29,71	30,62	30,58	29,61	28,85	29,15	30,32	30,41	31,80	29,44	27,24	25,43	628,84	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		5,54	6,35	5,41	4,73	4,36	4,30	4,07	5,30	4,75	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	140,07	
Ελάχιστη θερμική παραγωγή (MWh)		18,88	15,98	15,67	15,67	15,67	15,67	15,67	15,67	18,88	20,31	21,47	22,30	23,36	24,27	24,23	23,26	22,50	22,80	23,97	24,06	25,45	23,09	20,89	19,08	488,77	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	1	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

[illegible]

Πέμπτη, 10 Σεπτέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Υψηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		23,22	21,48	20,29	19,48	18,81	18,78	18,96	20,25	22,19	22,99	23,90	24,13	24,78	24,94	24,51	23,85	23,90	25,27	27,40	28,27	29,98	27,58	25,50	24,69	565,16	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		4,34	2,61	6,09	5,84	5,64	5,63	5,69	6,08	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	5,81	142,98	
Ελάχιστη θερμική παραγωγή (MWh)		18,88	18,88	14,20	13,63	13,17	13,14	13,27	14,18	15,84	16,64	17,55	17,78	18,43	18,59	18,16	17,50	17,55	18,92	21,05	21,92	23,63	21,23	19,15	18,88	422,18	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

[illegible]

[illegible]

[illegible]

Δευτέρα, 14 Σεπτέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		21,64	19,63	18,98	18,56	18,14	18,29	18,56	19,81	22,00	23,61	24,28	24,64	25,65	31,70	31,04	25,28	25,01	25,81	27,42	28,15	29,96	28,73	26,63	26,14	579,67	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	5,89	5,70	5,57	5,40	5,49	5,57	5,94	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	147,50	
Ελάχιστη θερμική παραγωγή (MWh)		15,29	13,74	13,29	12,99	12,74	12,80	12,99	13,87	15,65	17,26	17,93	18,29	19,30	25,35	24,69	18,93	18,66	19,46	21,07	21,80	23,61	22,38	20,28	19,79	432,17	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	0	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

[illegible]

[illegible]

[illegible]

[illegible]

Σάββατο, 19 Σεπτέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		23,20	21,18	20,10	19,85	19,21	19,39	18,80	19,72	21,48	23,11	23,94	23,93	24,91	25,64	24,99	24,43	24,25	25,14	25,69	26,52	28,31	26,80	25,40	24,40	560,40	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	6,35	6,03	5,95	5,76	5,82	5,64	5,92	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	149,42	
Ελάχιστη θερμική παραγωγή (MWh)		16,85	14,83	14,07	13,89	13,45	13,57	13,16	13,80	15,13	16,76	17,59	17,58	18,56	19,29	18,64	18,08	17,90	18,79	19,34	20,17	21,96	20,45	19,05	18,05	410,97	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	0	0	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	1	1	1	1	1	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

[illegible]

Δευτέρα, 21 Σεπτέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο		
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)		
Εκτίμηση ζήτησης (MWh)		21,45	19,42	18,71	18,33	17,80	18,32	18,86	20,03	21,60	23,43	24,02	24,37	25,56	26,41	25,56	24,35	23,97	24,97	26,01	28,34	29,67	27,46	24,93	23,78	557,34		
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	5,83	5,61	5,50	5,06	5,50	5,66	6,01	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,04	6,35	6,35	6,35	6,35	6,35	146,80		
Ελάχιστη θερμική παραγωγή (MWh)		15,10	13,59	13,10	12,83	12,74	12,82	13,20	14,02	15,25	17,08	17,67	18,02	19,21	20,06	19,21	18,00	17,62	18,62	19,98	21,99	23,32	21,11	18,58	17,43	410,54		
Μονάδα	Αποδιδόμενη Ισχύς (MW)																											
G1 (CEGIELSKI 9RTAF58)	9	0	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	0	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

[illegible]

Πέμπτη, 24 Σεπτέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Χαμηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		18,40	16,88	16,32	15,99	15,89	17,88	17,08	18,42	21,33	22,54	23,57	24,23	24,61	24,83	23,60	22,62	21,58	22,94	24,10	25,73	26,92	24,32	21,85	20,56	512,21	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		5,52	4,14	3,58	3,25	3,15	5,14	4,34	5,53	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,09	136,00	
Ελάχιστη θερμική παραγωγή (MWh)		12,88	12,74	12,74	12,74	12,74	12,74	12,74	12,89	14,98	16,19	17,22	17,88	18,26	18,48	17,25	16,27	15,23	16,59	17,75	19,38	20,57	17,97	15,50	14,48	376,21	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Δευτέρα, 28 Σεπτέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																							Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		17,61	16,05	15,82	15,51	15,22	15,50	16,71	18,06	20,38	20,94	21,41	22,07	22,52	22,45	21,59	21,77	22,06	22,55	23,52	24,78	26,26	24,25	21,73	20,54	489,31
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		4,23	2,67	2,45	2,13	1,84	2,12	3,33	4,68	6,11	6,28	6,35	6,35	6,22	6,15	6,35	6,35	6,35	6,25	6,35	6,35	6,35	5,02	6,35	6,16	122,79
Ελάχιστη θερμική παραγωγή (MWh)		13,38	13,38	13,38	13,38	13,38	13,38	13,38	13,38	14,27	14,65	15,06	15,72	16,30	16,30	15,24	15,42	15,71	16,30	17,17	18,43	19,91	19,23	15,38	14,38	366,51
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (CEGIELSKI 9RTAF58)	9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G2 (CEGIELSKI 9RTAF58)	11	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	0	1	1	1	1	1	0	0	Διαθέσιμη
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	Διαθέσιμη

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Τρίτη, 13 Οκτώβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Υψηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		16,58	15,57	15,42	15,10	14,57	14,92	16,66	18,30	19,52	19,85	20,29	19,78	20,13	21,65	22,14	20,38	19,58	19,28	21,97	24,93	24,74	23,02	20,88	19,05	464,30	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		3,84	4,67	4,63	4,53	4,37	4,48	3,92	5,49	5,86	5,96	6,09	5,93	6,04	5,98	6,35	6,11	5,87	5,78	3,09	6,05	5,86	4,14	6,26	5,72	127,02	
Ελάχιστη θερμική παραγωγή (MWh)		12,74	10,90	10,79	10,57	10,20	10,45	12,74	12,81	13,66	13,90	14,20	13,85	14,09	15,67	15,79	14,26	13,71	13,50	18,88	18,88	18,88	18,88	14,61	13,34	337,28	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	1	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	1	1	1	1	1	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Παρασκευή, 30 Οκτώβριος 2020		Προτεινόμενος ΗΕΠ Χίου																							Αιολικό δυναμικό: Μέτριο		
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		15,92	14,85	14,06	13,84	13,68	14,47	15,81	17,32	18,12	19,61	18,99	19,46	20,19	20,67	20,24	19,40	19,95	21,77	24,01	24,03	23,48	21,82	19,46	17,76	448,89	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		2,54	4,45	3,90	3,67	3,51	4,31	4,74	3,94	4,74	5,88	5,61	5,84	6,06	6,20	6,07	5,82	5,98	6,35	6,35	6,35	6,35	6,16	3,80	2,09	120,73	
Ελάχιστη θερμική παραγωγή (MWh)		13,38	10,39	10,16	10,16	10,16	10,16	11,07	13,38	13,38	13,73	13,38	13,62	14,13	14,47	14,17	13,58	13,96	15,42	17,66	17,68	17,13	15,66	15,66	15,66	328,16	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11	1	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	2,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	3,5	0	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	Διαθέσιμη	

[illegible]

[illegible]

[illegible]

Τρίτη, 3 Νοέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Χαμηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		16,18	14,66	14,01	13,79	14,07	14,82	16,16	18,18	18,28	20,62	21,08	21,24	21,78	21,66	19,82	19,97	20,06	21,98	24,67	24,62	24,07	22,50	20,08	20,02	464,34	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		3,45	4,40	3,85	3,62	3,90	4,44	3,43	5,44	5,48	6,19	6,32	6,35	6,35	6,35	5,95	4,31	4,40	6,31	6,35	6,35	6,35	6,19	6,02	6,01	127,82	
Ελάχιστη θερμική παραγωγή (MWh)		12,74	10,26	10,16	10,16	10,16	10,37	12,74	12,74	12,80	14,44	14,76	14,89	15,43	15,31	13,88	15,66	15,66	15,66	18,32	18,27	17,72	16,30	14,06	14,01	336,52	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	0	0	0	0	0	1	1	1	0	0	0	0	0	1	1	1	1	0	0	0	0	0	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	1	1	1	1	1	0	0	0	0	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Βλάβη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	0	0	Διαθέσιμη

[illegible]

[illegible]

Παρασκευή, 6 Νοέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Ισχυρό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		17,19	15,38	14,85	14,67	14,66	15,40	17,04	18,48	20,42	19,95	20,41	20,76	20,97	21,64	21,19	20,54	21,21	23,05	25,26	25,99	25,44	24,12	21,44	20,30	480,33	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		4,45	2,64	4,46	4,40	4,40	4,62	5,11	5,54	6,13	5,98	6,12	6,23	6,29	6,35	6,35	6,16	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,09	135,77	
Ελάχιστη θερμική παραγωγή (MWh)		12,74	12,74	10,40	10,27	10,26	10,78	11,93	12,94	14,29	13,96	14,28	14,53	14,68	15,29	14,84	14,38	14,86	16,70	18,91	19,64	19,09	17,77	15,09	14,21	344,56	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G10 (GMT A420.12)	4,2	0	0	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	0	0	Διαθέσιμη

Σάββατο, 7 Νοέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Ισχυρό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		16,64	14,72	13,70	13,40	13,42	14,41	14,90	15,67	16,44	17,01	17,32	17,79	18,18	18,72	18,03	17,91	19,44	22,38	24,69	24,94	24,06	22,29	20,53	18,75	435,33	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		3,91	1,98	3,54	3,24	3,25	4,24	4,47	4,70	4,93	5,10	4,58	5,05	5,44	5,62	5,29	5,17	5,83	6,35	6,35	6,35	6,35	6,35	6,16	5,62	119,88	
Ελάχιστη θερμική παραγωγή (MWh)		12,74	12,74	10,16	10,16	10,16	10,16	10,43	10,97	11,51	11,91	12,74	12,74	12,74	13,10	12,74	12,74	13,61	16,03	18,34	18,59	17,71	15,94	14,37	13,12	315,45	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G10 (GMT A420.12)	4,2	0	0	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	1	1	1	1	1	0	0	0	Διαθέσιμη

Κυριακή, 8 Νοέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																							Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		16,79	15,57	14,58	13,88	13,82	14,20	14,29	15,18	17,00	19,56	20,27	21,79	21,86	20,77	18,25	17,45	18,83	21,83	24,27	24,65	24,45	22,94	20,72	19,51	452,46
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		4,05	2,83	4,37	3,71	3,66	4,03	4,13	4,55	4,26	5,87	6,08	6,35	6,35	6,23	5,47	4,71	5,65	6,17	6,35	6,35	6,35	6,35	6,22	5,85	125,96
Ελάχιστη θερμική παραγωγή (MWh)		12,74	12,74	10,21	10,16	10,16	10,16	10,16	10,62	12,74	13,69	14,19	15,44	15,51	14,54	12,77	12,74	13,18	15,66	17,92	18,30	18,10	16,59	14,50	13,66	326,50
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G10 (GMT A420.12)	4,2	0	0	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	1	1	1	1	1	0	0	Διαθέσιμη

Δευτέρα, 9 Νοέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																							Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		17,19	15,38	14,85	14,67	14,66	15,40	17,04	18,48	19,42	18,94	18,40	18,76	18,97	19,64	19,19	19,54	20,21	23,05	25,26	25,99	25,44	24,11	21,44	20,30	466,31
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		4,45	2,64	4,46	4,40	4,40	4,62	5,11	5,54	5,82	5,68	5,52	5,63	5,69	5,89	5,76	5,86	6,06	6,35	6,35	6,35	6,35	6,35	6,35	6,09	131,73
Ελάχιστη θερμική παραγωγή (MWh)		12,74	12,74	10,40	10,27	10,26	10,78	11,93	12,93	13,59	13,26	12,88	13,13	13,28	13,75	13,43	13,68	14,15	16,70	18,91	19,64	19,09	17,76	15,09	14,21	334,58
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	0	0	0	0	0	1	1	Διαθέσιμη
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	0	0	Διαθέσιμη
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G10 (GMT A420.12)	4,2	0	0	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	Διαθέσιμη

Τρίτη, 10 Νοέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		17,13	15,23	15,02	14,77	14,62	15,54	16,83	19,03	19,96	19,54	18,87	19,01	20,10	20,18	20,26	20,66	21,73	24,24	26,04	26,20	25,94	24,57	22,82	20,16	478,45	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		4,39	4,57	4,50	4,43	4,38	4,66	4,10	5,71	5,99	5,86	5,66	5,70	6,03	6,05	6,08	6,20	6,07	6,35	6,35	6,35	6,35	6,35	6,35	6,05	134,54	
Ελάχιστη θερμική παραγωγή (MWh)		12,74	10,66	10,51	10,34	10,23	10,88	12,74	13,32	13,97	13,68	13,21	13,31	14,07	14,12	14,18	14,46	15,66	17,89	19,69	19,85	19,59	18,22	16,47	14,11	343,91	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	0	0	0	Διαθέσιμη	

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

Σάββατο, 21 Νοέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		18,04	16,37	15,46	15,36	15,63	15,80	16,60	17,40	18,95	21,30	20,82	20,69	24,66	25,07	21,80	22,62	24,12	26,99	29,42	29,27	28,57	27,17	24,80	22,05	518,98	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		2,38	4,91	4,64	4,61	4,69	4,74	4,98	4,66	5,69	6,35	6,25	6,21	5,78	6,19	2,92	3,75	5,25	6,35	6,35	6,35	6,35	6,35	5,92	6,35	128,01	
Ελάχιστη θερμική παραγωγή (MWh)		15,66	11,46	10,83	10,75	10,94	11,06	11,62	12,74	13,27	14,95	14,57	14,48	18,88	18,88	18,88	18,88	18,88	20,64	23,07	22,92	22,22	20,82	18,88	15,70	390,97	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Κυριακή, 22 Νοέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		19,95	17,19	16,30	15,56	15,22	15,67	16,32	16,84	17,76	18,53	19,57	20,20	20,37	20,36	19,11	20,31	22,20	25,83	27,39	28,01	28,10	27,13	23,85	22,32	494,09	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		5,99	3,81	4,89	4,67	4,57	4,70	4,89	4,10	5,02	5,56	5,87	6,06	6,11	6,11	5,73	6,09	6,35	6,35	6,35	6,35	6,35	6,35	4,97	6,35	133,60	
Ελάχιστη θερμική παραγωγή (MWh)		13,97	13,38	11,41	10,89	10,65	10,97	11,42	12,74	12,74	12,97	13,70	14,14	14,26	14,25	13,38	14,22	15,85	19,48	21,04	21,66	21,75	20,78	18,88	15,97	360,49	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	0	0	0	0	0	0	0	1	1	1	1	1	0	0	0	0	0	1	1	1	1	1	1	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	1	1	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Δευτέρα, 23 Νοέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																							Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		18,84	16,71	17,00	16,55	16,04	16,54	17,97	20,50	23,61	26,19	28,13	29,60	30,85	31,36	30,35	31,39	31,50	32,21	33,02	32,82	31,96	29,93	26,30	24,52	613,90
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		5,46	5,01	5,10	4,96	4,81	4,96	5,23	6,15	4,73	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	5,65	140,97
Ελάχιστη θερμική παραγωγή (MWh)		13,38	11,70	11,90	11,58	11,23	11,58	12,74	14,35	18,88	19,84	21,78	23,25	24,50	25,01	24,00	25,04	25,15	25,86	26,67	26,47	25,61	23,58	19,95	18,88	472,93
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (CEGIELSKI 9RTAF58)	9,5	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 9RTAF58)	11,28	1	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G10 (GMT A420.12)	4,2	0	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	0	0	0	Διαθέσιμη

[illegible]

[illegible]

Πέμπτη, 26 Νοέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		20,27	18,23	18,85	18,08	17,32	17,69	19,71	21,44	22,99	23,87	24,26	24,30	26,09	26,03	25,59	27,59	29,36	31,91	33,06	33,30	33,08	30,71	27,74	27,33	598,81	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,08	5,47	5,66	5,34	4,59	4,95	5,91	6,35	6,35	6,35	5,39	5,42	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	144,06	
Ελάχιστη θερμική παραγωγή (MWh)		14,19	12,76	13,20	12,74	12,74	12,74	13,80	15,09	16,64	17,52	18,88	18,88	19,74	19,68	19,24	21,24	23,01	25,56	26,71	26,95	26,73	24,36	21,39	20,98	454,75	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	1	1	1	1	0	0	0	Διαθέσιμη	

Παρασκευή, 27 Νοέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Χαμηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		20,10	18,07	18,69	17,92	17,17	17,53	19,54	21,26	22,79	23,66	24,05	24,09	25,86	25,81	25,37	27,35	29,10	31,63	32,77	33,01	32,79	30,44	27,50	27,09	593,59	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,03	5,33	5,61	5,18	4,44	4,80	5,86	6,35	6,35	6,35	5,17	5,21	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	142,88	
Ελάχιστη θερμική παραγωγή (MWh)		14,07	12,74	13,08	12,74	12,74	12,74	13,67	14,91	16,44	17,31	18,88	18,88	19,51	19,46	19,02	21,00	22,75	25,28	26,42	26,66	26,44	24,09	21,15	20,74	450,70	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	1	1	1	1	0	0	0	Διαθέσιμη	

[illegible]

Κυριακή, 29 Νοέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		20,23	18,11	18,57	17,67	16,85	16,94	17,63	18,58	20,01	21,37	23,39	24,02	24,78	24,86	23,49	24,07	25,84	28,83	30,29	30,29	30,48	29,17	26,15	24,53	556,14	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,07	5,37	5,57	4,94	4,11	4,20	4,89	5,57	6,00	6,35	4,51	5,14	5,91	5,98	4,61	5,19	6,35	6,35	6,35	6,35	6,35	6,35	6,35	5,65	134,51	
Ελάχιστη θερμική παραγωγή (MWh)		14,16	12,74	13,00	12,74	12,74	12,74	12,74	13,01	14,01	15,02	18,88	18,88	18,88	18,88	18,88	18,88	19,49	22,48	23,94	23,94	24,13	22,82	19,80	18,88	421,62	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Δευτέρα, 30 Νοέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		20,21	18,09	18,55	17,66	16,83	16,92	17,61	18,56	19,99	22,34	24,36	25,99	26,76	26,83	25,47	26,04	25,81	28,80	30,26	30,25	30,44	29,14	26,12	24,50	567,53	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,06	5,35	5,56	4,92	4,09	4,18	4,87	5,57	6,00	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	5,62	141,13	
Ελάχιστη θερμική παραγωγή (MWh)		14,15	12,74	12,98	12,74	12,74	12,74	12,74	12,99	13,99	15,99	18,01	19,64	20,41	20,48	19,12	19,69	19,46	22,45	23,91	23,90	24,09	22,79	19,77	18,88	426,40	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

[illegible]

[illegible]

Πέμπτη, 3 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Χαμηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		19,93	17,90	19,12	17,92	17,12	17,78	19,42	21,94	26,53	28,13	29,88	30,99	32,55	33,16	32,25	32,52	32,78	33,93	34,42	34,21	33,99	31,91	28,42	26,65	653,44	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		5,98	5,16	5,74	5,18	4,38	5,04	5,83	3,07	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	4,85	140,46	
Ελάχιστη θερμική παραγωγή (MWh)		13,95	12,74	13,38	12,74	12,74	12,74	13,60	18,88	20,18	21,78	23,53	24,64	26,20	26,81	25,90	26,17	26,43	27,58	28,07	27,86	27,64	25,56	22,07	21,80	512,98	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Παρασκευή, 4 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		21,32	18,72	20,07	19,10	18,14	18,65	20,78	23,05	25,84	27,24	27,63	26,55	27,42	27,55	26,93	30,28	32,64	32,85	34,49	34,74	34,17	32,49	29,19	27,57	637,42	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	5,62	6,02	5,73	5,40	5,59	6,23	4,18	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	146,72	
Ελάχιστη θερμική παραγωγή (MWh)		14,97	13,11	14,05	13,37	12,74	13,05	14,55	18,88	19,49	20,89	21,28	20,20	21,07	21,20	20,58	23,93	26,29	26,50	28,14	28,39	27,82	26,14	22,84	21,22	490,70	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	0	0	Διαθέσιμη
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Σάββατο, 5 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		23,66	19,44	20,27	19,16	18,59	18,87	20,43	22,50	23,87	23,76	24,84	24,81	25,19	25,92	26,03	29,08	29,46	30,43	34,19	34,09	33,49	33,13	28,84	27,38	617,41	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		4,78	5,83	6,08	5,75	5,58	5,66	6,13	3,63	4,99	4,88	5,97	5,93	6,31	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	141,36	
Ελάχιστη θερμική παραγωγή (MWh)		18,88	13,61	14,19	13,41	13,01	13,21	14,30	18,88	18,88	18,88	18,88	18,88	18,88	19,57	19,68	22,73	23,11	24,08	27,84	27,74	27,14	26,78	22,49	21,03	476,05	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	1	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Κυριακή, 6 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		23,79	19,41	18,48	18,96	17,99	18,11	18,88	19,55	21,99	23,53	25,38	27,77	28,71	31,60	29,01	30,80	30,44	29,63	31,74	31,61	31,64	30,28	28,72	25,16	613,19	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		4,92	5,82	5,54	5,69	5,26	5,38	5,66	5,86	6,32	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,28	145,64	
Ελάχιστη θερμική παραγωγή (MWh)		18,88	13,59	12,94	13,27	12,74	12,74	13,22	13,68	15,66	17,18	19,03	21,42	22,36	25,25	22,66	24,45	24,09	23,28	25,39	25,26	25,29	23,93	22,37	18,88	467,55	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	1	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	1	1	1	0	0	0	0	0	0	0	1	1	1	1	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Δευτέρα, 7 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																							Αιολικό δυναμικό: Υψηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		21,91	19,33	20,17	19,28	18,59	18,86	21,89	24,84	26,96	26,70	27,10	26,71	27,74	28,00	27,89	29,94	31,85	33,50	35,09	35,19	34,99	33,01	29,35	27,74	646,63
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	5,80	6,05	5,78	5,58	5,66	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	149,52
Ελάχιστη θερμική παραγωγή (MWh)		15,56	13,53	14,12	13,50	13,02	13,20	15,54	18,49	20,61	20,35	20,75	20,36	21,39	21,65	21,54	23,59	25,50	27,15	28,74	28,84	28,64	26,66	23,00	21,39	497,11
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (CEGIELSKI 9RTAF58)	9,5	0	1	1	1	1	1	1	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 9RTAF58)	11,28	1	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	0	0	Διαθέσιμη

[illegible]

[illegible]

Πέμπτη, 10 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Υψηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		21,19	18,66	19,67	18,71	17,87	18,28	19,99	22,99	24,91	24,42	26,11	25,91	26,01	26,27	25,43	26,25	27,99	31,18	32,49	33,15	32,89	31,46	28,03	26,20	606,06	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	5,60	5,90	5,61	5,13	5,48	6,00	4,12	6,03	5,54	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	144,66	
Ελάχιστη θερμική παραγωγή (MWh)		14,84	13,06	13,77	13,10	12,74	12,80	14,00	18,88	18,88	18,88	19,76	19,56	19,66	19,92	19,08	19,90	21,64	24,83	26,14	26,80	26,54	25,11	21,68	19,85	461,40	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Παρασκευή, 11 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Υψηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		21,08	18,79	19,63	18,65	17,81	18,16	20,15	23,70	26,01	26,97	26,92	26,12	26,63	25,96	26,22	29,15	30,47	32,24	32,34	31,64	31,88	28,86	25,97	26,36	611,71	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		2,21	5,64	5,89	5,60	5,08	5,42	6,04	4,82	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	142,29	
Ελάχιστη θερμική παραγωγή (MWh)		18,88	13,15	13,74	13,06	12,74	12,74	14,10	18,88	19,66	20,62	20,57	19,77	20,28	19,61	19,87	22,80	24,12	25,89	25,99	25,29	25,53	22,51	19,62	20,01	469,42	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	1	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

[illegible]

[illegible]

Δευτέρα, 14 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Υψηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		21,08	18,79	19,63	18,65	17,81	18,16	20,15	23,70	27,01	27,97	28,92	28,12	28,63	26,96	27,22	29,15	30,47	32,24	32,34	31,64	31,88	28,86	25,97	26,36	621,71	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,33	5,64	5,89	5,60	5,08	5,42	6,04	4,82	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	146,41	
Ελάχιστη θερμική παραγωγή (MWh)		14,76	13,15	13,74	13,06	12,74	12,74	14,10	18,88	20,66	21,62	22,57	21,77	22,28	20,61	20,87	22,80	24,12	25,89	25,99	25,29	25,53	22,51	19,62	20,01	475,30	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Συντήρηση	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

[illegible]

[illegible]

Πέμπτη, 17 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Χαμηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		20,14	17,54	18,57	17,41	16,81	17,35	19,56	22,78	25,56	26,45	26,27	27,15	27,79	27,45	25,75	28,20	30,21	31,97	32,20	33,13	33,53	31,34	27,87	26,35	611,39	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,04	4,80	5,57	4,68	4,07	4,61	5,87	3,90	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	141,15	
Ελάχιστη θερμική παραγωγή (MWh)		14,10	12,74	13,00	12,74	12,74	12,74	13,69	18,88	19,21	20,10	19,92	20,80	21,44	21,10	19,40	21,85	23,86	25,62	25,85	26,78	27,18	24,99	21,52	20,00	470,25	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Βλάβη	

[illegible]

[illegible]

[illegible]

Δευτέρα, 21 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		21,49	19,22	20,22	19,24	18,22	18,73	20,71	23,27	25,27	25,75	26,93	27,39	27,86	27,24	25,18	28,13	30,77	33,03	34,16	34,48	33,93	32,67	29,27	27,23	630,36	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	5,77	6,07	5,77	5,47	5,62	6,21	4,39	6,35	6,35	6,35	6,35	6,35	6,35	6,30	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	147,19	
Ελάχιστη θερμική παραγωγή (MWh)		15,14	13,45	14,15	13,47	12,76	13,11	14,50	18,88	18,92	19,40	20,58	21,04	21,51	20,89	18,88	21,78	24,42	26,68	27,81	28,13	27,58	26,32	22,92	20,88	483,16	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Τρίτη, 22 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		20,47	18,38	18,43	18,00	17,32	17,40	18,37	19,51	21,37	23,05	24,26	25,80	26,79	27,02	25,56	27,63	28,88	29,49	29,85	29,89	29,58	28,05	25,66	24,02	574,78	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,14	5,51	5,53	5,26	4,58	4,66	5,51	5,85	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	144,65	
Ελάχιστη θερμική παραγωγή (MWh)		14,33	12,86	12,90	12,74	12,74	12,74	12,86	13,66	15,02	16,70	17,91	19,45	20,44	20,67	19,21	21,28	22,53	23,14	23,50	23,54	23,23	21,70	19,31	17,67	430,13	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0	1	1	1	1	1	1	1	0	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	0	0	0	0	1	1	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Τετάρτη, 23 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																							Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		20,68	18,33	19,18	18,29	17,54	17,93	19,94	23,26	24,45	24,13	23,71	24,20	22,79	23,03	23,11	25,85	29,67	30,29	31,18	31,20	31,27	29,89	27,48	24,52	581,93
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,20	5,50	5,75	5,49	4,81	5,19	5,98	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	4,55	145,07
Ελάχιστη θερμική παραγωγή (MWh)		14,48	12,83	13,43	12,80	12,74	12,74	13,96	16,91	18,10	17,78	17,36	17,85	16,44	16,68	16,76	19,50	23,32	23,94	24,83	24,85	24,92	23,54	21,13	19,98	436,86
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη

Παρατηρήσεις:
 Σημειώνεται πως στις 21/12/2020 τέθηκε σε δοκιμαστική λειτουργία το αιολικό πάρκο Μελανιός, για το οποίο εκδίδεται από τον Διαχειριστή ΜΔΝ πρόγραμμα μέγιστης ωριαίας παραγωγής.

Πέμπτη, 24 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																							Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		20,85	18,58	19,38	18,33	17,63	18,39	20,44	23,58	25,28	26,43	26,56	25,98	25,45	24,60	26,48	28,66	32,04	33,47	34,04	34,12	33,56	31,59	28,79	25,79	620,00
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,25	5,57	5,81	5,50	4,89	5,52	6,13	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	5,82	147,09
Ελάχιστη θερμική παραγωγή (MWh)		14,59	13,00	13,56	12,83	12,74	12,87	14,31	17,23	18,93	20,08	20,21	19,63	19,10	18,25	20,13	22,31	25,69	27,12	27,69	27,77	27,21	25,24	22,44	19,98	472,91
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	1	1	1	1	1	0	0	0	0	0	0	0	1	1	0	0	0	Διαθέσιμη
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη

Παρατηρήσεις:
 Σημειώνεται πως στις 21/12/2020 τέθηκε σε δοκιμαστική λειτουργία το αιολικό πάρκο Μελανιός, για το οποίο εκδίδεται από τον Διαχειριστή ΜΔΝ πρόγραμμα μέγιστης ωριαίας παραγωγής.

Παρασκευή, 25 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																							Αιολικό δυναμικό: Υψηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		22,69	20,37	19,85	19,73	18,90	19,69	21,01	22,15	25,19	31,79	32,67	33,30	31,96	28,98	25,18	26,64	27,82	29,76	30,52	30,98	31,10	29,83	27,61	24,66	632,38
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		2,71	6,11	5,96	5,92	5,67	5,91	6,30	6,35	5,21	6,35	6,35	6,35	6,35	6,35	5,21	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	4,69	142,58
Ελάχιστη θερμική παραγωγή (MWh)		19,98	14,26	13,90	13,81	13,23	13,78	14,71	15,80	19,98	25,44	26,32	26,95	25,61	22,63	19,98	20,29	21,47	23,41	24,17	24,63	24,75	23,48	21,26	19,98	489,80
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G3 (H.S.D/MAN 9K60)	14,476	1	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη

Παρατηρήσεις:
Σημειώνεται πως στις 21/12/2020 τέθηκε σε δοκιμαστική λειτουργία το αιολικό πάρκο Μελανιός, για το οποίο εκδίδεται από τον Διαχειριστή ΜΔΝ πρόγραμμα μέγιστης ωριαίας παραγωγής.

Σάββατο, 26 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																							Αιολικό δυναμικό: Υψηλό	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		22,35	19,46	20,56	19,57	18,85	19,07	19,96	20,87	21,88	24,88	26,11	27,37	27,29	27,23	26,72	29,52	31,64	32,25	32,43	32,01	31,57	30,35	28,88	25,03	615,84
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	5,84	6,17	5,87	5,66	5,72	5,99	6,26	6,35	4,90	6,13	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	5,05	146,49
Ελάχιστη θερμική παραγωγή (MWh)		16,00	13,62	14,39	13,70	13,20	13,35	13,97	14,61	15,53	19,98	19,98	21,02	20,94	20,88	20,37	23,17	25,29	25,90	26,08	25,66	25,22	24,00	22,53	19,98	469,35
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη

Παρατηρήσεις:
Σημειώνεται πως στις 21/12/2020 τέθηκε σε δοκιμαστική λειτουργία το αιολικό πάρκο Μελανιός, για το οποίο εκδίδεται από τον Διαχειριστή ΜΔΝ πρόγραμμα μέγιστης ωριαίας παραγωγής.

Κυριακή, 27 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		22,44	20,20	20,62	20,49	18,98	19,52	22,22	24,20	26,50	26,92	26,25	26,67	27,89	26,88	28,59	31,41	34,46	36,64	37,23	36,21	37,34	32,80	30,29	27,19	661,95	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		2,46	6,06	6,18	6,15	5,69	5,86	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	146,71	
Ελάχιστη θερμική παραγωγή (MWh)		19,98	14,14	14,43	14,34	13,29	13,66	15,87	17,85	20,15	20,57	19,90	20,32	21,54	20,53	22,24	25,06	28,11	30,29	30,88	29,86	30,99	26,45	23,94	20,84	515,24	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	0	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	1	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	1	1	1	0	0	0	0	0	0	0	0	1	1	1	1	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Παρατηρήσεις:
Σημειώνεται πως στις 21/12/2020 τέθηκε σε δοκιμαστική λειτουργία το αιολικό πάρκο Μελανιός, για το οποίο εκδίδεται από τον Διαχειριστή ΜΔΝ πρόγραμμα μέγιστης ωριαίας παραγωγής.

Δευτέρα, 28 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		22,19	19,98	20,39	20,26	18,77	19,31	21,98	23,94	26,21	26,62	25,97	26,38	27,59	26,58	28,27	31,06	34,08	36,23	36,82	35,81	36,93	32,44	29,96	26,89	654,67	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	4,31	6,12	6,08	5,63	5,79	6,31	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	148,54	
Ελάχιστη θερμική παραγωγή (MWh)		15,84	15,67	14,27	14,18	13,14	13,51	15,67	17,59	19,86	20,27	19,62	20,03	21,24	20,23	21,92	24,71	27,73	29,88	30,47	29,46	30,58	26,09	23,61	20,54	506,12	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	0	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	4,5	1	1	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	1	1	1	1	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Παρατηρήσεις:
Σημειώνεται πως στις 21/12/2020 τέθηκε σε δοκιμαστική λειτουργία το αιολικό πάρκο Μελανιός, για το οποίο εκδίδεται από τον Διαχειριστή ΜΔΝ πρόγραμμα μέγιστης ωριαίας παραγωγής.

Τρίτη, 29 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																								Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		21,86	18,80	20,10	19,33	18,53	18,84	21,02	24,78	26,73	26,95	26,23	25,45	26,07	26,63	27,05	30,40	33,21	35,51	36,89	36,78	36,27	34,59	31,15	27,42	650,59	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		6,35	5,64	6,03	5,80	5,56	5,65	6,31	5,90	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	148,84	
Ελάχιστη θερμική παραγωγή (MWh)		15,51	13,16	14,07	13,53	12,97	13,19	14,72	18,88	20,38	20,60	19,88	19,10	19,72	20,28	20,70	24,05	26,86	29,16	30,54	30,43	29,92	28,24	24,80	21,07	501,75	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Παρατηρήσεις:
 Σημειώνεται ότι στις 21/12/2020 τέθηκε σε δοκιμαστική λειτουργία το αιολικό πάρκο Μελανιός, για το οποίο εκδίδεται από τον Διαχειριστή ΜΔΝ πρόγραμμα μέγιστης ωριαίας παραγωγής.

Τετάρτη, 30 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																							Αιολικό δυναμικό: Μέτριο		
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		18,21	14,93	16,50	15,65	14,71	15,26	18,11	20,14	21,15	23,81	26,25	26,23	23,87	23,81	23,53	24,82	26,34	29,31	30,00	31,10	30,11	28,34	25,88	24,27	552,36	
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		5,46	3,29	4,86	4,01	3,07	3,62	5,43	6,04	5,49	6,35	6,35	6,35	4,99	4,94	4,66	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	132,07	
Ελάχιστη θερμική παραγωγή (MWh)		12,75	11,64	11,64	11,64	11,64	11,64	12,67	14,10	15,66	17,46	19,90	19,88	18,88	18,88	18,88	18,47	19,99	22,96	23,65	24,75	23,76	21,99	19,53	17,92	420,29	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0	0	1	1	1	0	0	0	0	Διαθέσιμη	
G2 (CEGIELSKI 9RTAF58)	11,28	1	1	1	1	1	1	1	0	0	0	1	1	1	1	1	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G3 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (H.S.D/MAN 9K60)	14,476	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	Διαθέσιμη
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη	

Παρατηρήσεις:
Σημειώνεται ότι στις 21/12/2020 τέθηκε σε δοκιμαστική λειτουργία το αιολικό πάρκο Μελανιός, για το οποίο εκδίδεται από τον Διαχειριστή ΜΔΝ πρόγραμμα μέγιστης ωριαίας παραγωγής.

Πέμπτη, 31 Δεκέμβριος 2020		Προτεινόμενος ΗΕΠ Χίου																							Αιολικό δυναμικό: Μέτριο	
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Εκτίμηση ζήτησης (MWh)		22,67	18,95	19,96	19,28	18,57	18,58	21,35	23,33	26,50	27,65	27,09	26,59	26,46	26,52	28,97	32,76	33,77	34,54	35,20	35,28	34,53	31,65	28,57	23,81	642,60
Μέγιστη δυνατότητα απορρόφησης αιολικής ενέργειας (MWh)		2,70	5,68	5,99	5,79	5,57	5,57	2,47	4,46	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	6,35	5,53	6,35	3,84	136,49
Ελάχιστη θερμική παραγωγή (MWh)		19,98	13,26	13,97	13,50	13,00	13,00	18,88	18,88	20,15	21,30	20,74	20,24	20,11	20,17	22,62	26,41	27,42	28,19	28,85	28,93	28,18	26,12	22,22	19,98	506,11
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (CEGIELSKI 9RTAF58)	9,5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (CEGIELSKI 9RTAF58)	11,28	0	0	0	0	0	0	1	1	1	0	0	0	0	0	0	1	1	1	1	1	1	1	0	0	Διαθέσιμη
G3 (H.S.D/MAN 9K60)	14,476	1	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (H.S.D/MAN 9K60)	14,476	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G7 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G8 (GMT - FIAT C4212ESS)	3,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G9 (GMT A420.12)	4,5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη
G10 (GMT A420.12)	4,2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Διαθέσιμη

Παρατηρήσεις:
 Σημειώνεται ότι στις 21/12/2020 τέθηκε σε δοκιμαστική λειτουργία το αιολικό πάρκο Μελανιός, για το οποίο εκδίδεται από τον Διαχειριστή ΜΔΝ πρόγραμμα μέγιστης ωριαίας παραγωγής.