

			Προτεινόμενες ώρες έναρξης																							
			0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
ATM	14	10	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
DIESEL 2	10	4,9																								
DIESEL 3	18	14	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
DIESEL 4	18	14																								
DIESEL 5	18	14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
AEP 1	17	4	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	
AEP 2	22	4,5	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	
AEP 3	20	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
AEP 4	27	5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
AEP 5	27,9	5,6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
AEP 6	32,9	6,6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Η/Ζ ΕΝΟΙΚ ΣΟΡΟΝΗΣ	1	0,4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Η/Ζ ΕΝΟΙΚ_ΟΗΣ	1	0,4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
DIESEL 1	17,1	6,8	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	0	
DIESEL 2	17,1	6,8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
DIESEL 3	17,1	6,8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
DIESEL 4	17,1	6,8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
DIESEL 5	17,1	6,8	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	
DIESEL 6	17,1	6,8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
DIESEL 7	17,1	6,8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
ΣΥΝΟΛΟ	256,39	89,26																								
Φορτίο (MW)			59,00	52,00	48,00	46,00	45,00	44,00	55,00	58,00	64,00	66,00	68,00	68,00	70,00	74,00	68,00	66,00	65,00	71,00	75,00	79,00	74,00	73,00	70,00	64,00
Υπολογιζόμενο Setpoint			17,70	14,40	10,40	8,40	7,40	6,40	16,37	16,19	16,26	15,48	15,23	14,76	15,09	16,30	15,00	13,44	16,64	20,48	22,50	23,70	22,20	21,90	21,00	19,20
Μέγιστη Αποδοόμενη Ενταγμένων Μονάδων			66,20	66,20	66,20	66,20	66,20	66,20	66,20	71,00	71,00	71,00	71,00	71,00	71,00	71,00	71,00	66,20	66,20	66,20	83,30	83,30	83,30	83,30	83,30	66,20
Αθροισμα τεχνικών ελαχίστων μονάδων σε λειτουργία			37,60	37,60	37,60	37,60	37,60	37,60	37,60	32,50	32,50	32,50	32,50	32,50	32,50	32,50	32,50	37,60	37,60	37,60	44,40	44,40	44,40	44,40	37,60	37,60
Εκτίμηση δυνατότητας παραγωγής ΑΠ			9,07	9,98	10,70	11,44	12,29	13,03	13,97	15,08	15,63	15,72	16,14	16,76	17,03	17,02	16,83	16,66	16,48	16,06	15,31	14,51	14,35	14,59	14,81	15,00
Εκτίμηση δυνατότητας Φ/Β παραγωγής			0	0	0	0	0	0	0,42	4,02	9,79	14,39	17,24	18,8	19,7	19,67	17,99	14,96	9,55	2,72	0	0	0	0	0	0
Συνολο δυνατότητας εκτίμησης ΑΠΕ			9,07	9,98	10,70	11,44	12,29	13,03	14,39	19,10	25,42	30,11	33,38	35,56	36,73	36,69	34,82	31,62	28,03	18,78	15,31	14,51	14,35	14,59	14,81	15,00