

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 7 Μαΐου 2025						
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Τετάρτη, 7 Μαΐου 2025	00:00	0,709		1					
	01:00	0,646		1					
	02:00	0,635		1					
	03:00	0,628		1					
	04:00	0,624		1					
	05:00	0,645		1					
	06:00	0,702		1					
	07:00	0,726		1					
	08:00	0,833		1					
	09:00	0,894		1					
	10:00	0,955		1			1		
	11:00	0,960		1			1		
	12:00	0,982		1			1		
	13:00	0,890		1			1		
	14:00	0,901		1			1		
	15:00	0,832		1			1		
	16:00	0,842		1					
	17:00	0,873		1					
	18:00	0,892		1					
	19:00	0,957		1					
	20:00	1,012		1					
	21:00	1,024		1					
	22:00	0,899		1					
	23:00	0,766		1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 8 Μαΐου 2025						
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Α Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Πέμπτη, 8 Μαΐου 2025	00:00	0,701		1					
	01:00	0,665		1					
	02:00	0,631		1					
	03:00	0,629		1					
	04:00	0,627		1					
	05:00	0,646		1					
	06:00	0,696		1					
	07:00	0,694		1					
	08:00	0,738		1					
	09:00	0,791		1					
	10:00	0,805		1					
	11:00	0,808		1					
	12:00	0,804		1					
	13:00	0,793		1					
	14:00	0,787		1					
	15:00	0,802		1					
	16:00	0,787		1					
	17:00	0,843		1					
	18:00	0,900		1					
	19:00	0,962		1			1		
	20:00	0,973		1			1		
	21:00	0,987		1			1		
	22:00	0,862		1			1		
	23:00	0,768		1			1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 9 Μαΐου 2025						
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η ε ρ ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Παρασκευή, 9 Μαΐου 2025	00:00	0,689					1		
	01:00	0,653					1		
	02:00	0,644					1		
	03:00	0,627					1		
	04:00	0,609					1		
	05:00	0,625					1		
	06:00	0,671					1		
	07:00	0,675					1		
	08:00	0,747					1	1	
	09:00	0,802					1	1	
	10:00	0,856					1	1	
	11:00	0,827					1	1	
	12:00	0,786					1	1	
	13:00	0,839					1	1	
	14:00	0,856					1	1	
	15:00	0,834					1	1	
	16:00	0,858					1	1	
	17:00	0,905				1	1		
	18:00	0,923				1	1		
	19:00	0,966				1	1		
	20:00	1,027				1	1		
	21:00	0,985				1	1		
	22:00	0,924				1	1		
	23:00	0,824				1	1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 10 Μαΐου 2025						
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Σάββατο, 10 Μαΐου 2025	00:00	0,742					1		
	01:00	0,701					1		
	02:00	0,672					1		
	03:00	0,652					1		
	04:00	0,634					1		
	05:00	0,654					1		
	06:00	0,709					1		
	07:00	0,726					1		
	08:00	0,765					1		
	09:00	0,832		1			1		
	10:00	0,881					1	1	
	11:00	0,820		1			1		
	12:00	0,838		1			1		
	13:00	0,901		1			1		
	14:00	0,919		1			1		
	15:00	0,908		1			1		
	16:00	0,846		1			1		
	17:00	0,894		1			1		
	18:00	0,938		1			1		
	19:00	1,038		1			1		
	20:00	1,058		1			1		
	21:00	1,033		1			1		
	22:00	0,924		1			1		
	23:00	0,837		1			1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 11 Μαΐου 2025						
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η ε π ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Κυριακή, 11 Μαΐου 2025	00:00	0,729		1			1		
	01:00	0,691					1		
	02:00	0,674					1		
	03:00	0,669					1		
	04:00	0,669					1		
	05:00	0,677					1		
	06:00	0,722					1		
	07:00	0,718					1		
	08:00	0,762					1		
	09:00	0,795					1		
	10:00	0,810					1	1	
	11:00	0,826					1	1	
	12:00	0,825					1	1	
	13:00	0,821					1	1	
	14:00	0,828					1	1	
	15:00	0,814					1	1	
	16:00	0,792					1	1	
	17:00	0,846					1	1	
	18:00	0,916					1	1	
	19:00	0,958					1	1	
	20:00	1,018					1	1	
	21:00	0,973					1	1	
	22:00	0,913					1	1	
	23:00	0,798					1	1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 12 Μαΐου 2025						
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ε Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Δευτέρα, 12 Μαΐου 2025	00:00	0,760					1	1	
	01:00	0,697					1		
	02:00	0,648					1		
	03:00	0,618					1		
	04:00	0,627					1		
	05:00	0,656					1		
	06:00	0,707					1		
	07:00	0,713					1		
	08:00	0,767					1		
	09:00	0,786					1		
	10:00	0,801					1	1	
	11:00	0,846				1	1		
	12:00	0,826				1	1		
	13:00	0,831				1	1		
	14:00	0,894				1	1		
	15:00	0,928				1	1		
	16:00	0,835				1	1		
	17:00	0,863				1	1		
	18:00	0,941				1	1		
	19:00	0,999				1	1		
	20:00	1,028				1	1		
	21:00	1,074				1	1		
	22:00	0,951				1	1		
	23:00	0,825				1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 13 Μαΐου 2025						
Αποδιδόμενη Ισχύς (MW)			0,400	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Ε Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Τρίτη, 13 Μαΐου 2025	00:00	0,733					1		
	01:00	0,693					1		
	02:00	0,673					1		
	03:00	0,660					1		
	04:00	0,657					1		
	05:00	0,689					1		
	06:00	0,549					1		
	07:00	0,719					1		
	08:00	0,768					1		
	09:00	0,828		1			1		
	10:00	0,894		1			1		
	11:00	0,917		1			1		
	12:00	0,877		1			1		
	13:00	0,853		1			1		
	14:00	0,831		1			1		
	15:00	0,811		1			1		
	16:00	0,816		1			1		
	17:00	0,883		1			1		
	18:00	0,992		1			1		
	19:00	1,036		1			1		
	20:00	1,082		1			1		
	21:00	1,069		1			1		
	22:00	0,952		1			1		
	23:00	0,841		1			1		

Διάστημα 06:15 – 06:55 σημειώθηκε μερική διακοπή λόγω σφάλματος στο δί

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης