

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 18 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Τετάρτη, 18 Ιουνίου 2025	00:00	1,200						1	1
	01:00	1,087						1	1
	02:00	1,067						1	1
	03:00	1,003						1	1
	04:00	0,950						1	1
	05:00	1,000						1	1
	06:00	1,022						1	1
	07:00	1,115						1	1
	08:00	1,284						1	1
	09:00	1,411						1	1
	10:00	1,462						1	1
	11:00	1,491						1	1
	12:00	1,499						1	1
	13:00	1,480						1	1
	14:00	1,511						1	1
	15:00	1,447						1	1
	16:00	1,476						1	1
	17:00	1,529						1	1
	18:00	1,615						1	1
	19:00	1,639						1	1
	20:00	1,626						1	1
	21:00	1,645						1	1
	22:00	1,581						1	1
	23:00	1,427						1	1



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 19 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000
Η ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Πέμπτη, 19 Ιουνίου 2025	00:00	1,238						1	1
	01:00	1,115						1	1
	02:00	1,074						1	1
	03:00	1,020						1	1
	04:00	1,007						1	1
	05:00	1,019						1	1
	06:00	1,030						1	1
	07:00	1,122						1	1
	08:00	1,277						1	1
	09:00	1,435						1	1
	10:00	1,495			1			1	1
	11:00	1,542			1			1	1
	12:00	1,561			1			1	1
	13:00	1,570			1			1	1
	14:00	1,561			1			1	1
	15:00	1,544			1			1	1
	16:00	1,537			1			1	1
	17:00	1,591			1			1	1
	18:00	1,708			1			1	1
	19:00	1,765			1			1	1
	20:00	1,791			1			1	1
	21:00	1,816			1			1	1
	22:00	1,725			1			1	1
	23:00	1,521			1			1	1



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 20 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)		0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Η ε π ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Παρασκευή, 20 Ιουνίου 2025	00:00	1,381						1	1
	01:00	1,227						1	1
	02:00	1,173						1	1
	03:00	1,154						1	1
	04:00	1,073						1	1
	05:00	1,105						1	1
	06:00	1,080						1	1
	07:00	1,292						1	1
	08:00	1,425						1	1
	09:00	1,565			1			1	1
	10:00	1,657			1			1	1
	11:00	1,701			1			1	1
	12:00	1,693			1			1	1
	13:00	1,790			1			1	1
	14:00	1,831			1			1	1
	15:00	1,825			1			1	1
	16:00	1,824			1			1	1
	17:00	1,911			1			1	1
	18:00	1,996			1			1	1
	19:00	2,039			1			1	1
	20:00	2,071			1			1	1
	21:00	2,082			1			1	1
	22:00	1,987			1			1	1
	23:00	1,828			1			1	1



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 21 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)		0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Η ε π ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Σάββατο, 21 Ιουνίου 2025	00:00	1,670			1			1	1
	01:00	1,527				1			1
	02:00	1,457				1			1
	03:00	1,377				1			1
	04:00	1,353				1			1
	05:00	1,303				1			1
	06:00	1,315				1			1
	07:00	1,368				1			1
	08:00	1,516				1			1
	09:00	1,607			1	1			1
	10:00	1,713			1	1			1
	11:00	1,722			1	1			1
	12:00	1,757			1	1			1
	13:00	1,789			1	1			1
	14:00	1,796			1	1			1
	15:00	1,753			1	1			1
	16:00	1,758			1	1			1
	17:00	1,802			1	1			1
	18:00	1,891			1	1			1
	19:00	1,947			1	1			1
	20:00	1,951			1	1			1
	21:00	1,875			1	1			1
	22:00	1,727			1	1			1
	23:00	1,587			1	1			1



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 22 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000
Η ε π ε ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Κυριακή, 22 Ιουνίου 2025	00:00	1,386				1			1
	01:00	1,259				1			1
	02:00	1,227				1			1
	03:00	1,194				1			1
	04:00	1,158				1			1
	05:00	1,128				1			1
	06:00	1,156				1			1
	07:00	1,250				1			1
	08:00	1,322				1			1
	09:00	1,486				1			1
	10:00	1,596				1		1	1
	11:00	1,570				1		1	1
	12:00	1,584				1		1	1
	13:00	1,562				1		1	1
	14:00	1,529				1		1	1
	15:00	1,509				1		1	1
	16:00	1,494				1		1	1
	17:00	1,575				1		1	1
	18:00	1,669				1		1	1
	19:00	1,719				1		1	1
	20:00	1,697				1		1	1
	21:00	1,728				1		1	1
	22:00	1,575				1		1	1
	23:00	1,409				1		1	1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 23 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)		0,300	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Η Ε Π Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Δευτέρα, 23 Ιουνίου 2025	00:00	1,252				1		1	
	01:00	1,125				1		1	
	02:00	1,100				1		1	
	03:00	1,054				1		1	
	04:00	1,042				1		1	
	05:00	1,032				1		1	
	06:00	1,058				1		1	
	07:00	1,192				1		1	
	08:00	1,305				1		1	
	09:00	1,433				1		1	
	10:00	1,492				1		1	
	11:00	1,468				1		1	
	12:00	1,471				1		1	
	13:00	1,517				1		1	
	14:00	1,526				1		1	
	15:00	1,515				1		1	
	16:00	1,514				1		1	
	17:00	1,588				1		1	
	18:00	1,632				1		1	
	19:00	1,710				1		1	
	20:00	1,760			1	1		1	
	21:00	1,795			1	1		1	
	22:00	1,709			1	1		1	
	23:00	1,529			1	1		1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 24 Ιουνίου 2025						
Αποδιδόμενη Ισχύς (MW)			0,300	1,000	1,000	1,000	1,000	1,000	1,000
Η ω ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
Τρίτη, 24 Ιουνίου 2025	00:00	1,310				1		1	
	01:00	1,163				1		1	
	02:00	1,115				1		1	
	03:00	1,088				1		1	
	04:00	1,058				1		1	
	05:00	1,063				1		1	
	06:00	1,087				1		1	
	07:00	1,233				1		1	
	08:00	1,357				1		1	
	09:00	1,439				1		1	
	10:00	1,480				1		1	
	11:00	1,557				1		1	
	12:00	1,589			1	1		1	
	13:00	1,611			1	1		1	
	14:00	1,633			1	1		1	
	15:00	1,660			1	1		1	
	16:00	1,641			1	1		1	
	17:00	1,678			1	1		1	
	18:00	1,808			1	1		1	
	19:00	1,861			1	1		1	
	20:00	1,931			1	1		1	
	21:00	1,935			1	1		1	
	22:00	1,839			1	1		1	
	23:00	1,736			1	1		1	



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης